

J.C. Broderick & Associates, Inc.

Environmental / Construction Consulting & Testing



January 6, 2026

Mr. Daniel Leddy
Smithtown Central School District
26 New York Avenue
Smithtown, New York 11787

1775 Expressway Drive North
Hauppauge, NY 11788
631.584.5492
Fax: 631.584.3395
www.jcbroderick.com

Re: **Lead Testing in School Drinking Water
Remedial Action Plan
2023-25 Compliance 10 NYCRR Subpart 67-4**

JCB#: **23-54650**

Dear Mr. Leddy:

J.C. Broderick & Associates, Inc. (JCB) was retained to perform lead testing and analysis of the outlets which service the above referenced school district in accordance with 10 NYCRR Subpart 67-4 (Subpart 67-4).

The outlets servicing each of the school buildings were inventoried and assigned unique identification numbers. The use and location of each outlet was reviewed to determine its applicability for testing under Subpart 67-4.

An initial first-draw sample was collected from each applicable outlet after the minimum 8-hour stagnation period. Samples were logged into a chain of custody document and delivered to an Environmental Laboratory Approval Program (ELAP) accredited laboratory for analysis.

Results from the laboratory analysis were compared with the Action Level as defined by Subpart 67-4 of 5 parts per billion (ppb). Any outlet which exceeded this level requires a remediation action plan be implemented (i.e. removal from service, placarding for non-drinking uses). Outlets which did not exceed the action level do not require further testing or remediation.

Please see the following attachments which detail the sampling and analysis performed and remediation actions taken to date.

Attachment 1: Lead in Water Remediation Plan
Attachment 2: Outlet Inventory and Lead Testing Results
Attachment 3: Laboratory Analytical Reports
Attachment 4: Laboratory Certifications

If you have any questions, or if more information is needed, please contact our office.

Sincerely,

Bryan Ezelius
Project Manager
J C Broderick & Associates, Inc.

Attachment 1:

Lead in Water Remediation Plan



J.C. Broderick & Associates, Inc.
Environmental Consulting & Testing
1775 Expressway Drive North
Hauppauge, New York 11788
631.584.5492 fax 631.584.3395

Lead in Water Remediation Plan

Section 67-4.4 Response of the New York State Department of Health (NYS DOH) Title 10 of the Official Compilation of the Codes, Rules and Regulations of the State of New York requires:

If the lead concentration of water at an outlet exceeds the action level, the school shall:

(a) prohibit use of the outlet until:

*(1) a lead remediation plan is implemented to mitigate the lead level of such outlet; and
(2) test results indicate that the lead levels are at or below the action level;*

As historical sampling results have indicated, the concentrations of lead are more likely attributable to the individual fixtures and/or their immediately adjoining plumbing, and not with the building-wide plumbing. Based upon this information, the following remedial steps are recommended:

Step 1A: Potable Outlets (Outlets intended to be used for drinking/cooking)


Immediately remove the fixture from service. If necessary, provide an adequate supply of potable water for drinking/cooking to this location at no cost to the occupants. If an outlet is seldomly used or is unnecessary, the district may consider permanent removal of the outlet and capping of its supply line.

Step 1B: Non-Potable Outlets (Outlets not intended for drinking/cooking)

See Step 1A OR Placard the outlet for non-drinking use. Signs must be clearly visible and in close proximity to the affected outlet. Example signage is provided at: https://www.health.ny.gov/environmental/water/drinking/lead/docs/donotdrinksigns_lead.pdf.



Do not use for drinking



Step 2: Service & Repair or Outlet Replacement

The school district's plumber should evaluate the outlet to determine if any components require service or repair. Depending on the extent of service/repair necessary, age of the fixture, and or overall costs, the district may consider replacing the outlet entirely. Any newly installed components shall be certified lead free. (i.e. NSF/ANSI 61, NSF/ANSI-273). If servicing involves installing/replacing a point-of-use filtration system, this filter shall be certified for its lead reduction capability (i.e. NSF/ANSI 53). Follow all manufacturer's instructions for all component installations. OUTLET RESTRICTIONS MUST REMAIN IN PLACE UNTIL SATISFACTORY TEST RESULTS ARE RECEIVED. See Step 3.

Step 3: Retesting & Return to Service


Schedule a retest of the outlet. Outlet restrictions must remain in place until lead testing results at or below the action level are received. Once satisfactory results are received, the outlet may be returned to normal service. Note: It is recommended that "Do Not Drink" signage remain in place for all non-potable and non-applicable outlet types.

Attachment 2:

Outlet Inventory and Lead Testing Results



J.C. Broderick & Associates, Inc.
Environmental Consulting & Testing
1775 Expressway Drive North
Hauppauge, New York 11788
631.584.5492 fax 631.584.3395



Laboratory Lead in Water Results

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

Page 1 of 164

JCB #: 23-54650

Smithtown Central School District

Accompsett Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-0001	CLASSROOM 58	NA	Water Fountain-No Chiller	Applicable	12/3/2025	OOS			Testing Required Before Return to Service
SMTH-0002	CLASSROOM 47	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0003	CLASSROOM 56	NA	Water Fountain-No Chiller	Applicable	12/3/2025	OOS			Testing Required Before Return to Service
SMTH-0004	CLASSROOM 49	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0005	CLASSROOM 54	NA	Water Fountain-No Chiller	Applicable	12/3/2025	OOS			Testing Required Before Return to Service
SMTH-0006	CLASSROOM 51	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0007	CLASSROOM 59	NA	Water Fountain-No Chiller	Applicable	12/3/2025	OOS			Testing Required Before Return to Service
SMTH-0008	CLASSROOM 46	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0009	CLASSROOM 57	NA	Water Fountain-No Chiller	Applicable	12/3/2025	OOS			Testing Required Before Return to Service
SMTH-0010	CLASSROOM 48	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0011	STEM ROOM	NA	Water Fountain-No Chiller	Applicable	12/3/2025	OOS			Testing Required Before Return to Service
SMTH-0012	CLASSROOM 50	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0013	BOYS BATHROOM	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0014	GIRLS BATHROOM	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0015	MENS BATHROOM	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0016	WOMENS BATHROOM	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Accompsett Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-0017	CLASSROOM 52	1000	Water Fountain-No Chiller	Applicable	12/3/2025	OOS			Testing Required Before Return to Service
SMTH-0018	CLASSROOM 44	1000	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0019	CLASSROOM 53	1001	Water Fountain-No Chiller	Applicable	12/3/2025	OOS			Testing Required Before Return to Service
SMTH-0020	CLASSROOM 45	1001	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0021	CLASSROOM 50	1002	Water Fountain-No Chiller	Applicable	12/3/2025	OOS			Testing Required Before Return to Service
SMTH-0022	CLASSROOM 42	1002	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0023	CLASSROOM 51	1003	Water Fountain-No Chiller	Applicable	12/3/2025	OOS			Testing Required Before Return to Service
SMTH-0024	CLASSROOM 43	1003	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0025	CLASSROOM 48	1004	Water Fountain-No Chiller	Applicable	12/3/2025	OOS			Testing Required Before Return to Service
SMTH-0026	CLASSROOM 40	1004	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0027	CLASSROOM 49	1005	Water Fountain-No Chiller	Applicable	12/3/2025	OOS			Testing Required Before Return to Service
SMTH-0028	CLASSROOM 41	1005	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0030	CLASSROOM 45	1008	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0031	CLASSROOM 46	1007	Water Fountain-No Chiller	Applicable	12/3/2025	OOS			Testing Required Before Return to Service
SMTH-0032	CLASSROOM 38	1007	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0033	CLASSROOM 43	1010	Water Fountain-No Chiller	Applicable	12/3/2025	OOS			Testing Required Before Return to Service
SMTH-0034	CLASSROOM 44	1009	Water Fountain-No Chiller	Applicable	12/3/2025	OOS			Testing Required Before Return to Service
SMTH-0035	CLASSROOM 42	1011	Water Fountain-No Chiller	Applicable	12/3/2025	OOS			Testing Required Before Return to Service
SMTH-0036	CLASSROOM 41	1012	Water Fountain-No Chiller	Applicable	12/3/2025	OOS			Testing Required Before Return to Service
SMTH-0037	CLASSROOM 40	1013	Water Fountain-No Chiller	Applicable	12/3/2025	OOS			Testing Required Before Return to Service

Accompsett Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTM-0038	CLASSROOM 32	1013	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0040	CLASSROOM 39	1015	Water Fountain-No Chiller	Applicable	12/3/2025	OOS			Testing Required Before Return to Service
SMTM-0041	CLASSROOM 31	1015	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0042	CLASSROOM 38	1019	Water Fountain-No Chiller	Applicable	12/3/2025	OOS			Testing Required Before Return to Service
SMTM-0043	CLASSROOM 30	1019	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0044	BOYS BATHROOM	1016	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0045	BOYS BATHROOM	1016	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0046	BOYS BATHROOM	1016	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0047	GIRLS BATHROOM	1014	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0048	GIRLS BATHROOM	1014	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0049	GIRLS BATHROOM	1014	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0050	KITCHEN	NA	Kitchen Faucet (Cold)	Applicable	12/3/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTM-0051	KITCHEN	NA	Hand Wash Only	Applicable	12/3/2025	3.4			Result Below Action Level Continue O&M
SMTM-0052	KITCHEN	NA	Spray Nozzle	Applicable	12/3/2025	5.8			Further Investigation Determined Outlet Use to be Non-Applicable. Placarded for Non-Drinking Use
SMTM-0053	KITCHEN	NA	Kitchen Faucet (Cold)	Applicable	12/3/2025	2.2			Result Below Action Level Continue O&M
SMTM-0054	KITCHEN	NA	Kitchen Faucet (Cold)	Applicable	12/3/2025	29.2			Removed From Service, Pending Remediation
SMTM-0055	FACULTY ROOM	NA	Kitchen Faucet (Cold)	Applicable	12/3/2025	8.4			Removed From Service, Pending Remediation
SMTM-0056	Bathroom Near Faculty Lounge	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0057	Custodial Storage/Control Room	1028	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0058	Custodial Storage/Control Room Bathroom	1028A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Accompsett Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTM-0059	WOMENS BATHROOM	1024	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0060	WOMENS BATHROOM	1024	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0061	MENS BATHROOM	1023	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0062	MENS BATHROOM	1023	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0063	WOMENS BATHROOM	1032	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0064	WOMENS BATHROOM	1032	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0065	STORAGE ROOM	1034D	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0066	NURSING OFFICE	1037	Nurse's Office Sink	Applicable	12/3/2025	1.5			Result Below Action Level Continue O&M
SMTM-0067	MENS BATHROOM	1035	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0068	LIBRARY	1033A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0069	CLASSROOM 30	1038	Water Fountain-No Chiller	Applicable	12/3/2025	OOS			Testing Required Before Return to Service
SMTM-0070	CLASSROOM 16	1038	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0071	CLASSROOM 28	1039	Water Fountain-No Chiller	Applicable	12/3/2025	OOS			Testing Required Before Return to Service
SMTM-0072	CLASSROOM 8	1039	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0073	Psychologist Office	1040	Kitchen Faucet (Cold)	Applicable	12/3/2025	8.5			Removed From Service, Pending Remediation
SMTM-0074	Classroom 25	1042	Water Fountain-No Chiller	Applicable	12/3/2025	OOS			Testing Required Before Return to Service
SMTM-0075	Classroom 5	1042	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0076	CLASSROOM 26	1043	Water Fountain-No Chiller	Applicable	12/3/2025	OOS			Testing Required Before Return to Service
SMTM-0077	CLASSROOM 6	1043	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0078	CLASSROOM 24	1045	Water Fountain-No Chiller	Applicable	12/3/2025	OOS			Testing Required Before Return to Service

Accompsett Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTM-0079	CLASSROOM 4	1045	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0080	CLASSROOM 23	1044	Water Fountain-No Chiller	Applicable	12/3/2025	OOS			Testing Required Before Return to Service
SMTM-0081	CLASSROOM 3	1044	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0082	CLASSROOM 22	1047	Water Fountain-No Chiller	Applicable	12/3/2025	OOS			Testing Required Before Return to Service
SMTM-0083	CLASSROOM 2	1047	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0084	CLASSROOM 21	1046	Water Fountain-No Chiller	Applicable	12/3/2025	OOS			Testing Required Before Return to Service
SMTM-0085	CLASSROOM 1	1046	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0086	CLASSROOM 19	1052	Water Fountain-No Chiller	Applicable	12/3/2025	OOS			Testing Required Before Return to Service
SMTM-0087	CLASSROOM 11	1052	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0088	CLASSROOM 18	1053	Water Fountain-No Chiller	Applicable	12/3/2025	OOS			Testing Required Before Return to Service
SMTM-0089	CLASSROOM 12	1053	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0090	CLASSROOM 15	NA	Water Fountain-No Chiller	Applicable	12/3/2025	OOS			Testing Required Before Return to Service
SMTM-0091	CLASSROOM 58	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0092	CLASSROOM 11	NA	Water Fountain-No Chiller	Applicable	12/3/2025	OOS			Testing Required Before Return to Service
SMTM-0093	CLASSROOM 60	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0094	CLASSROOM 14	NA	Water Fountain-No Chiller	Applicable	12/3/2025	OOS			Testing Required Before Return to Service
SMTM-0095	CLASSROOM 59	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0096	CLASSROOM 10	NA	Water Fountain-No Chiller	Applicable	12/3/2025	OOS			Testing Required Before Return to Service
SMTM-0097	CLASSROOM 61	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0098	o/s CLASSROOM 14	NA	Bottle Fill Station	Applicable	12/3/2025	<1.00 ND			Result Below Action Level Continue O&M

Accompsett Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTM-0099	o/s CLASSROOM 14	NA	Water Cooler	Applicable	12/3/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTM-0100	WOMENS BATHROOM	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0101	Hallway O/S 62	NA	Bottle Fill Station	Applicable	12/3/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTM-0102	Hallway O/S 62	NA	Water Cooler	Applicable	12/3/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTM-0103	MAIN OFFICE	NA	Kitchen Faucet (Cold)	Applicable	12/3/2025	2.5			Result Below Action Level Continue O&M
SMTM-0104	Classroom 4	NA	Water Fountain-No Chiller	Applicable	12/3/2025	OOS			Testing Required Before Return to Service
SMTM-0105	Classroom 67	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0106	Classroom 3	NA	Water Fountain-No Chiller	Applicable	12/3/2025	OOS			Testing Required Before Return to Service
SMTM-0107	Classroom 62	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0108	Classroom 5	NA	Water Fountain-No Chiller	Applicable	12/3/2025	OOS			Testing Required Before Return to Service
SMTM-0109	Classroom 64	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0110	Classroom 6	NA	Water Fountain-No Chiller	Applicable	12/3/2025	OOS			Testing Required Before Return to Service
SMTM-0111	Classroom 69	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0112	Classroom 7	NA	Water Fountain-No Chiller	Applicable	12/3/2025	OOS			Testing Required Before Return to Service
SMTM-0113	Classroom 66	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0114	Classroom 9	NA	Water Fountain-No Chiller	Applicable	12/3/2025	OOS			Testing Required Before Return to Service
SMTM-0115	Classroom 68	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0116	Classroom 8	NA	Water Fountain-No Chiller	Applicable	12/3/2025	OOS			Testing Required Before Return to Service
SMTM-0117	Classroom 71	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0119	NURSES OFFICE Bathroom	1037B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Accompsett Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-0120	Custodial Storage	1028	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1990	New Addition Custodial Closet By 1053	NA	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1991	Custodial Closet	NA	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1992	Corridor o/s 1032	1026	Water Cooler	Applicable	12/3/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-1993	Corridor o/s 1031	1026	Bottle Fill Station	Applicable	12/3/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-1994	New Addition Custodial Closet by 1022	NA	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1995	Custodial Closet	1017	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1996	CLASSROOM 33	1012	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1997	CLASSROOM 34	1011	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1998	CLASSROOM 35	1010	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1999	CLASSROOM 36	1009	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2000	New Addition Custodial Closet By Classroom 51	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2382	Corridor by Room 58	N/A	Water Cooler	Applicable	12/3/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-2383	Corridor by Room 58	N/A	Bottle Fill Station	Applicable	12/3/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-3191	Girls' Bathroom	1014	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3192	Boys' Bathroom	1016	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3193	Boys' Bathroom	1023	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3194	Girls' Bathroom	1024	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3195	Custodial Storage/Control Room	1028	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3196	Custodial Storage/Control Room	1028	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

Accompsett Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTM-3197	Custodial Storage/Control Room	1028	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3198	Boiler Room	1028B	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3199	Boiler Room	1028B	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3200	WOMENS BATHROOM	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3201	Classroom 62 Bathroom	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3202	Classroom 64 Bathroom	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3203	Classroom 67 Bathroom	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3204	Classroom 66 Bathroom	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3205	Classroom 69 Bathroom	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3206	Classroom 68 Bathroom	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3207	Classroom 71 Bathroom	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3208	Classroom 59 Bathroom	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3209	Classroom 58 Bathroom	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3210	Classroom 60 Bathroom	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3211	Classroom 61 Bathroom	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3212	Kitchen	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3213	Exterior o/s Classroom 30	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3214	Exterior o/s Classroom 47	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3215	Exterior o/s Classroom 45	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3216	Exterior o/s Classroom 1	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

Accompsett Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTM-3217	Exterior o/s Classroom 11	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3218	Exterior o/s Classroom 58	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3219	Exterior o/s Classroom 59	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3220	Exterior o/s Classroom 59	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3221	Exterior o/s Classroom 67	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3222	Exterior o/s Classroom 71	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3223	Exterior o/s Boiler Room	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3276	Corridor (Room 30-Room 45)	1020	Bottle Fill Station	Applicable	12/3/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTM-3277	Corridor (Room 30-Room 45)	1020	Water Cooler	Applicable	12/3/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTM-3281	Room 45	1008	Water Fountain-No Chiller	Applicable	12/3/2025	OOS			Testing Required Before Return to Service
SMTM-3282	Room 37	1008	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Accompsett Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTM-0118	Boiler Room	0005	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0241	Main Office Closet	1013C	Kitchen Faucet (Cold)	Applicable	12/9/2025	1.4			Result Below Action Level Continue O&M
SMTM-0242	Main Office Bathroom	1013D	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0244	Nurse's Office	1013K	Nurse's Office Sink	Applicable	12/9/2025	3.7			Result Below Action Level Continue O&M
SMTM-0245	Room 341 Music Office	1002	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0246	Men's Faculty Restroom	1010	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0247	Men's Faculty Restroom	1010	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0248	Corridor by Men's Faculty Restroom	1014	Water Fountain-No Chiller	Applicable	12/9/2025	1.4			Result Below Action Level Continue O&M
SMTM-0249	Custodial Closet	1009	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0250	Room 347	1004	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0251	Room 359	1005	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0252	Room 361 Art	1006	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0253	Room 361 Art	1006	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0254	Room 361 Art	1006	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0255	Room 365	1007	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0256	Room 365	1007	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0257	Room 365	1007	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0258	Women's Faculty Restroom	1008	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0259	Women's Faculty Restroom	1008	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0260	Corridor by Women's Faculty Restroom	1006	Water Fountain-No Chiller	Applicable	12/9/2025	3.2			Result Below Action Level Continue O&M

Accompsett Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-0261	Room 203	1051	Kitchen Faucet (Cold)	Applicable	12/9/2025	4.4			Result Below Action Level Continue O&M
SMTH-0262	LIBRARY	1053	Water Fountain-No Chiller	Applicable	12/9/2025	OOS			Testing Required Before Return to Service
SMTH-0263	Library Office	1053A	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0264	Corridor o/s Boys' Bathroom	1048	Bottle Fill Station	Applicable	12/9/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-0265	Corridor o/s Boys' Bathroom	1048	Water Cooler	Applicable	12/9/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-0266	Boys' Bathroom	1045	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0267	Boys' Bathroom	1045	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0268	Boys' Bathroom	1045	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0269	Boys' Bathroom	1045	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0270	Boys' Bathroom	1045	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0271	Men's Bathroom	1044	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0272	Custodial Closet	1042	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0274	Women's Bathroom	1038	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0275	Girls' Bathroom	1037	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0276	Girls' Bathroom	1037	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0277	Girls' Bathroom	1037	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0278	Girls' Bathroom	1037	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0279	Girls' Bathroom	1037	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0280	Room 235	1029	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0281	Corridor o/s Girls' Locker Room	1026	Water Fountain-No Chiller	Applicable	12/9/2025	1.6			Result Below Action Level Continue O&M

Accompsett Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-0282	Faculty Room	1024	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0283	Girls' Locker Room PE Office Bathroom	1022A1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0284	Girl's Locker Room Bathroom	1022B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0285	Girl's Locker Room Bathroom	1022B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0286	Girl's Locker Room	1022	Water Fountain-No Chiller	Applicable	12/9/2025	OOS			Testing Required Before Return to Service
SMTH-0287	New Addition Exit Vestibule o/s Girls' Locker Room	NA	Water Cooler	Applicable	12/9/2025	OOS			Testing Required Before Return to Service
SMTH-0288	New Addition Exit Vestibule o/s Girls' Locker Room	NA	Water Cooler	Applicable	12/9/2025	OOS			Testing Required Before Return to Service
SMTH-0289	Women's Bathroom New Addition o/s Girls' Locker	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0290	Girls' Bathroom	1025	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0291	Girls' Bathroom	1025	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0292	Girls' Bathroom	1025	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0293	Girls' Bathroom	1025	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0294	Girls' Bathroom	1025	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0295	Custodial Storage	1015A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0297	Main Lobby/Cafeteria Kitchen	1015B	Kitchen Faucet (Cold)	Applicable	12/9/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-0298	Main Lobby/Cafeteria Kitchen	1015B	Kitchen Faucet (Cold)	Applicable	12/9/2025	2.8			Result Below Action Level Continue O&M
SMTH-0299	Main Lobby/Cafeteria Bathroom	1015B1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0300	Boys' Bathroom	1016	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0301	Boys' Bathroom	1016	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0302	Boys' Bathroom	1016	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Accompsett Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTM-0303	Boys' Bathroom	1016	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0305	Boy's Locker Room PE Office Bathroom	1020A1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0306	Boy's Locker Room Bathroom	1020B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0307	Boy's Locker Room Bathroom	1020B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0308	Boy's Locker Room	1020	Water Fountain-No Chiller	Applicable	12/9/2025	OOS			Testing Required Before Return to Service
SMTM-0309	Boy's Locker Room Ice Room	1020D	Ice Machine	Applicable	12/9/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTM-0310	New Addition Exit Vestibule o/s Boys' Locker Room	NA	Bottle Fill Station	Applicable	12/9/2025	OOS			Testing Required Before Return to Service
SMTM-0311	New Addition Exit Vestibule o/s Boys' Locker Room	NA	Water Cooler	Applicable	12/9/2025	OOS			Testing Required Before Return to Service
SMTM-0312	Men's Bathroom New Addition o/s Boys' Locker	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0313	Receiving Custodial Office/Lockers Bathroom	1017B1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0314	Storage	1018	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0318	Main Lobby/Cafeteria	1015	Water Cooler	Applicable	12/9/2025	OOS			Testing Required Before Return to Service
SMTM-0319	Room 145	0003	Home Economics Faucet (Cold)	Applicable	12/9/2025	4.8			Result Below Action Level Continue O&M
SMTM-0320	Room 145	0003	Home Economics Faucet (Cold)	Applicable	12/9/2025	7.4			Removed From Service, Pending Remediation
SMTM-0321	Room 145	0003	Home Economics Faucet (Cold)	Applicable	12/9/2025	12.1			Removed From Service, Pending Remediation
SMTM-0322	Room 145	0003	Home Economics Faucet (Cold)	Applicable	12/9/2025	14.8			Removed From Service, Pending Remediation
SMTM-0323	Home EC Laundry Room	0003A1	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0324	Room 139	0043	Home Economics Faucet (Cold)	Applicable	12/9/2025	4.6			Result Below Action Level Continue O&M
SMTM-0325	Room 139	0043	Home Economics Faucet (Cold)	Applicable	12/9/2025	3.2			Result Below Action Level Continue O&M
SMTM-0326	Room 139	0043	Home Economics Faucet (Cold)	Applicable	12/9/2025	2.4			Result Below Action Level Continue O&M

Accompsett Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTM-0327	Room 139	0043	Home Economics Faucet (Cold)	Applicable	12/9/2025	14.7			Removed From Service, Pending Remediation
SMTM-0328	Room 102	0010	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0329	Room 102	0010	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0330	Room 102	0010	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0331	Room 102	0010	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0332	Room 102	0010	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0333	Room 102	0010	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0334	Room 102	0010	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0335	Room 102	0010	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0336	Room 102	0010	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0337	Room 102	0010	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0338	Room 102	0010	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0339	Room 102	0010	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0340	Room 102	0010	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0341	Room 104	0011	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0342	Room 104	0011	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0343	Room 104	0011	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0344	Room 104	0011	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0345	Room 104	0011	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0346	Room 104	0011	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

Accompsett Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTM-0347	Room 104	0011	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0348	Room 104	0011	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0349	Room 104	0011	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0350	Room 104	0011	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0351	Room 104	0011	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0352	Room 104	0011	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0353	Room 104	0011	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0354	Room 106	0015	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0355	Room 106	0015	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0356	Room 106	0015	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0357	Room 106	0015	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0358	Room 106	0015	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0359	Room 106	0015	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0360	Room 106	0015	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0361	Room 106	0015	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0362	Room 106	0015	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0363	Room 106	0015	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0364	Room 106	0015	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0365	Room 106	0015	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-0366	Room 106	0015	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

Accompsett Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-0367	Corridor by Boys' Bathroom	0030	Bottle Fill Station	Applicable	12/9/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-0368	Corridor by Boys' Bathroom	0030	Water Cooler	Applicable	12/9/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-0369	Boys' Bathroom	0019	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0370	Boys' Bathroom	0019	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0371	Boys' Bathroom	0019	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0372	Boys' Bathroom	0019	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0373	Boys' Bathroom	0019	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0374	Faculty Men's Room	0020	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0375	Corridor by Girls' Bathroom	0030	Water Fountain-No Chiller	Applicable	12/9/2025	OOS			Testing Required Before Return to Service
SMTH-0376	Faculty Women's Bathroom	0028	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1361	Health Office Bathroom	1013N1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1865	Room 112	0037	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1866	Room 112	0037	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1867	Room 112	0037	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1868	Room 112	0037	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1869	Room 112	0037	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1870	Room 112	0037	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1871	Room 112	0037	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1872	Room 112	0037	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1873	Room 112	0037	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

Accompsett Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-1874	Room 112	0037	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1929	CLASSROOM 132A	0026	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1930	CLASSROOM 132A	0026	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1931	CLASSROOM 132A	0026	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1932	CLASSROOM 132A	0026	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1933	CLASSROOM 132A	0026	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1934	CLASSROOM 132A	0026	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1935	CLASSROOM 132A	0026	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1936	CLASSROOM 132A	0026	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1937	CLASSROOM 132A	0026	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1938	132A Science Storage 118	0026A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1939	132A Science Storage 118	0026A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1940	Room 116	0041	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1941	Room 116	0041	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1942	Room 116	0041	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1943	Room 116	0041	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1944	Room 116	0041	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1945	Room 116	0041	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1946	Room 116	0041	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1947	Room 116	0041	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

Accompsett Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTM-1948	Room 116	0041	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1949	Room 116	0041	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1950	Room 116	0041	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1951	Room 116	0041	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1952	Room 116	0041	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1953	Room 114	0038	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1954	Room 114	0038	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1955	Room 114	0038	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1956	Room 114	0038	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1957	Room 114	0038	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1958	Room 114	0038	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1959	Room 114	0038	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1960	Room 114	0038	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1961	Room 114	0038	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1962	Room 114	0038	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1963	Room 114	0038	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1964	Room 114	0038	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1965	Room 114	0038	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1966	Room 112	0037	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1967	Room 112	0037	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

Accompsett Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-1968	Room 112	0037	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1980	Custodial Closet	0027	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1981	Girls' Bathroom	0029	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1982	Girls' Bathroom	0029	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1983	Girls' Bathroom	0029	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1984	Girls' Bathroom	0029	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1985	Girls' Bathroom	0029	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1986	Room 116 Greenhouse	0041A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1987	Room 116 Greenhouse	0041A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1988	Room 116 Greenhouse	0041A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1989	Room 116 Greenhouse	0041A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2981	Women's Faculty Restroom	1008	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2982	Men's Faculty Restroom	1010	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2983	Main Lobby/Cafeteria	1015	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2984	Main Lobby/Cafeteria Kitchen	1015B	Spray Nozzle	Applicable	12/9/2025	6.1			Further Investigation Determined Outlet Use to be Non-Applicable. Placarded for Non-Drinking Use
SMTH-2985	Boys' Bathroom	1016	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2986	Receiving Custodial Office/Lockers Bathroom	1017B1	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2987	Receiving Custodial Office/Lockers Bathroom	1017B1	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2988	Receiving Custodial Office/Lockers Bathroom	1017B1	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2989	Boys' Locker Room	1020	Shower Head	Non-Applicable					Placarded for Non-Drinking Use

Accompsett Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTM-2990	Boys' Locker Room	1020	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2991	Boys' Locker Room	1020	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2992	Boys' Locker Room	1020	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2993	Boys' Locker Room	1020	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2994	Boys' Locker Room	1020	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2995	Boys' Locker Room	1020	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2996	Boys' Locker Room	1020	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2997	Boys' Locker Room	1020	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2998	Boys' Locker Room	1020	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2999	Boys' Locker Room	1020	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3000	Boys' Locker Room	1020	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3001	Boys' Locker Room	1020	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3002	Boys' Locker Room	1020	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3003	Boys' Locker Room	1020	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3004	Boys' Locker Room	1020	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3005	Boys' Locker Room	1020	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3006	Boys' Locker Room	1020	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3007	Boys' Locker Room	1020	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3008	Boys' Locker Room	1020	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3009	Boys' Locker Room	1020	Shower Head	Non-Applicable					Placarded for Non-Drinking Use

Accompsett Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-3010	Boys' Locker Room	1020	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3011	Boys' Locker Room	1020	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3012	Boys' Locker Room	1020	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3013	Boys' Locker Room PE Office Bathroom	1020A1	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3014	Boys' Locker Room Bathroom	1020B	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3015	Boys' Team Locker Room Shower	NA	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3016	Men's Bathroom New Addition o/s Boys' Locker	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3017	Girls' Locker Room	1022	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3018	Girls' Locker Room	1022	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3019	Girls' Locker Room	1022	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3020	Girls' Locker Room	1022	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3021	Girls' Locker Room	1022	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3022	Girls' Locker Room	1022	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3023	Girls' Locker Room	1022	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3024	Girls' Locker Room	1022	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3025	Girls' Locker Room	1022	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3026	Girls' Locker Room	1022	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3027	Girls' Locker Room	1022	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3028	Girls' Locker Room	1022	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3029	Girls' Locker Room	1022	Shower Head	Non-Applicable					Placarded for Non-Drinking Use

Accompsett Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-3030	Girls' Locker Room	1022	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3031	Girls' Locker Room	1022	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3032	Girls' Locker Room	1022	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3033	Girls' Locker Room	1022	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3034	Girls' Locker Room	1022	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3035	Girls' Locker Room	1022	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3036	Girls' Locker Room	1022	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3037	Girls' Locker Room	1022	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3038	Girls' Locker Room	1022	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3039	Girls' Locker Room	1022	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3040	Girls' Locker Room PE Office Bathroom	1022A1	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3041	Girls' Locker Room Bathroom	1022B	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3042	Girls' Team Locker Room Shower	NA	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3043	Girls' Team Locker Room Shower	NA	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3044	Women's Bathroom New Addition o/s Girls' Locker	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3045	Girls' Bathroom	1025	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3046	Home EC Laundry Room	0003A1	Washing Machine	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3047	Home EC Laundry Room	0003A1	Washing Machine	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3048	Lower Courtyard	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3049	Upper Courtyard	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

Accompsett Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTM-3050	Girls' Bathroom	1037	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3051	Room 208 English Book Room	1041	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3052	Boys' Bathroom	1045	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3053	Boys' Bathroom	0019	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3054	Room 132A	0026	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3057	Room 132A Science Storage (118)	0026A	Washing Machine	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3058	Girls' Bathroom	0029	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3061	Exterior o/s Girls' Team Locker Room	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3062	Exterior o/s Room 237	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3063	Exterior o/s Room 225	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3064	Exterior o/s Room 217	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3065	Exterior o/s Room 207	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3066	Exterior o/s Room 347A	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3067	Exterior o/s Main Office	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3068	Exterior o/s Receiving	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3231	Main Lobby/Cafeteria	1015	Bottle Fill Station	Applicable	12/9/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTM-3232	Main Lobby/Cafeteria	1015	Water Cooler	Applicable	12/9/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTM-3304	Main Lobby/Cafeteria Kitchen	1015B	Hand Wash Only	Applicable	12/9/2025	1.6			Result Below Action Level Continue O&M
SMTM-3305	Corridor (Boy's Bathroom-Gym)	1027	Water Fountain-No Chiller	Applicable	12/9/2025	2.3			Result Below Action Level Continue O&M

Saint James Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-0121	Hallway O/S New Gym	NA	Bottle Fill Station	Applicable	12/4/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-0122	Hallway O/S New Gym	NA	Water Cooler	Applicable	12/4/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-0123	Custodial Closet O/S New Gym	NA	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0124	Corridor by Gym	NA	Water Cooler	Applicable	12/4/2025	OOS			Testing Required Before Return to Service
SMTH-0125	Corridor by Gym	NA	Water Cooler	Applicable	12/4/2025	OOS			Testing Required Before Return to Service
SMTH-0126	BATHROOM	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0127	BATHROOM	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0128	CLASSROOM 50	NA	Water Fountain-No Chiller	Applicable	12/4/2025	1.3			Result Below Action Level Continue O&M
SMTH-0129	CLASSROOM 50	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0130	CLASSROOM 51	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0131	CLASSROOM 51	NA	Water Fountain-No Chiller	Applicable	12/4/2025	1.3			Result Below Action Level Continue O&M
SMTH-0132	CLASSROOM 48	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0133	CLASSROOM 48	NA	Water Fountain-No Chiller	Applicable	12/4/2025	OOS			Testing Required Before Return to Service
SMTH-0134	CLASSROOM 49	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0135	CLASSROOM 49	NA	Water Fountain-No Chiller	Applicable	12/4/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-0136	CLASSROOM 46	NA	Water Fountain-No Chiller	Applicable	12/4/2025	2.2			Result Below Action Level Continue O&M
SMTH-0137	CLASSROOM 46	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0138	CLASSROOM 47	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0139	CLASSROOM 47	NA	Water Fountain-No Chiller	Applicable	12/4/2025	1.8			Result Below Action Level Continue O&M
SMTH-0140	CLASSROOM 44	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Saint James Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-0141	CLASSROOM 44	NA	Water Fountain-No Chiller	Applicable	12/4/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-0142	CLASSROOM 45	NA	Water Fountain-No Chiller	Applicable	12/4/2025	1.4			Result Below Action Level Continue O&M
SMTH-0143	CLASSROOM 45	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0144	CLASSROOM 43	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0145	CLASSROOM 43	NA	Water Fountain-No Chiller	Applicable	12/4/2025	1.3			Result Below Action Level Continue O&M
SMTH-0146	CLASSROOM 42	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0147	CLASSROOM 42	NA	Water Fountain-No Chiller	Applicable	12/4/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-0148	CLASSROOM 41	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0149	CLASSROOM 41	NA	Water Fountain-No Chiller	Applicable	12/4/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-0150	CLASSROOM 40	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0151	CLASSROOM 40	NA	Water Fountain-No Chiller	Applicable	12/4/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-0152	Custodial Closet O/S Music Room	NA	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0154	New Const. Music Room Bathroom	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0155	BATHROOM	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0156	BATHROOM	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0157	Room 12	1058	Water Fountain-No Chiller	Applicable	12/4/2025	OOS			Testing Required Before Return to Service
SMTH-0158	Room 12	1058	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0159	Room 11	1061	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0160	Room 11	1061	Water Fountain-No Chiller	Applicable	12/4/2025	7.9			Removed From Service, Pending Remediation
SMTH-0161	Hall Closet	1060	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use

Saint James Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-0162	Room 10	1056	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0163	Room 10	1056	Water Fountain-No Chiller	Applicable	12/4/2025	OOS			Testing Required Before Return to Service
SMTH-0164	Room 7	1050	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0165	Room 7	1050	Water Fountain-No Chiller	Applicable	12/4/2025	1.9			Result Below Action Level Continue O&M
SMTH-0166	Room 8	1052	Water Fountain-No Chiller	Applicable	12/4/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-0167	Room 8	1052	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0168	Room 9	1055	Water Fountain-No Chiller	Applicable	12/4/2025	OOS			Testing Required Before Return to Service
SMTH-0169	Room 9	1055	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0170	BATHROOM	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0171	CLASSROOM 52	NA	Water Fountain-No Chiller	Applicable	12/4/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-0172	CLASSROOM 52	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0173	BATHROOM	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0174	CLASSROOM 53	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0176	CLASSROOM 54	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0177	CLASSROOM 54	NA	Water Fountain-No Chiller	Applicable	12/4/2025	1.3			Result Below Action Level Continue O&M
SMTH-0178	Custodial Closet O/S Room 54	NA	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0179	CLASSROOM 55	NA	Water Fountain-No Chiller	Applicable	12/4/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-0180	CLASSROOM 55	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0181	Room 6	1039	Water Fountain-No Chiller	Applicable	12/4/2025	1.7			Result Below Action Level Continue O&M
SMTH-0182	Room 6	1039	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Saint James Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-0183	Room 5	1036	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0184	Room 5	1036	Water Fountain-No Chiller	Applicable	12/4/2025	1.5			Result Below Action Level Continue O&M
SMTH-0185	Custodial Closet O/S Room 4	1035	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0186	Room 4	1034	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0187	Room 4	1034	Water Fountain-No Chiller	Applicable	12/4/2025	3.6			Result Below Action Level Continue O&M
SMTH-0188	Room 3	1031	Water Fountain-No Chiller	Applicable	12/4/2025	4.1			Result Below Action Level Continue O&M
SMTH-0189	Room 3	1031	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0190	Room 2	1028	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0191	Room 2	1028	Water Fountain-No Chiller	Applicable	12/4/2025	3.3			Result Below Action Level Continue O&M
SMTH-0192	Third Grade Art (1)	1026	Water Fountain-No Chiller	Applicable	12/4/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-0193	Third Grade Art (1)	1026	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0194	Girls' Bathroom O/S Speech Language	1023	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0195	Girls' Bathroom O/S Speech Language	1023	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0196	Boys' Bathroom O/S Speech Language	1022	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0197	Boys' Bathroom O/S Speech Language	1022	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0198	Corridor by Boys Bathroom	1024	Bottle Fill Station	Applicable	12/4/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-0199	Corridor by Boys Bathroom	1024	Water Cooler	Applicable	12/4/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-0200	Custodial Closet	1021	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0201	Kitchen	1047	Kitchen Faucet (Cold)	Applicable	12/4/2025	3.3			Result Below Action Level Continue O&M
SMTH-0202	Kitchen	1047	Kitchen Faucet (Cold)	Applicable	12/4/2025	<1.00 ND			Result Below Action Level Continue O&M

Saint James Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-0203	Kitchen	1047	Kitchen Faucet (Cold)	Applicable	12/4/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-0204	Kitchen	1047	Kitchen Faucet (Cold)	Applicable	12/4/2025	1.6			Result Below Action Level Continue O&M
SMTH-0205	Kitchen	1047	Spray Nozzle	Applicable	12/4/2025	10.1	12/31/2025	< 1.0	Outlet Remediated and Returned to Service, Continue O&M
SMTH-0206	Kitchen	1047	Kitchen Faucet (Cold)	Applicable	12/4/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-0207	Kitchen	1047	Kitchen Faucet (Cold)	Applicable	12/4/2025	16.2	12/31/2025	< 1.0	Outlet Remediated and Returned to Service, Continue O&M
SMTH-0208	Kitchen	1047	Spray Nozzle	Applicable	12/4/2025	<1.00 ND	12/31/2025	< 1.0	Result Below Action Level Continue O&M
SMTH-0209	Kitchen Bathroom	1047C2	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0210	Room 13 Art	1049	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0211	Gym Exit Vestibule Work Room	1013E2	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0212	Room 20 Music	1001	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0213	Room 20 Music	1001	Water Fountain-No Chiller	Applicable	12/4/2025	6.0			Removed From Service, Pending Remediation
SMTH-0214	Room 20 Music	1001	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0215	Room 20 Music	1001	Water Fountain-No Chiller	Applicable	12/4/2025	2.2			Result Below Action Level Continue O&M
SMTH-0216	Room 21 Music	1000A	Water Fountain-No Chiller	Applicable	12/4/2025	7.2			Removed From Service, Pending Remediation
SMTH-0217	Room 21 Music	1000A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0218	Room 21 Music	1000A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0219	Room 21 Music	1000A	Water Fountain-No Chiller	Applicable	12/4/2025	OOS			Testing Required Before Return to Service
SMTH-0220	Custodial Closet	1006	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0221	Men's Bathroom	1007	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0222	Men's Bathroom	1007	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Saint James Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-0223	Room 107 Clerical Services	1008	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0224	Corridor Library by Ladies Room	1019	Water Fountain-No Chiller	Applicable	12/4/2025	OOS			Testing Required Before Return to Service
SMTH-0225	Principal's Office Bathroom	1010A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0226	Ladies' Bathroom	1014	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0227	Ladies' Bathroom	1014	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0229	Health Office	1018A	Nurse's Office Sink	Applicable	12/4/2025	4.1			Result Below Action Level Continue O&M
SMTH-0230	Health Office Bathroom	1018A3	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0231	Faculty Room	1015	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0232	Boys' Bathroom	2002	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0233	Boys' Bathroom	2002	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0234	Girls' Bathroom	2009	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0235	Girls' Bathroom	2009	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0236	Corridor by Girls' Bathroom	2017	Water Fountain-No Chiller	Applicable	12/4/2025	4.8			Result Below Action Level Continue O&M
SMTH-0237	Corridor by Custodial Closet	2017	Bottle Fill Station	Applicable	12/4/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-0238	Corridor by Custodial Closet	2017	Bottle Fill Station	Applicable	12/4/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-0239	Custodial Closet	2004	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0240	Cafeteria	1045	Water Fountain-No Chiller	Applicable	12/4/2025	OOS			Testing Required Before Return to Service
SMTH-3135	Corridor Library To Custodial Closet	1019	Water Fountain-No Chiller	Applicable	12/4/2025	OOS			Testing Required Before Return to Service
SMTH-3139	Courtyard	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3140	Courtyard	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

Saint James Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-3141	Boys' Bathroom O/S Speech Language	1022	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3142	Speech Language Work Room Storage	1043A	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3143	BATHROOM	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3144	CLASSROOM 53	NA	Water Fountain-No Chiller	Applicable	12/4/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-3145	Classroom 53 Bathroom	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3146	Classroom 55 Bathroom	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3147	Custodial Closet O/S Room 54	NA	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3148	Classroom 54 Bathroom	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3149	Classroom 52 Bathroom	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3150	BATHROOM	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3151	BATHROOM	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3152	BATHROOM	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3153	Cafeteria Storage Room Old Shower	1045A1	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3154	Cafeteria Storage Room Old Shower	1045A1	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3155	Cafeteria Storage Room Old Shower	1045A1	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3156	Cafeteria Storage Room Old Shower	1045A1	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3157	Cafeteria Storage Room Old Shower	1045A1	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3158	Cafeteria Storage Room Old Shower	1045A1	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3159	CLASSROOM 47	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3160	Corridor by Girls' Bathroom	2017	Water Fountain-No Chiller	Applicable	12/4/2025	OOS			Testing Required Before Return to Service

Saint James Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTM-3161	School Psychologist Office Room 29 Bathroom	2016A1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3162	Exterior o/s Custodial Office	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3163	Exterior o/s New Gym Coach's Office	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3164	Exterior o/s New Exterior Storage	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3165	Exterior o/s Room 13 Art	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3166	Exterior o/s Classroom 55	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3167	Exterior o/s Classroom 54	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3168	Exterior o/s Classroom 52	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3169	Exterior o/s Room 4	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3170	Exterior o/s Room 16	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3171	Exterior o/s Office Room 104	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3361	Corridor 11B To New Addition	1063	Bottle Fill Station	Applicable	12/4/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTM-3362	Corridor 11B To New Addition	1063	Water Cooler	Applicable	12/4/2025	<1.00 ND			Result Below Action Level Continue O&M

Smithtown Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-0377	Receiving/Mechanical Room Fan Room	1017A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0378	Receiving/Mechanical Room	1017	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0379	Cafeteria Kitchen	1015B	Spray Nozzle	Applicable	12/6/2025	10.7			Further Investigation Determined Outlet Use to be Non-Applicable. Placarded for Non-Drinking Use
SMTH-0380	Entrance Vestibule	1016	Water Fountain-No Chiller	Applicable	12/6/2025	OOS			Testing Required Before Return to Service
SMTH-0381	Cafeteria Kitchen	1015B	Hand Wash Only	Applicable	12/6/2025	1.2			Result Below Action Level Continue O&M
SMTH-0382	Cafeteria Kitchen Bathroom	1015B2	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0383	Cafeteria Kitchen	1015B	Kitchen Faucet (Cold)	Applicable	12/6/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-0384	Cafeteria Kitchen	1015B	Kitchen Faucet (Cold)	Applicable	12/6/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-0385	Nurses Office	1029C	Nurse's Office Sink	Applicable	12/6/2025	21.4			Removed From Service, Pending Remediation
SMTH-0386	Nurses Office Bathroom	1029C1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0401	Room 18	1042	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0403	Room 17	1040	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0405	Room 16B	1039	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0407	Room 15	1035	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0409	Room 14	1032	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0411	Room 12	1031	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0412	Nurses Office Hallway Bathroom	1029B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0413	Boys' Bathroom	1020	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0414	Boys' Bathroom	1020	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0415	Boys' Bathroom	1020	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Smithtown Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-0416	Boys' Bathroom	1020	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0417	Girls' Bathroom	1022	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0418	Girls' Bathroom	1022	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0419	Girls' Bathroom	1022	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0420	Girls' Bathroom	1022	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0421	Faculty Room Bathroom	1023A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0422	Faculty Room Bathroom 2	1023B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0424	Corridor by Orchestra Room	1025	Water Fountain-No Chiller	Applicable	12/6/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-0425	Bathroom by CLASSROOM 55	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0426	Corridor by CLASSROOM 55	NA	Water Fountain-No Chiller	Applicable	12/6/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-0427	Bathroom by CLASSROOM 55	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0428	CLASSROOM 55	NA	Water Fountain-No Chiller	Applicable	12/6/2025	OOS			Testing Required Before Return to Service
SMTH-0429	CLASSROOM 55	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0430	CLASSROOM 54	NA	Water Fountain-No Chiller	Applicable	12/6/2025	OOS			Testing Required Before Return to Service
SMTH-0431	CLASSROOM 54	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0432	CLASSROOM 53	NA	Water Fountain-No Chiller	Applicable	12/6/2025	OOS			Testing Required Before Return to Service
SMTH-0433	CLASSROOM 53	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0434	CLASSROOM 52	NA	Water Fountain-No Chiller	Applicable	12/6/2025	OOS			Testing Required Before Return to Service
SMTH-0435	CLASSROOM 52	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0436	CLASSROOM 51	NA	Water Fountain-No Chiller	Applicable	12/6/2025	OOS			Testing Required Before Return to Service

Smithtown Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-0437	CLASSROOM 51	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0438	CLASSROOM 41	NA	Water Fountain-No Chiller	Applicable	12/6/2025	OOS			Testing Required Before Return to Service
SMTH-0439	CLASSROOM 41	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0440	CLASSROOM 41	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0441	Bathroom by CLASSROOM 41	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0442	Bathroom by CLASSROOM 42	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0443	CLASSROOM 42	NA	Water Fountain-No Chiller	Applicable	12/6/2025	OOS			Testing Required Before Return to Service
SMTH-0444	CLASSROOM 42	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0445	Faculty Bathroom	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0446	Faculty Bathroom	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0447	CLASSROOM 43 Bathroom	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0448	CLASSROOM 43	NA	Water Fountain-No Chiller	Applicable	12/6/2025	OOS			Testing Required Before Return to Service
SMTH-0449	CLASSROOM 43	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0450	CLASSROOM 45	NA	Water Fountain-No Chiller	Applicable	12/6/2025	OOS			Testing Required Before Return to Service
SMTH-0451	CLASSROOM 45	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0452	CLASSROOM 56	NA	Water Fountain-No Chiller	Applicable	12/6/2025	OOS			Testing Required Before Return to Service
SMTH-0453	CLASSROOM 56	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0454	CLASSROOM 47	NA	Water Fountain-No Chiller	Applicable	12/6/2025	OOS			Testing Required Before Return to Service
SMTH-0455	CLASSROOM 47	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0456	CLASSROOM 47 Bathroom	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Smithtown Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-0457	CLASSROOM 48 Bathroom	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0458	CLASSROOM 48	NA	Water Fountain-No Chiller	Applicable	12/6/2025	OOS			Testing Required Before Return to Service
SMTH-0459	CLASSROOM 48	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0460	CLASSROOM 49	NA	Water Fountain-No Chiller	Applicable	12/6/2025	OOS			Testing Required Before Return to Service
SMTH-0461	CLASSROOM 49	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0463	Room 25	1009	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0465	Room 26	1008	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0467	Room 27	1007	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0469	Room 28	1006	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0471	Room 29	1005	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0473	Room 30	1004	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0475	Room 31	1001	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0477	Room 31	1001	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0478	Room 31 Bathroom	1001A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0479	Room 32 Bathroom	1002B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0481	Room 32	1002	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0483	Room 32	1002	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0484	CLASSROOM 34	NA	Water Fountain-No Chiller	Applicable	12/6/2025	OOS			Testing Required Before Return to Service
SMTH-0485	CLASSROOM 34	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0486	CLASSROOM 35	NA	Water Fountain-No Chiller	Applicable	12/6/2025	OOS			Testing Required Before Return to Service

Smithtown Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-0487	CLASSROOM 35	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0488	CLASSROOM 36	NA	Water Fountain-No Chiller	Applicable	12/6/2025	OOS			Testing Required Before Return to Service
SMTH-0489	CLASSROOM 36	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0492	Room 31 Bathroom	1001A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0493	CLASSROOM 34 Bathroom	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0494	CLASSROOM 35 Bathroom	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1851	Custodial Closet by Room 25	NA	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1852	Corridor by Room 25	1010	Bottle Fill Station	Applicable	12/6/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-1853	Corridor by Room 25	1010	Water Fountain-No Chiller	Applicable	12/6/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-1854	Corridor by CLASSROOM 55	NA	Bottle Fill Station	Applicable	12/6/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-1855	Corridor by Orchestra Room	1025	Bottle Fill Station	Applicable	12/6/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-2148	Exterior o/s Room 32 (#1002)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2149	Exterior o/s Room 36	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2150	Exterior o/s Entrance Vestibule (#1016)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2202	Exterior o/s Table Storage (#1013)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2255	Exterior o/s Table Storage (#1013)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2256	Exterior o/s Receiving/Mechanical Room	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2276	Exterior o/s Boiler Room (#1034A)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2277	Exterior o/s Room 19 (#1044)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2278	Exterior o/s Orchestra Room Storage Closet (#1025A2)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

Smithtown Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-2279	Exterior o/s Classroom 53	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2280	Exterior o/s Classroom 45	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2344	CLASSROOM 36 Bathroom	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2370	Receiving/Mechanical Room	1017	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2371	Receiving/Mechanical Room	1017	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2373	Room 26	1008	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2374	Exterior o/s Room 25 (#1009)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2375	Exterior o/s Room 27 (#1007)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2376	Exterior o/s Room 31 (#1001)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2381	Exterior o/s Rooms 31 & 32 (#1001, #1002)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2711	Exterior o/s New Gym	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2961	Custodial Closet 26	1033	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2962	Custodial Closet o/s Gym (1026)	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2963	Custodial Closet o/s Classroom 45	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3226	Room 28	1006	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3227	Room 29	1005	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3264	Room 30	1004	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3265	Room 29	1005	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3266	Room 28	1006	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3267	Room 27	1007	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Smithtown Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-3268	Room 26	1008	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3269	Room 25	1009	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3270	Room 12	1031	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3271	Room 14	1032	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3272	Room 15	1035	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3273	Room 16B	1039	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3274	Room 17	1040	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3275	Room 18	1042	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3363	Room 24	1036	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3364	Room 23	1038	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3365	Room 22	1041	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3366	Room 21	1043	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3367	Faculty Room Small Corridor Kitchenette	1023C	Kitchen Faucet (Cold)	Applicable	12/6/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-3368	Room 27	1007	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3369	Room 31	1001	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3370	Room 31	1001	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3371	Room 32	1002	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3372	Room 32	1002	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Mills Pond Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-0490	Classroom 27 (Formerly Room 30)	1035	Water Fountain-No Chiller	Applicable	12/10/2025	OOS			Testing Required Before Return to Service
SMTH-0491	Classroom 30	1035	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1107	Classroom 45 (Formerly Room 48)	NA	Water Fountain-No Chiller	Applicable	12/10/2025	OOS			Testing Required Before Return to Service
SMTH-1108	Classroom 48	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1109	Classroom 44 (Formerly Room 47)	NA	Water Fountain-No Chiller	Applicable	12/10/2025	OOS			Testing Required Before Return to Service
SMTH-1110	Classroom 47	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1111	Classroom 43 (Formerly Room 46)	NA	Water Fountain-No Chiller	Applicable	12/10/2025	OOS			Testing Required Before Return to Service
SMTH-1112	Classroom 46	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1113	Classroom 45	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1114	Classroom 42 (Formerly Room 45)	NA	Water Fountain-No Chiller	Applicable	12/10/2025	OOS			Testing Required Before Return to Service
SMTH-1115	Custodial Closet	NA	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1116	Classroom 41 (Formerly Room 44)	NA	Water Fountain-No Chiller	Applicable	12/10/2025	OOS			Testing Required Before Return to Service
SMTH-1117	Classroom 44	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1118	Corridor by Classroom 44	NA	Bottle Fill Station	Applicable	12/10/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-1119	Corridor by Classroom 44	NA	Water Cooler	Applicable	12/10/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-1120	Corridor by Classroom 44	NA	Water Cooler	Applicable	12/10/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-1121	Faculty Bathroom (Left)	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1122	Faculty Bathroom (Right)	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1123	Girls' Bathroom	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1124	Girls' Bathroom	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Mills Pond Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-1125	Girls' Bathroom	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1126	Girls' Bathroom	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1127	Boys' Bathroom	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1128	Boys' Bathroom	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1129	Boys' Bathroom	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1130	Boys' Bathroom	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1131	Classroom 39 (Formerly Room 42)	NA	Water Fountain-No Chiller	Applicable	12/10/2025	OOS			Testing Required Before Return to Service
SMTH-1132	Classroom 42	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1133	Classroom 38 (Formerly Room 41)	NA	Water Fountain-No Chiller	Applicable	12/10/2025	OOS			Testing Required Before Return to Service
SMTH-1134	Classroom 41	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1135	Classroom 31 (Formerly Room 34)	1043	Water Fountain-No Chiller	Applicable	12/10/2025	OOS			Testing Required Before Return to Service
SMTH-1136	Classroom 34	1043	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1137	Classroom 30 (Formerly Room 33)	1042	Water Fountain-No Chiller	Applicable	12/10/2025	OOS			Testing Required Before Return to Service
SMTH-1138	Classroom 33	1042	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1139	Classroom 33 (Formerly Room 36)	1045	Water Fountain-No Chiller	Applicable	12/10/2025	OOS			Testing Required Before Return to Service
SMTH-1140	Classroom 36	1045	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1141	Classroom 32 (Formerly Room 35)	1044	Water Fountain-No Chiller	Applicable	12/10/2025	OOS			Testing Required Before Return to Service
SMTH-1142	Classroom 35	1044	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1143	Classroom 35 (Formerly Room 38)	1047	Water Fountain-No Chiller	Applicable	12/10/2025	OOS			Testing Required Before Return to Service
SMTH-1144	Classroom 38	1047	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Mills Pond Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-1145	Classroom 34 (Formerly Room 37)	1046	Water Fountain-No Chiller	Applicable	12/10/2025	OOS			Testing Required Before Return to Service
SMTH-1146	Classroom 37	1046	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1147	Room 26 Girls' Bathroom	1040	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1148	Room 26 Girls' Bathroom	1040	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1149	Room 26 Girls' Bathroom	1040	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1150	Classroom 29 (Formerly Room 32)	1041	Water Fountain-No Chiller	Applicable	12/10/2025	OOS			Testing Required Before Return to Service
SMTH-1151	Classroom 32	1041	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1152	Corridor by Room 32	1041	Water Cooler	Applicable	12/10/2025	OOS			Testing Required Before Return to Service
SMTH-1153	Corridor by Room 32	1041	Water Cooler	Applicable	12/10/2025	OOS			Testing Required Before Return to Service
SMTH-1154	Classroom 28 (Formerly Room 31)	1039	Water Fountain-No Chiller	Applicable	12/10/2025	OOS			Testing Required Before Return to Service
SMTH-1155	Classroom 31	1039	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1156	Room 27 Boys' Bathroom	1038	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1157	Room 27 Boys' Bathroom	1038	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1158	Room 27 Boys' Bathroom	1038	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1159	Custodial Closet	1037	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1160	Corridor by Gym	NA	Bottle Fill Station	Applicable	12/10/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-1161	Corridor by Gym	NA	Water Cooler	Applicable	12/10/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-1162	Corridor by Gym	NA	Water Cooler	Applicable	12/10/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-1163	Bathroom by Gym (Left)	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1164	Bathroom by Gym (Right)	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Mills Pond Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-1165	Kitchen	NA	Hand Wash Only	Applicable	12/10/2025	13.0			Placarded for Non-Drinking Use Until Remediated
SMTH-1166	Kitchen	NA	Kitchen Faucet (Cold)	Applicable	12/31/2025	1.5			Outlet Remediated and Returned to Service, Continue O&M
SMTH-1167	Kitchen	NA	Kitchen Faucet (Cold)	Applicable	12/10/2025	3.6			Result Below Action Level Continue O&M
SMTH-1168	Kitchen	NA	Spray Nozzle	Applicable	12/31/2025	16.5			Further Investigation Determined Outlet Use to be Non-Applicable. Placarded for Non-Drinking Use
SMTH-1169	Kitchen	NA	Kitchen Faucet (Cold)	Applicable	12/10/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-1170	Faculty Room	NA	Kitchen Faucet (Cold)	Applicable	12/10/2025	421			Removed From Service, Pending Remediation
SMTH-1171	Custodial Closet (Near Custodial Office)	1029	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1172	Maintenance Room	1023A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1173	BOILER ROOM	1023	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1174	Women's Bathroom	1022	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1175	Women's Bathroom	1022	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1176	Main Lobby	1025	Bottle Fill Station	Applicable	12/10/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-1177	Main Lobby	1025	Water Cooler	Applicable	12/10/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-1178	Library Room 18	1020	Kitchen Faucet (Cold)	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1179	Main Office File Room	1019B	Kitchen Faucet (Cold)	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1180	Men's Room	1018	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1181	Custodial Closet	1017	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1182	Nurse's Office	1016	Nurse's Office Sink	Applicable	12/10/2025	1.0			Result Below Action Level Continue O&M
SMTH-1183	Nurse's Office Bathroom	1016B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1184	Classroom 17 (Formerly Room 16)	1015	Water Fountain-No Chiller	Applicable	12/10/2025	OOS			Testing Required Before Return to Service

Mills Pond Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-1185	Classroom 16	1015	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1186	Classroom 4 (Formerly Room 11)	1011	Water Fountain-No Chiller	Applicable	12/10/2025	OOS			Testing Required Before Return to Service
SMTH-1187	Classroom 11	1011	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1188	Classroom 3 (Formerly Room 12)	1012	Water Fountain-No Chiller	Applicable	12/10/2025	OOS			Testing Required Before Return to Service
SMTH-1189	Classroom 12	1012	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1190	Classroom 11A	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1191	Classroom 2 (Formerly Room 11A)	NA	Water Fountain-No Chiller	Applicable	12/10/2025	OOS			Testing Required Before Return to Service
SMTH-1192	Classroom 12A	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1193	Classroom 1 (Formerly Room 12A)	NA	Water Fountain-No Chiller	Applicable	12/10/2025	OOS			Testing Required Before Return to Service
SMTH-1194	Corridor from Room 1 - 6	NA	Water Cooler	Applicable	12/10/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-1195	Corridor from Room 1 - 6	NA	Water Cooler	Applicable	12/10/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-1196	Classroom 15 (Formerly Room 8)	1008	Water Fountain-No Chiller	Applicable	12/10/2025	OOS			Testing Required Before Return to Service
SMTH-1197	Classroom 8	1008	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1198	Classroom 7	1007	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1199	Classroom 12 (Formerly Room 5)	1005	Water Fountain-No Chiller	Applicable	12/10/2025	OOS			Testing Required Before Return to Service
SMTH-1200	Classroom 5	1005	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1201	Classroom 6	1004	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1202	Classroom 13 (Formerly Room 6)	1004	Water Fountain-No Chiller	Applicable	12/10/2025	OOS			Testing Required Before Return to Service
SMTH-1203	Classroom 3	1003	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1204	Classroom 10 (Formerly Room 3)	1003	Water Fountain-No Chiller	Applicable	12/10/2025	OOS			Testing Required Before Return to Service

Mills Pond Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-1205	Classroom 11 (Formerly Room 4)	1002	Water Fountain-No Chiller	Applicable	12/10/2025	OOS			Testing Required Before Return to Service
SMTH-1206	Classroom 4	1002	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1207	Classroom 8 (Formerly Room 1)	1001	Water Fountain-No Chiller	Applicable	12/10/2025	OOS			Testing Required Before Return to Service
SMTH-1208	Classroom 1	1001	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1209	Classroom 9 (Formerly Room 2)	1000	Water Fountain-No Chiller	Applicable	12/10/2025	OOS			Testing Required Before Return to Service
SMTH-1210	Classroom 2	1000	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1211	Classroom 6 (Formerly Room 1A)	NA	Water Fountain-No Chiller	Applicable	12/10/2025	OOS			Testing Required Before Return to Service
SMTH-1212	Classroom 1A	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1213	Classroom 7 (Formerly Room 2A)	NA	Water Fountain-No Chiller	Applicable	12/10/2025	OOS			Testing Required Before Return to Service
SMTH-1214	Classroom 2A	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1215	Exterior o/s Faculty Room	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2791	Classroom 7	1007	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2792	Maintenance Room	1023A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2793	Maintenance Room Bathroom	1023A1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2794	Room 27 Boys' Bathroom	1038	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2795	Room 27 Boys' Bathroom	1038	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2796	Room 26 Girl's Bathroom	1040	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2797	Faculty Bathroom (Right)	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2798	Faculty Bathroom (Left)	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2799	Boys' Bathroom	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

Mills Pond Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-2800	Boys' Bathroom	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2801	Girls' Bathroom	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2802	Bathroom by Gym (Left)	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2803	Bathroom by Gym (Right)	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2804	Exterior o/s Room 12A	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2805	Exterior o/s Room 11	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2806	Exterior o/s Room 1A	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2807	Exterior o/s Room 36	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2808	Exterior o/s Classroom 48	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2809	Exterior o/s Classroom 47	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2810	Exterior o/s Classroom 41	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2811	Exterior o/s Room 30	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2812	Exterior o/s Band Room	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

Great Hollow Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-0495	Boiler Room	1033B	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0496	Key Room	1033C	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0497	Bathroom 134C	1033A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0498	Bathroom 134C	1033A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0501	Corridor by Room 128	1055	Water Fountain-No Chiller	Applicable	11/26/2025	10.0			Removed From Service, Pending Remediation
SMTH-0502	Room 127	1046A	Home Economics Faucet (Cold)	Applicable	11/26/2025	6.2			Removed From Service, Pending Remediation
SMTH-0503	Room 127	1046A	Home Economics Faucet (Cold)	Applicable	11/26/2025	1.1			Result Below Action Level Continue O&M
SMTH-0504	Room 127	1046A	Home Economics Faucet (Cold)	Applicable	11/26/2025	8.0			Removed From Service, Pending Remediation
SMTH-0505	Room 127	1046A	Home Economics Faucet (Cold)	Applicable	11/26/2025	1.6			Result Below Action Level Continue O&M
SMTH-0506	Room 128	1046C	Home Economics Faucet (Cold)	Applicable	11/26/2025	94.6			Removed From Service, Pending Remediation
SMTH-0507	Room 128	1046C	Home Economics Faucet (Cold)	Applicable	11/26/2025	82.2			Removed From Service, Pending Remediation
SMTH-0508	Room 128	1046C	Home Economics Faucet (Cold)	Applicable	11/26/2025	5.1			Removed From Service, Pending Remediation
SMTH-0509	Room 128	1046C	Home Economics Faucet (Cold)	Applicable	11/26/2025	182			Removed From Service, Pending Remediation
SMTH-0510	Room 126	1045	Home Economics Faucet (Cold)	Applicable	11/26/2025	3.6			Result Below Action Level Continue O&M
SMTH-0511	Room 126	1045	Home Economics Faucet (Cold)	Applicable	11/26/2025	2.9			Result Below Action Level Continue O&M
SMTH-0512	Room 126	1045	Home Economics Faucet (Cold)	Applicable	11/26/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-0513	Room 126	1045	Home Economics Faucet (Cold)	Applicable	11/26/2025	1.2			Result Below Action Level Continue O&M
SMTH-0516	Women's Faculty Room 116	1039	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0517	Women's Faculty Room 116	1039	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0518	Men's Faculty Room 117	1038	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Great Hollow Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-0519	Men's Faculty Room 117	1038	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0520	Boys' Bathroom 113	1001	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0521	Boys' Bathroom 113	1001	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0522	Boys' Bathroom 113	1001	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0523	Boys' Bathroom 113	1001	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0524	Girls' Bathroom 111	1003	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0525	Girls' Bathroom 111	1003	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0526	Girls' Bathroom 111	1003	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0527	109C	1006C	Kitchen Faucet (Cold)	Applicable	11/26/2025	149			Removed From Service, Pending Remediation
SMTH-0528	Bathroom 109E	1006F	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0529	Health Office Bathroom	1009A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0530	Health Office	1009	Nurse's Office Sink	Applicable	11/26/2025	11.9			Removed From Service, Pending Remediation
SMTH-0531	Room 104	1011	Kitchen Faucet (Cold)	Applicable	11/26/2025	42.7			Removed From Service, Pending Remediation
SMTH-0532	Room 104	1011	Ice Machine	Applicable	11/26/2025	1.5			Result Below Action Level Continue O&M
SMTH-0536	Girls' Locker Room 101A Bathroom	1015A2	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0537	Girls' Locker Room Bathroom	1015B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0538	Girls' Locker Room Bathroom	1015B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0539	Girls' Locker Room Bathroom	1015B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0540	Boys' Locker Room Office Bathroom	1017C1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0543	Boys' Locker Room Bathroom	1017B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Great Hollow Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-0544	Boys' Locker Room Bathroom	1017B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0545	Serving Area 139	1023	Kitchen Faucet (Cold)	Applicable	11/26/2025	6.0			Removed From Service, Pending Remediation
SMTH-0548	Serving Area 139	1023	Hand Wash Only	Applicable	11/26/2025	18.6			Placarded for Non-Drinking Use Until Remediated
SMTH-0549	Kitchen	1022	Hand Wash Only	Applicable	11/26/2025	11.7			Placarded for Non-Drinking Use Until Remediated
SMTH-0550	Kitchen	1022	Hand Wash Only	Applicable	11/26/2025	1.1			Result Below Action Level Continue O&M
SMTH-0551	Kitchen	1022	Kitchen Faucet (Cold)	Applicable	11/26/2025	4.8			Result Below Action Level Continue O&M
SMTH-0552	Kitchen	1022	Kitchen Faucet (Cold)	Applicable	11/26/2025	1.8			Result Below Action Level Continue O&M
SMTH-0553	Kitchen	1022	Kitchen Faucet (Cold)	Applicable	11/26/2025	31.6			Placarded for Non-Drinking Use Until Remediated
SMTH-0554	Kitchen Room 139B Bathroom	1022C	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0555	Kitchen Room 139B Bathroom	1022C	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0556	Kitchen Room 139E	1022A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0557	Kitchen	1022	Kitchen Faucet (Cold)	Applicable	11/26/2025	34.6			Removed From Service, Pending Remediation
SMTH-0559	Faculty Women's Bathroom 142	1019	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0560	Corridor by Faculty Men's Bathroom 141	NA	Water Cooler	Applicable	11/26/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-0561	Corridor by Faculty Men's Bathroom 141	NA	Bottle Fill Station	Applicable	11/26/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-0563	GIRLS BATHROOM	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0564	GIRLS BATHROOM	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0565	BOYS BATHROOM	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0566	BOYS BATHROOM	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0569	Bathroom by Elevator	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Great Hollow Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-0570	Bathroom by Elevator	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0571	Bathroom by Elevator	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0572	Bathroom by Elevator	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0573	Bathroom by Elevator	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0574	Bathroom by Elevator	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0575	Bathroom by Elevator	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0576	Bathroom by Elevator	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0577	Bathroom by Elevator	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0578	MAIN OFFICE	NA	Kitchen Faucet (Cold)	Applicable	11/26/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-0579	MAIN OFFICE	NA	Kitchen Faucet (Cold)	Applicable	11/26/2025	OOS			Testing Required Before Return to Service
SMTH-0582	Corridor by Room 168	NA	Water Cooler	Applicable	11/26/2025	OOS			Testing Required Before Return to Service
SMTH-0583	Locker Room	NA	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0584	Coach's Office Bathroom	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0585	Locker Room Bathroom	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0586	Locker Room Bathroom	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0587	Locker Room Bathroom	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0588	Locker Room	NA	Water Cooler	Applicable	11/26/2025	OOS			Testing Required Before Return to Service
SMTH-0590	Coach's Office Bathroom	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0591	Locker Room Bathroom	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0592	Locker Room Bathroom	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service RFI = Removed from Inventory

Great Hollow Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-0593	Locker Room Bathroom	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0597	Art Room 119	1037	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0598	Art Room 119	1037	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0599	Art Room 119	1037	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0600	Art Room 123	1044	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0601	Art Room 123	1044	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0602	Art Room 123	1044	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0603	Room 131	1051	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0604	Room 132	1052	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0605	Room 133	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0606	Bathroom by Elevator	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0607	Bathroom by Elevator	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0608	Bathroom by Elevator	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0609	Bathroom by Elevator	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0610	Bathroom by Elevator	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0611	Corridor by Room 256	NA	Water Cooler	Applicable	11/26/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-0612	Corridor by Room 256	NA	Bottle Fill Station	Applicable	11/26/2025	OOS			Testing Required Before Return to Service
SMTH-0613	Corridor by Room 256	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0617	Women's Faculty Restroom 234	2019	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0618	Women's Faculty Restroom 234	2019	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Great Hollow Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-0619	Men's Faculty Restroom 233	2018	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0620	Men's Faculty Restroom 233	2018	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0629	Women's Faculty Room	2042	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0630	Women's Faculty Room	2042	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0631	Men's Faculty Room 216	2041	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0633	Room 209A	2049A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0635	Corridor by Library	2016	Water Fountain-No Chiller	Applicable	11/26/2025	OOS			Testing Required Before Return to Service
SMTH-0636	Boys' Bathroom 205	2052	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0637	Boys' Bathroom 205	2052	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0638	Boys' Bathroom 205	2052	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0639	Boys' Bathroom 205	2052	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0640	Girls' Bathroom 207	2050	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0641	Girls' Bathroom 207	2050	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0642	Girls' Bathroom 207	2050	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0650	Media Center Office 201B	2004A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1879	ROOM 213	2040	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1880	ROOM 213	2040	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1881	ROOM 213	2040	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1882	ROOM 213	2040	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1883	ROOM 213	2040	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

Great Hollow Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTM-1884	ROOM 213	2040	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1885	ROOM 213	2040	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1886	ROOM 213	2040	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1887	ROOM 213	2040	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1888	ROOM 213	2040	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1889	ROOM 213	2040	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1890	ROOM 213	2040	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1891	ROOM 213	2040	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1892	ROOM 213	2040	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1893	ROOM 213	2040	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1894	ROOM 211A	2044A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1895	ROOM 211A	2044A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1896	ROOM 212	2043	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1897	ROOM 212	2043	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1898	ROOM 212	2043	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1899	ROOM 212	2043	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1900	ROOM 212	2043	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1901	ROOM 211	2044	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1902	ROOM 211	2044	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1903	ROOM 211	2044	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

Great Hollow Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTM-1904	ROOM 211	2044	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1905	ROOM 211	2044	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1906	ROOM 209	2049	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1907	ROOM 209	2049	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1908	ROOM 209	2049	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1909	ROOM 209	2049	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1910	ROOM 209	2049	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1911	ROOM 202	2001	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1912	ROOM 202	2001	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1913	ROOM 202	2001	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1914	ROOM 202	2001	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1915	ROOM 202	2001	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1916	ROOM 202A STORAGE	2001A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1917	ROOM 203	2000	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1918	ROOM 203	2000	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1919	ROOM 203	2000	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1920	ROOM 203	2000	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1921	Custodial Closet o/s 185	NA	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1922	Kitchen	1022	Spray Nozzle	Applicable	11/26/2025	1.2			Result Below Action Level Continue O&M
SMTM-1923	Room 102	1014	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use

Great Hollow Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-1924	Custodial Closet 112	1002	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1925	ROOM 203	2000	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1926	Custodial Closet 206	2051	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1927	Room 129A	1048	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1928	Room 126A	1045A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2727	Girl's Bathroom 111	1003	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2730	Girl's Locker Room 101 Corridor	1015	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2731	Girl's Locker Room	1015C	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2732	Girl's Locker Room	1015C	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2733	Girl's Locker Room	1015C	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2734	Girl's Locker Room	1015C	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2735	Girl's Locker Room	1015C	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2736	Girl's Locker Room	1015C	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2737	Girl's Locker Room	1015C	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2738	Girl's Locker Room	1015C	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2739	Girl's Locker Room	1015C	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2740	Girl's Locker Room	1015C	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2741	Girl's Locker Room	1015C	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2742	Girl's Locker Room	1015C	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2743	Girl's Locker Room	1015C	Shower Head	Non-Applicable					Placarded for Non-Drinking Use

Great Hollow Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTM-2744	Girl's Locker Room	1015C	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2745	Girl's Locker Room	1015C	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2746	Girl's Locker Room	1015C	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2747	Girl's Locker Room	1015C	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2748	Girl's Locker Room	1015C	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2749	Girl's Locker Room	1015C	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2750	Girl's Locker Room	1015C	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2751	Girl's Locker Room	1015C	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2752	Girl's Locker Room	1015C	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2753	Girl's Locker Room	1015C	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2754	Girl's Locker Room	1015C	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2755	Girl's Locker Room	1015C	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2756	Girl's Locker Room	1015C	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2757	Girl's Locker Room	1015C	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2758	Girl's Locker Room	1015C	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2759	Girl's Locker Room	1015C	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2760	Girl's Locker Room	1015C	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2761	Boy's Locker Room Shower	1017A	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2762	Boy's Locker Room Shower	1017A	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2763	Boy's Locker Room Shower	1017A	Shower Head	Non-Applicable					Placarded for Non-Drinking Use

Great Hollow Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-2764	Boy's Locker Room Shower	1017A	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2765	Boy's Locker Room Shower	1017A	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2766	Boy's Locker Room Shower	1017A	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2767	Boy's Locker Room Shower	1017A	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2768	Boy's Locker Room Shower	1017A	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2769	Boy's Locker Room Shower	1017A	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2770	Boy's Locker Room Shower	1017A	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2771	Boy's Locker Room	1017	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2772	Boy's Locker Room Office Bathroom	1017C1	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2773	Girl's Locker Room 101A Bathroom	1015A2	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2774	Bathroom 134C	1033A	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3069	Kitchen	1022	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3070	Kitchen Room 139B Bathroom	1022C	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3071	Room 126A	1045A	Washing Machine	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3072	Room 126A	1045A	Washing Machine	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3073	Room 128	1046C	Ice Machine	Applicable	11/26/2025	OOS			Testing Required Before Return to Service
SMTH-3074	Room 128	1046C	Dish Washer	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3075	Coach's Office Bathroom	NA	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3076	Locker Room Showers	NA	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3077	Locker Room Showers	NA	Shower Head	Non-Applicable					Placarded for Non-Drinking Use

Great Hollow Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-3078	Locker Room Showers	NA	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3079	Locker Room Bathroom	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3080	Coach's Office Bathroom	NA	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3081	Locker Room Showers	NA	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3082	Locker Room Showers	NA	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3083	Locker Room Showers	NA	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3084	Locker Room Bathroom	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3085	Girls' Bathroom 184	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3086	Corridor by Room 185	NA	Bottle Fill Station	Applicable	11/26/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-3087	Corridor by Room 185	NA	Water Cooler	Applicable	11/26/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-3088	Boys' Bathroom 185	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3089	Women's Room 187	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3090	Men's Room 188	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3091	Boys' Bathroom 196	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3092	Girls' Bathroom 197	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3093	Custodial Closet 197A	NA	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3094	Cafeteria West Serving Area	NA	Hand Wash Only	Applicable	11/26/2025	3.5			Result Below Action Level Continue O&M
SMTH-3095	Girl's Bathroom 207	2050	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3096	Girls' Bathroom 254	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3097	Boys' Bathroom 256	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

Great Hollow Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTM-3098	Exterior o/s West Cafeteria	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3099	Exterior o/s Wrestling Room	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3100	Exterior o/s Room 168	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3101	Exterior o/s Boys' New Locker Room	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3102	Exterior o/s Girls' New Locker Room	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3103	Exterior o/s Room 133	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3283	Corridor (Art Room 119-Main Lobby)	1042	Bottle Fill Station	Applicable	11/26/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTM-3284	Corridor (Art Room 119-Main Lobby)	1042	Water Cooler	Applicable	11/26/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTM-3285	Boy's Locker Room	1017	Bottle Fill Station	Applicable	11/26/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTM-3286	Boy's Locker Room	1017	Water Cooler	Applicable	11/26/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTM-3287	Girls Locker Room	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3288	Girls Locker Room	N/A	Bottle Fill Station	Applicable	11/26/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTM-3289	Girls Locker Room	N/A	Water Cooler	Applicable	11/26/2025	OOS			Testing Required Before Return to Service
SMTM-3290	Corridor o/s 268	N/A	Bottle Fill Station	Applicable	11/26/2025	OOS			Testing Required Before Return to Service
SMTM-3291	Corridor o/s 268	N/A	Water Cooler	Applicable	11/26/2025	OOS			Testing Required Before Return to Service
SMTM-3292	Corridor (Room 211-Room 231B)	2045	Water Fountain-No Chiller	Applicable	11/26/2025	29.3			Removed From Service, Pending Remediation
SMTM-3293	Corridor (Room 203-Room 236)	2016	Water Fountain-No Chiller	Applicable	11/26/2025	OOS			Testing Required Before Return to Service
SMTM-3294	Corridor (Room 203-Room 236)	2016	Water Fountain-No Chiller	Applicable	11/26/2025	OOS			Testing Required Before Return to Service
SMTM-3295	Corridor (Room 203-Room 236)	2016	Water Fountain-No Chiller	Applicable	11/26/2025	OOS			Testing Required Before Return to Service
SMTM-3296	Room 204	2053	Hand Wash Only	Applicable	11/26/2025	7.6			Placarded for Non-Drinking Use Until Remediated

Great Hollow Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTM-3297	Room 204	2053	Ice Machine	Applicable	11/26/2025	1.8			Result Below Action Level Continue O&M
SMTM-3298	Corridor (Room 204-Room 210)	2054	Water Fountain-No Chiller	Applicable	11/26/2025	1.0			Result Below Action Level Continue O&M

Barton Administration Annex

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-0500	Room 4	1501	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1244	Women's Bathroom	1513	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1245	Women's Bathroom	1513	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1246	Corridor o/s 1513	1519	Water Fountain-No Chiller	Applicable	12/11/2025	OOS			Testing Required Before Return to Service
SMTH-1247	Men's Bathroom	1512	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1248	Men's Bathroom	1512	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1249	Custodial Storage 122	1511	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1250	Room 124 Bathroom Men's	1505A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1251	Room 124 Bathroom Women's	1505B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1252	Room 3A	1503	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1253	Room 3A	1503	Water Fountain-No Chiller	Applicable	12/11/2025	OOS			Testing Required Before Return to Service
SMTH-1254	Room 2	1502	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1255	Room 2	1502	Water Fountain-No Chiller	Applicable	12/11/2025	OOS			Testing Required Before Return to Service
SMTH-1256	Corridor o/s 1502	1519	Water Fountain-No Chiller	Applicable	12/11/2025	OOS			Testing Required Before Return to Service
SMTH-1257	Room 5 Break Room	1506	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1258	Room 5	1506B	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1260	Multi Purpose Room	1518	Water Fountain-No Chiller	Applicable	12/11/2025	OOS			Testing Required Before Return to Service
SMTH-1261	Multi Purpose Kitchen	1521	Kitchen Faucet (Cold)	Applicable	12/11/2025	9.6			Placarded for Non-Drinking Use Until Remediated
SMTH-1262	Multi Purpose Kitchen Vestibule Slop Room	1521A1	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1263	Women's Bathroom	2505	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Barton Administration Annex

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-1264	Women's Bathroom	2505	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1265	Men's Bathroom	2506	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1266	Men's Bathroom	2506	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1267	Room 218	2507	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1268	Corridor o/s 2512C	2514	Water Fountain-No Chiller	Applicable	12/11/2025	OOS			Testing Required Before Return to Service
SMTH-1269	Room 225A	2500D	Kitchen Faucet (Cold)	Applicable	12/11/2025	6.5			Placarded for Non-Drinking Use Until Remediated
SMTH-1270	Custodial Closet 4	0006	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1271	Basement Corridor	0010	Water Fountain-No Chiller	Applicable	12/11/2025	OOS			Testing Required Before Return to Service
SMTH-1272	Room Across from Room 4 Office	0009D	Kitchen Faucet (Cold)	Applicable	12/11/2025	1.2			Result Below Action Level Continue O&M
SMTH-1273	Ladies Bathroom	0003	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1274	Men's Bathroom	0002A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2905	Women's Bathroom	2505	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2906	Room 215 Closet	2504A	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2908	Men's Bathroom	2506	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2909	Men's Bathroom	0002A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2910	Locker Room, Now File Storage Room	0004A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2911	Locker Room, Now File Storage Room	0004A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2913	Locker Room, Now File Storage Room Old Coach	0004A1A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2914	Locker Room, Now File Storage Room Old Coach	0004A1A	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2915	Locker Room, Now File Storage Room	0004A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

Barton Administration Annex

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTM-2916	Locker Room, Now File Storage Room	0004A	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2917	Locker Room, Now File Storage Room	0004A	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2918	Locker Room, Now File Storage Room	0004A	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2919	Locker Room, Now File Storage Room	0004A	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2920	Locker Room, Now File Storage Room	0004A	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2921	Locker Room, Now File Storage Room	0004A	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2922	Locker Room, Now File Storage Room	0004A	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2923	Locker Room, Now File Storage Room	0004A	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2924	Locker Room, Now File Storage Room	0004A	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2925	Locker Room, Now File Storage Room	0004A	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2926	Locker Room, Now File Storage Room	0004A	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2927	Locker Room, Now File Storage Room	0004A	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2928	Locker Room, Now File Storage Room	0004A	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2929	Locker Room, Now File Storage Room	0004A	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2930	Locker Room, Now File Storage Room	0004A	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2934	Room 4	1501	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2935	Room 4	1501	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2936	Men's Bathroom	1512	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2937	Women's Bathroom	1513	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2938	Kitchen Bathroom	1517A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Barton Administration Annex

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTM-2939	Multi Purpose Kitchen	1521	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2941	Exterior o/s Room 119	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2942	Exterior o/s Multi Purpose Kitchen Vestibule	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2943	Exterior o/s Room 4	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

Smithtown High School West

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-0533	Locker Room Bathroom	1137B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0546	Locker Room Bathroom	1137B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0624	Locker Room Bathroom	1137B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0626	Room A211 Metal Shop	2082	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0678	Weight Room Training Room	1132A	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1537	Room A102	1073	Home Economics Faucet (Cold)	Applicable	12/6/2025	26.1			Removed From Service, Pending Remediation
SMTH-1538	Room A102	1073	Home Economics Faucet (Cold)	Applicable	12/6/2025	24.5			Removed From Service, Pending Remediation
SMTH-1539	Nurse Suite Storage	1075D	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1540	Nurse Suite	1075	Nurse's Office Sink	Applicable	12/6/2025	5.3			Removed From Service, Pending Remediation
SMTH-1541	Nurse Suite	1075	Nurse's Office Sink	Applicable	12/6/2025	5.4			Removed From Service, Pending Remediation
SMTH-1542	Nurse Suite Toilet	1075A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1543	Corridor 1078 o/s 1074	1078	Bottle Fill Station	Applicable	12/6/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-1544	Corridor 1078 o/s 1074	1078	Water Fountain-No Chiller	Applicable	12/6/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-1545	Room A101	1076	Home Economics Faucet (Cold)	Applicable	12/6/2025	10.2			Removed From Service, Pending Remediation
SMTH-1546	Room A101	1076	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1547	Room A101	1076	Home Economics Faucet (Cold)	Applicable	12/6/2025	1.9			Result Below Action Level Continue O&M
SMTH-1549	Room A101	1076	Home Economics Faucet (Cold)	Applicable	12/6/2025	1.5			Result Below Action Level Continue O&M
SMTH-1550	Room A101	1076	Home Economics Faucet (Cold)	Applicable	12/6/2025	3.7			Result Below Action Level Continue O&M
SMTH-1551	Room A101	1076	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1552	Main Office Workroom	1079K	Kitchen Faucet (Cold)	Applicable	12/6/2025	33.7			Removed From Service, Pending Remediation

Smithtown High School West

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-1553	Main Office Womens Bathroom	1079I	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1554	Main Office Mens Bathroom	1079E	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1555	Reading II/Career Center	1064	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1556	Room A103	1059	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1557	Custodial Closet	1056	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1558	Custodial	1053	Kitchen Faucet (Cold)	Applicable	12/6/2025	1.9			Result Below Action Level Continue O&M
SMTH-1559	Locker Room Bathroom	1052A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1560	Break Room	1051	Kitchen Faucet (Cold)	Applicable	12/6/2025	16.0			Removed From Service, Pending Remediation
SMTH-1561	BATHROOM	1046A1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1562	Kitchen	1046	Hand Wash Only	Applicable	12/6/2025	4.1			Result Below Action Level Continue O&M
SMTH-1563	Kitchen	1046	Kitchen Faucet (Cold)	Applicable	12/6/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-1564	Kitchen	1046	Spray Nozzle	Applicable	12/6/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-1565	Kitchen	1046	Kitchen Faucet (Cold)	Applicable	12/6/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-1566	Kitchen	1046	Hand Wash Only	Applicable	12/6/2025	4.3			Result Below Action Level Continue O&M
SMTH-1568	Faculty Dining	1045	Kitchen Faucet (Cold)	Applicable	12/6/2025	4.7			Result Below Action Level Continue O&M
SMTH-1569	Boys Bathroom	1082	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1570	Boys Bathroom	1082	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1571	Mens Bathroom	1081	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1572	Corridor 1107 o/s 1081	1107	Water Fountain-No Chiller	Applicable	12/6/2025	4.4			Result Below Action Level Continue O&M
SMTH-1573	Womens Bathroom	1083	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Smithtown High School West

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-1574	Girls Bathroom	1084	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1575	Girls Bathroom	1084	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1576	Girls Bathroom	1084	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1577	Girls Bathroom	1084	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1578	Girls Bathroom	1084	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1579	Prep Room	1092	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1581	Prep Room	1092	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1582	Room C101	1085	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1583	Room C106	1086	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1584	Room C106 Inner Lab	1086A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1585	Room C106 Inner Lab	1086A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1586	Room C106 Inner Lab	1086A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1587	Room C106 Inner Lab	1086A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1588	Room C106 Inner Lab	1086A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1589	Room C106 Inner Lab	1086A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1590	Room C106 Inner Lab	1086A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1591	Room C106 Inner Lab	1086A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1592	Room C106 Inner Lab	1086A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1593	Room C106 Inner Lab	1086A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1594	Room C106 Inner Lab	1086A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

Smithtown High School West

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-1595	Room C106 Inner Lab	1086A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1596	Room C106 Inner Lab	1086A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1597	Room C106 Inner Lab	1086A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1598	Room C106 Inner Lab	1086A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1599	Room C106 Inner Lab	1086A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1600	Room C106 Inner Lab	1086A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1601	Room C106 Inner Lab	1086A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1602	Room C106 Inner Lab	1086A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1603	Room C106 Inner Lab	1086A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1604	Room C106 Inner Lab	1086A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1605	Room C106 Inner Lab	1086A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1606	Room C106 Inner Lab	1086A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1607	Room C106 Inner Lab	1086A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1608	Room C106 Inner Lab	1086A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1609	Room C106 Inner Lab	1086A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1610	Room C106 Inner Lab	1086A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1611	Room C106 Inner Lab	1086A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1612	Room C106 Inner Lab	1086A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1613	Room C106 Inner Lab	1086A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1614	Room C106 Inner Lab	1086A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

Smithtown High School West

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-1615	Room C106 Inner Lab	1086A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1616	Room C105	1130	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1617	Prep Room Adjacent To Room C105	1129	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1618	Room C104	1125	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1619	Room C104	1125	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1620	Room C104	1125	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1621	Room C104	1125	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1622	Room C104	1125	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1623	Room C104	1125	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1624	Room C104	1125	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1625	Room C104	1125	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1626	Room C104	1125	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1627	Room C104	1125	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1628	Room C104	1125	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1629	Room C104	1125	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1630	Room C104	1125	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1631	Room C104	1125	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1632	Room C103	1124	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1633	Room C103	1124	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1634	Room C103	1124	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

Smithtown High School West

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-1635	Room C103	1124	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1636	Room C103	1124	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1637	Room C103	1124	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1638	Room C103	1124	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1639	Room C103	1124	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1640	Room C103	1124	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1641	Room C103	1124	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1642	Room C103	1124	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1643	Room C103	1124	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1644	Room C103	1124	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1645	Room C103	1124	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1646	Room C102	1122	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1647	Room C102	1122	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1648	Room C102	1122	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1649	Room C102	1122	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1650	Room C102	1122	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1651	Room C102	1122	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1652	Room C102	1122	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1653	Room C102	1122	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1654	Room C102	1122	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

Smithtown High School West

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-1655	Room C102	1122	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1656	Room C102	1122	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1657	Room C102	1122	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1658	Room C102	1122	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1659	Room C102	1122	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1660	Room C111	1128	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1661	Prep Room Adjacent To Room C111	1127	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1662	Room C112	1123	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1663	Room C112	1123	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1664	Room C112	1123	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1665	Room C112	1123	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1666	Room C112	1123	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1667	Room C112	1123	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1668	Room C112	1123	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1669	Room C112	1123	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1670	Room C112	1123	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1671	Room C112	1123	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1672	Room C112	1123	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1673	Room C112	1123	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1674	Room C112	1123	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

Smithtown High School West

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTM-1675	Room C112	1123	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1676	Room C112	1123	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1677	Room C112	1123	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1678	Room C112	1123	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1679	Room C112	1123	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1680	Room C112	1123	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1681	Room C112	1123	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1682	Room C112	1123	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1683	Room C112	1123	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1684	Room C112	1123	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1685	Room C112	1123	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1686	Room C112	1123	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1687	Room C112	1123	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1688	Room C112	1123	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1689	Room C112	1123	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1690	Room C112	1123	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1691	Room C112	1123	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1692	Room C112	1123	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1693	Room C112	1123	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1694	Room C107	1093	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

Smithtown High School West

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-1695	Prep Room Adjacent To C107	1094	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1696	Room C110	1117	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1697	Room C110	1117	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1698	Room C110	1117	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1699	Room C110	1117	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1700	Room C110	1117	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1701	Room C110	1117	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1702	Room C110	1117	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1703	Room C110	1117	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1704	Room C110	1117	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1705	Room C110	1117	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1706	Room C110	1117	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1707	Room C110	1117	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1708	Room C110	1117	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1709	Room C110	1117	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1710	Room C109	1118	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1711	Room C109	1118	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1712	Room C109	1118	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1713	Room C109	1118	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1714	Room C109	1118	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

Smithtown High School West

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-1715	Room C109	1118	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1716	Room C109	1118	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1717	Room C109	1118	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1718	Room C109	1118	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1719	Room C109	1118	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1720	Room C109	1118	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1721	Room C109	1118	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1722	Room C109	1118	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1723	Room C109	1118	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1724	Room C108	1120	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1725	Room C108	1120	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1726	Room C108	1120	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1727	Room C108	1120	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1728	Room C108	1120	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1729	Room C108	1120	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1730	Room C108	1120	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1731	Room C108	1120	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1732	Room C108	1120	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1733	Room C108	1120	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1734	Room C108	1120	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

Smithtown High School West

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-1735	Room C108	1120	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1736	Room C108	1120	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1737	Room C108	1120	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1738	Mens Bathroom	1100	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1740	Womens Bathroom	1101	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1741	Corridor (Wrestling Room-Exit)	1138	Water Fountain-No Chiller	Applicable	12/6/2025	6.7			Removed From Service, Pending Remediation
SMTH-1743	Boys Bathroom	1002	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1744	Boys Bathroom	1002	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1745	Boys Bathroom	1002	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1746	Mens Bathroom	1001	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1747	Girls Bathroom	1008	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1748	Girls Bathroom	1008	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1749	Girls Bathroom	1008	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1750	Womens Bathroom	1007	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1751	Guidance Suite B Conference Room	1003A	Kitchen Faucet (Cold)	Applicable	12/6/2025	2.6			Result Below Action Level Continue O&M
SMTH-1756	Mens Bathroom	1023	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1757	Womens Bathroom	1015	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1758	Cafeteria F	1018	Water Cooler	Applicable	12/6/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-1759	Cafeteria F	1018	Bottle Fill Station	Applicable	12/6/2025	1.3			Result Below Action Level Continue O&M
SMTH-1760	Boys Bathroom	1037	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Smithtown High School West

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-1761	Boys Bathroom	1037	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1762	Boys Bathroom	1037	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1763	Mens Bathroom	1036	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1765	Girls Bathroom	1028	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1766	Girls Bathroom	1028	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1767	Girls Bathroom	1028	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1768	Womens Bathroom	1027	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1769	E Administration Work Room	1035A	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1770	Cafeteria E	1031	Water Cooler	Applicable	12/6/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-1771	Cafeteria E	1031	Bottle Fill Station	Applicable	12/6/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-1772	Kitchen E	1032	Kitchen Faucet (Cold)	Applicable	12/6/2025	2.9			Result Below Action Level Continue O&M
SMTH-1773	Kitchen E	1032	Spray Nozzle	Applicable	12/6/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-1774	Kitchen E	1032	Hand Wash Only	Applicable	12/6/2025	3.0			Result Below Action Level Continue O&M
SMTH-1775	Corridor Outside Auditorium	2096	Water Cooler	Applicable	12/6/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-1776	Corridor Outside Auditorium	2096	Bottle Fill Station	Applicable	12/6/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-1777	Boys Bathroom	2069	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1778	Boys Bathroom	2069	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1779	Boys Bathroom	2069	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1780	Boys Bathroom	2069	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1781	Boys Bathroom	2069	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Smithtown High School West

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-1782	Mens Bathroom	2068	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1783	Room A209	2079	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1784	Room A209	2079	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1785	Room A209	2079	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1786	Corridor by Room A208	2086	Water Fountain-No Chiller	Applicable	12/6/2025	3.0			Result Below Action Level Continue O&M
SMTH-1787	Room A207	2077	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1788	Room A207	2077	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1789	Music Suite Ensemble	2085G	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1790	Corridor by Stage	2092	Water Fountain-No Chiller	Applicable	12/6/2025	3.5			Result Below Action Level Continue O&M
SMTH-1791	Corridor by Library Conference Room 3	2096	Water Cooler	Applicable	12/6/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-1792	Corridor by Library Conference Room 3	2096	Bottle Fill Station	Applicable	12/6/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-1793	Womens Bathroom	2094	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1794	Womens Bathroom	2094	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1795	Womens Bathroom	2094	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1796	Mens Bathroom	2095	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1797	Mens Bathroom	2095	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1798	Mens Bathroom	2095	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1799	Corridor Outside Auxiliary Gym	2109	Water Cooler	Applicable	12/6/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-1800	Corridor Outside Auxiliary Gym	2109	Bottle Fill Station	Applicable	12/6/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-1801	Concession Stand	2098	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use

Smithtown High School West

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-1802	Material Production	2060A	Kitchen Faucet (Cold)	Applicable	12/6/2025	2.1			Result Below Action Level Continue O&M
SMTH-1803	Library Office	2063A	Kitchen Faucet (Cold)	Applicable	12/6/2025	3.6			Result Below Action Level Continue O&M
SMTH-1804	Library Office	2063B	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1805	English Office Material Production	2048A	Kitchen Faucet (Cold)	Applicable	12/6/2025	3.3			Result Below Action Level Continue O&M
SMTH-1806	Corridor Outside Library	2064	Water Fountain-No Chiller	Applicable	12/6/2025	4.4			Result Below Action Level Continue O&M
SMTH-1807	Boys Bathroom	2033	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1808	Mens Bathroom	2032	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1809	Corridor Between Tower F & Tower E	2036	Water Fountain-No Chiller	Applicable	12/6/2025	5.4			Removed From Service, Pending Remediation
SMTH-1810	Womens Bathroom	2030	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1811	Girls Bathroom	2029	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1812	Boys Bathroom	2016	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1813	Mens Bathroom	2015	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1814	Corridor Between Tower G & Tower F	2019	Water Fountain-No Chiller	Applicable	12/6/2025	2.0			Result Below Action Level Continue O&M
SMTH-1815	Girls Bathroom	2012	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1816	Womens Bathroom	2013	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1817	Corridor by Women's Bathroom	3032	Water Fountain-No Chiller	Applicable	12/6/2025	5.2			Removed From Service, Pending Remediation
SMTH-1818	Womens Bathroom	3030	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1819	Mens Bathroom	3028	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1820	Womens Bathroom	3015	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1821	Corridor by Women's Bathroom	3016	Water Fountain-No Chiller	Applicable	12/6/2025	7.3			Removed From Service, Pending Remediation

Smithtown High School West

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-1822	Bathroom	3013	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1824	Girls' Locker Room	2108	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1829	Girls' Locker Room Additional Lockers Left	2108E	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1830	Girls' Locker Room Additional Lockers Left	2108E	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1831	Girls' Locker Room	2108	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1832	Girls' Locker Room	2108	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1857	Room A212 Auto Shop	2083	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1858	Room A208	2078	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1859	Stage	2092	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1860	Auxiliary Gym IM Room	2104	Ice Machine	Applicable	12/6/2025	1.5			Result Below Action Level Continue O&M
SMTH-1861	Girls Bathroom	2090	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1862	Girls Bathroom	2090	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1863	Girls Bathroom	2090	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1864	Womens Bathroom	2089	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1876	Boys' Locker Room	2101	Water Fountain-No Chiller	Applicable	12/6/2025	OOS			Testing Required Before Return to Service
SMTH-1877	Boys' Locker Room	2101	Water Fountain-No Chiller	Applicable	12/6/2025	OOS			Testing Required Before Return to Service
SMTH-1878	Boys' Locker Room	2101	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2146	Girls' Locker Room Additional Lockers Right	2108C	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2147	Girls' Locker Room Additional Lockers Right	2108C	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2289	Room C119	1108	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Smithtown High School West

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-2479	Room A102	1073	Dish Washer	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2480	Room A102 Closet	1073A	Washing Machine	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2481	Room A102 Closet	1073A	Washing Machine	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2482	Room A101	1076	Dish Washer	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2483	Room A105	1069	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2484	Locker Room Bathroom	1052A	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2485	Boys Bathroom	1082	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2486	Boys Bathroom	1082	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2487	Girls Bathroom	1084	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2488	Girls Bathroom	1084	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2489	Main Office Mens Bathroom	1079E	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2490	Main Office Mens Bathroom	1079E	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2493	Room A107	1067	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2494	Nurse Suite	1075	Ice Machine	Applicable	12/6/2025	1.8			Result Below Action Level Continue O&M
SMTH-2495	Independent Room 2	1088	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2496	Independent Room 3	1089	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2497	Independent Room 4	1090	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2498	Independent Room 5	1091	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2499	Room C105	1130	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2500	Room C104	1125	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

Smithtown High School West

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-2501	Room C103	1124	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2502	Room C102	1122	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2503	Prep Room	1092	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2504	Room C107	1093	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2505	Prep Room Adjacent To C107	1094	Dish Washer	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2508	Room C111	1128	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2509	Room C108	1120	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2510	Room C109	1118	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2511	Room C110	1117	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2512	Independent Room 6	1095	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2513	Independent Room 7	1096	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2514	Independent Room 8	1097	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2515	Independent Room 9	1098	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2516	Independent Room 10	1099	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2517	Science Storage	1102	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2518	Room C114	1109	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2519	Room C115	1111	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2520	Room C116	1113	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2521	Custodial Closet	1131	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2522	Custodial Closet	1131	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use

Smithtown High School West

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-2523	Locker Room Shower	1137A	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2524	Locker Room Shower	1137A	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2525	Locker Room Shower	1137A	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2526	Locker Room Shower	1137A	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2527	Locker Room Shower	1137A	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2528	Locker Room Shower	1137A	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2529	Locker Room Shower	1137A	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2530	Locker Room Shower	1137A	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2531	Locker Room Shower	1137A	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2532	Locker Room Shower	1137A	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2533	Locker Room Shower	1137A	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2534	Locker Room Shower	1137A	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2535	Locker Room Shower	1137A	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2536	Locker Room Shower	1137A	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2537	Locker Room Shower	1137A	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2538	Locker Room Shower	1137A	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2539	Locker Room Shower	1137A	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2540	Locker Room Shower	1137A	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2541	Garage	1136	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2542	Corridor by Room G102	1006	Water Fountain-No Chiller	Applicable	12/6/2025	4.4			Result Below Action Level Continue O&M

Smithtown High School West

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-2543	Guidance Suite B Conference Room	1003A	Spray Nozzle	Applicable	12/6/2025	5.4			Placarded for Non-Drinking Use Until Remediated
SMTH-2546	Kitchen G	1010	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2549	Kitchen F	1019	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2550	Kitchen E	1032	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2555	Custodial Closet	2070	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2556	Room A201	2066	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2557	Room A201	2066	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2558	Room A201	2066	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2559	Room A202	2071	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2560	Room A202	2071	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2561	Room A205	2076	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2562	Room A205	2076	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2563	Room A207	2077	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2564	Room A209	2079	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2565	Room A209	2079	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2566	Room A212 Auto Shop	2083	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2567	Room A212 Auto Shop	2083	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2568	Material Production	2055	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2569	Custodial Closet	2106	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2570	Girls' Locker Room Coach's Office Bathroom	2801F1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Smithtown High School West

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-2571	Girls' Locker Room Coach's Office Bathroom	2801F1	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2572	Girls Locker Room	2108	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2573	Girls Locker Room	2108	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2574	Girls Locker Room	2108	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2575	Girls Locker Room	2108	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2576	Girls Locker Room	2108	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2577	Girls Locker Room	2108	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2578	Girls Locker Room	2108	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2579	Girls Locker Room	2108	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2580	Girls Locker Room	2108	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2581	Girls Locker Room	2108	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2582	Girls Locker Room	2108	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2583	Girls Locker Room	2108	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2584	Girls Locker Room	2108	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2585	Girls Locker Room	2108	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2586	Girls Locker Room	2108	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2587	Girls Locker Room	2108	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2588	Girls Locker Room	2108	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2589	Girls Locker Room	2108	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2590	Girls Locker Room	2108	Shower Head	Non-Applicable					Placarded for Non-Drinking Use

Smithtown High School West

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-2591	Girls Locker Room	2108	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2592	Girls Locker Room	2108	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2593	Girls Locker Room	2108	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2594	Girls Locker Room	2108	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2595	Girls Locker Room	2108	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2596	Girls Locker Room	2108	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2597	Girls Locker Room	2108	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2598	Girls Locker Room	2108	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2599	Girls Locker Room	2108	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2600	Girls Locker Room	2108	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2601	Girls Locker Room	2108	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2602	Girls Locker Room	2108	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2603	Girls Locker Room	2108	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2605	Team Locker Room	2102	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2606	Team Locker Room	2102	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2607	Team Locker Room	2102	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2608	Team Locker Room	2102	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2609	Team Locker Room	2102	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2610	Team Locker Room	2102	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2611	Team Locker Room	2102	Shower Head	Non-Applicable					Placarded for Non-Drinking Use

Smithtown High School West

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-2612	Team Locker Room	2102	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2613	Team Locker Room	2102	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2614	Team Locker Room	2102	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2615	Team Locker Room	2102	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2616	Team Locker Room	2102	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2617	Team Locker Room	2102	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2618	Team Locker Room	2102	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2619	Team Locker Room	2102	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2620	Team Locker Room	2102	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2621	Team Locker Room	2102	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2622	Team Locker Room	2102	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2623	Team Locker Room	2102	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2624	Boys' Locker Room Coach's Office Bathroom	2101C1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2625	Boys Locker Room Coaches Office Bathroom	2101C1	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2626	Boys Locker Room	2101	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2627	Boys Locker Room	2101	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2628	Boys Locker Room Office Bathroom	2101B1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2629	Boys Locker Room Office Bathroom	2101B1	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2632	Boys Locker Room	2101	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2633	Boys Locker Room	2101	Shower Head	Non-Applicable					Placarded for Non-Drinking Use

Smithtown High School West

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-2634	Boys Locker Room	2101	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2635	Boys Locker Room	2101	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2636	Boys Locker Room	2101	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2637	Boys Locker Room	2101	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2638	Boys Locker Room	2101	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2639	Boys Locker Room	2101	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2640	Boys Locker Room	2101	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2641	Boys Locker Room	2101	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2642	Boys Locker Room	2101	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2643	Boys Locker Room	2101	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2644	Boys Locker Room	2101	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2645	Boys Locker Room	2101	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2646	Boys Locker Room	2101	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2647	Boys Locker Room	2101	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2648	Boys Locker Room	2101	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2650	Boys Locker Room	2101	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2651	Boys Locker Room	2101	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2652	Boys Locker Room	2101	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2653	Boys Locker Room	2101	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2654	Boys Locker Room	2101	Shower Head	Non-Applicable					Placarded for Non-Drinking Use

Smithtown High School West

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-2655	Boys Locker Room	2101	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2656	Boys Locker Room	2101	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2657	Boys Locker Room	2101	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2658	Boys Locker Room	2101	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2659	Boys Locker Room	2101	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2660	Boys Locker Room	2101	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2661	Boys Locker Room	2101	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2662	Boys Locker Room	2101	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2663	Boys Locker Room	2101	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2664	Boys Locker Room	2101	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2665	Boys Locker Room	2101	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2666	Boys Locker Room	2101	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2667	Boys Locker Room	2101	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2668	Boys Locker Room	2101	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2669	Boys Locker Room	2101	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2670	Boys Locker Room	2101	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2671	Boys Locker Room	2101	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2672	Boys Locker Room	2101	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2673	Boys Locker Room	2101	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2674	Boys Locker Room	2101	Shower Head	Non-Applicable					Placarded for Non-Drinking Use

Smithtown High School West

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-2675	Exterior Men's Bathroom	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2676	Exterior Women's Bathroom	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2677	Custodial Closet	2031	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2680	Custodial Closet	2014	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2683	Boys' Bathroom	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2684	Custodial Closet	3014	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2685	Girls' Bathroom	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2686	Boys' Bathroom	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2687	3029	3029	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2688	Girls' Bathroom	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2689	South Courtyard	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2690	South Courtyard	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2691	North Courtyard	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2692	North Courtyard	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2693	Exterior	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2694	Exterior	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2695	Exterior	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2696	Exterior	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2697	Exterior	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2698	Exterior	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

Smithtown High School West

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-2699	Exterior	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2700	Exterior	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2701	Exterior	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2702	Exterior	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2703	Exterior	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2704	Exterior	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2705	Exterior	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2707	Exterior	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2708	Exterior	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2709	Exterior	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2710	Exterior	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2885	Exterior o/s Custodial Entrance	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3233	Concession Area	N/A	Kitchen Faucet (Cold)	Applicable	12/6/2025	OOS			Testing Required Before Return to Service
SMTH-3234	Concession Area	N/A	Kitchen Faucet (Cold)	Applicable	12/6/2025	OOS			Testing Required Before Return to Service
SMTH-3235	Concession Men's Bathroom	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3236	Concession Men's Bathroom	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3237	Concession Men's Bathroom	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3238	Concession Men's Bathroom	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3239	Concession Women's Bathroom	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3240	Concession Women's Bathroom	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Smithtown High School West

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-3241	Concession Women's Bathroom	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3242	Concession Women's Bathroom	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3243	Exterior of Concession Stand	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3259	Kitchen F	1019	Hand Wash Only	Applicable	12/6/2025	1.4			Result Below Action Level Continue O&M
SMTH-3260	Kitchen G	1010	Hand Wash Only	Applicable	12/6/2025	4.4			Result Below Action Level Continue O&M
SMTH-3300	Prep Room	1092	Ice Machine	Applicable	12/6/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-3301	Corridor 1107 o/s 1100	1107	Water Fountain-No Chiller	Applicable	12/6/2025	1.2			Result Below Action Level Continue O&M
SMTH-3302	Corridor (Room E101-Cafeteria E)	1039	Water Cooler	Applicable	12/6/2025	5.0			Result Below Action Level Continue O&M
SMTH-3303	Attendance Office	1029	Bottled Water Dispenser	Applicable	12/6/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-3344	Cafeteria G	1011	Bottle Fill Station	Applicable	12/6/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-3345	Cafeteria G	1011	Water Cooler	Applicable	12/6/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-3346	Corridor (Room F101-Cafeteria F)	1025	Bottle Fill Station	Applicable	12/6/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-3347	Corridor (Room F101-Cafeteria F)	1025	Water Cooler	Applicable	12/6/2025	<1.00 ND			Result Below Action Level Continue O&M

Mount Pleasant Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-0643	Custodial Storage Bathroom	1021A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0646	Women's Bathroom 21	1027	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0647	Women's Bathroom 21	1027	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0648	Nurse's Office	1034	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1825	Nurse's Office Bathroom	1034A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1826	Men's Bathroom 17	1032	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1827	Main Office Supply Room	1031A	Kitchen Faucet (Cold)	Applicable	12/12/2025	1.4			Result Below Action Level Continue O&M
SMTH-1828	Room 5	1038	Water Fountain-No Chiller	Applicable	12/12/2025	OOS			Testing Required Before Return to Service
SMTH-1833	Room 5	1038	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1834	Room 3	1040	Water Fountain-No Chiller	Applicable	12/12/2025	OOS			Testing Required Before Return to Service
SMTH-1835	Room 3	1040	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1836	Room 1	1041	Water Fountain-No Chiller	Applicable	12/12/2025	OOS			Testing Required Before Return to Service
SMTH-1837	Room 1	1041	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1838	Room 2	1042	Water Fountain-No Chiller	Applicable	12/12/2025	OOS			Testing Required Before Return to Service
SMTH-1839	Room 2	1042	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1840	Room 4	1039	Water Fountain-No Chiller	Applicable	12/12/2025	OOS			Testing Required Before Return to Service
SMTH-1841	Room 4	1039	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1842	Room 6	1037	Water Fountain-No Chiller	Applicable	12/12/2025	OOS			Testing Required Before Return to Service
SMTH-1843	Room 6	1037	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1844	Room 8	1036	Water Fountain-No Chiller	Applicable	12/12/2025	OOS			Testing Required Before Return to Service

Mount Pleasant Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-1845	Room 8	1036	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1846	Room 18 (Formerly Room 16)	1030	Water Fountain-No Chiller	Applicable	12/12/2025	OOS			Testing Required Before Return to Service
SMTH-1847	Room 16	1030	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1848	Library	1029	Kitchen Faucet (Cold)	Applicable	12/12/2025	1.1			Result Below Action Level Continue O&M
SMTH-2080	Room 12 (Formerly Room 11)	1048	Water Fountain-No Chiller	Applicable	12/12/2025	OOS			Testing Required Before Return to Service
SMTH-2081	Room 11	1048	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2082	Room 11	1048	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2083	Room 13 (Formerly Room 12)	1049	Water Fountain-No Chiller	Applicable	12/12/2025	OOS			Testing Required Before Return to Service
SMTH-2084	Room 12	1049	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2085	Corridor by Room 14 & 15 (Formerly by Room 12)	NA	Water Cooler	Applicable	12/12/2025	OOS			Testing Required Before Return to Service
SMTH-2086	Corridor by Room 14 & 15 (Formerly by 12)	NA	Bottle Fill Station	Applicable	12/12/2025	9.2			Removed From Service, Pending Remediation
SMTH-2087	Room 16 (Formerly Room 52)	NA	Water Fountain-No Chiller	Applicable	12/12/2025	OOS			Testing Required Before Return to Service
SMTH-2088	Room 52	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2089	Room 17 (Formerly Room 53)	NA	Water Fountain-No Chiller	Applicable	12/12/2025	OOS			Testing Required Before Return to Service
SMTH-2090	Room 53	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2091	Girls' Bathroom	1016	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2092	Girls' Bathroom	1016	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2093	Girls' Bathroom	1012	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2094	Girls' Bathroom	1012	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2095	Girls' Bathroom	1012	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Mount Pleasant Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-2096	Corridor by Room 31	1013	Water Cooler	RFI	12/12/2025	<1.00 ND			Sticker Replaced by #3373
SMTH-2097	Corridor by Room 31	1013	Bottle Fill Station	RFI	12/12/2025	<1.00 ND			Sticker Replaced by #3374
SMTH-2098	Boys' Bathroom	1011	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2099	Boys' Bathroom	1011	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2100	KITCHEN	NA	Hand Wash Only	Applicable	12/12/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-2101	KITCHEN	NA	Kitchen Faucet (Cold)	Applicable	12/12/2025	5.5			Removed From Service, Pending Remediation
SMTH-2102	KITCHEN	NA	Kitchen Faucet (Cold)	Applicable	12/12/2025	2.0			Result Below Action Level Continue O&M
SMTH-2103	KITCHEN	NA	Spray Nozzle	Applicable	12/12/2025	3.3			Result Below Action Level Continue O&M
SMTH-2104	KITCHEN	NA	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2105	FACULTY	NA	Kitchen Faucet (Cold)	Applicable	12/12/2025	3.7			Result Below Action Level Continue O&M
SMTH-2106	Bathroom	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2107	Room 29 (Formerly Room 30)	1008	Water Fountain-No Chiller	Applicable	12/12/2025	OOS			Testing Required Before Return to Service
SMTH-2108	Room 30	1008	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2109	Room 30 (Formerly Room 31)	1007	Water Fountain-No Chiller	Applicable	12/12/2025	OOS			Testing Required Before Return to Service
SMTH-2110	Room 31	1007	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2111	Room 31 (Formerly Room 32)	1006	Water Fountain-No Chiller	Applicable	12/12/2025	OOS			Testing Required Before Return to Service
SMTH-2112	Room 32	1006	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2113	Room 32 (Formerly Room 34)	1005	Water Fountain-No Chiller	Applicable	12/12/2025	OOS			Testing Required Before Return to Service
SMTH-2114	Room 34	1005	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2115	Room 34 (Formerly Room 36)	1003	Water Fountain-No Chiller	Applicable	12/12/2025	OOS			Testing Required Before Return to Service

OOS= Out of Service RFI = Removed from Inventory

Mount Pleasant Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-2116	Room 36	1003	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2117	Room 36 (Formerly Room 38)	1001	Water Fountain-No Chiller	Applicable	12/12/2025	OOS			Testing Required Before Return to Service
SMTH-2118	Room 38	1001	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2119	Room 40	NA	Water Fountain-No Chiller	Applicable	12/12/2025	OOS			Testing Required Before Return to Service
SMTH-2120	Room 40	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2121	Room 42	NA	Water Fountain-No Chiller	Applicable	12/12/2025	OOS			Testing Required Before Return to Service
SMTH-2122	Room 42	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2123	Room 44	NA	Water Fountain-No Chiller	Applicable	12/12/2025	OOS			Testing Required Before Return to Service
SMTH-2124	Room 44	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2125	Room 46 (Formerly Room 48)	NA	Water Fountain-No Chiller	Applicable	12/12/2025	OOS			Testing Required Before Return to Service
SMTH-2126	Room 48	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2127	Room 48 (Formerly Room 50)	NA	Water Fountain-No Chiller	Applicable	12/12/2025	OOS			Testing Required Before Return to Service
SMTH-2128	Room 50	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2129	Room 47 (Formerly Room 51)	NA	Water Fountain-No Chiller	Applicable	12/12/2025	OOS			Testing Required Before Return to Service
SMTH-2130	Room 51	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2131	Room 45 (Formerly Room 49)	NA	Water Fountain-No Chiller	Applicable	12/12/2025	OOS			Testing Required Before Return to Service
SMTH-2132	Room 49	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2133	Room 43	NA	Water Fountain-No Chiller	Applicable	12/12/2025	OOS			Testing Required Before Return to Service
SMTH-2134	Room 43	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2135	Room 43	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Mount Pleasant Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-2136	Room 41	NA	Water Fountain-No Chiller	Applicable	12/12/2025	OOS			Testing Required Before Return to Service
SMTH-2137	Room 41	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2138	Room 39	NA	Water Fountain-No Chiller	Applicable	12/12/2025	OOS			Testing Required Before Return to Service
SMTH-2139	Room 39	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2140	Room 37	1000	Water Fountain-No Chiller	Applicable	12/12/2025	OOS			Testing Required Before Return to Service
SMTH-2141	Room 37	1000	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2142	Room 35	1002	Water Fountain-No Chiller	Applicable	12/12/2025	OOS			Testing Required Before Return to Service
SMTH-2143	Room 35	1002	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2144	Room 33	1004	Water Fountain-No Chiller	Applicable	12/12/2025	OOS			Testing Required Before Return to Service
SMTH-2145	Room 33	1004	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2964	Custodial Closet o/s Room 44	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2965	Custodial Closet	1010	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2966	Custodial Storage Slop	1021B	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2967	Custodial Storage Slop	1021B	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2968	New Addition Cafeteria Custodial Closet	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2970	Custodial Closet	1033	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2971	Custodial Closet New Addition	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2972	Exterior o/s (1022)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2973	Exterior o/s (1008)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2974	Exterior o/s Room 51	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

Mount Pleasant Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTM-2975	Exterior o/s (1037)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2976	Exterior o/s (1050)	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2977	Exterior o/s New Addition	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2978	Exterior o/s New Addition	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3306	Main Lobby o/s Women's Bathroom	1028	Water Cooler	Applicable	12/12/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTM-3307	Main Lobby o/s Women's Bathroom	1028	Bottle Fill Station	Applicable	12/12/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTM-3308	Principal's Office	1031B	Bottled Water Dispenser (Cold)	Applicable	12/12/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTM-3309	Principal's Office	1031B	Bottled Water Dispenser (Hot)	Applicable	12/12/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTM-3310	Corridor o/s Room 45	N/A	Water Cooler	Applicable	12/12/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTM-3311	Corridor o/s Room 45	N/A	Bottle Fill Station	Applicable	12/12/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTM-3373	Corridor (Room 30-37)	1013	Water Cooler	Applicable	12/12/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTM-3374	Corridor (Room 30-37)	1013	Bottle Fill Station	Applicable	12/12/2025	<1.00 ND			Result Below Action Level Continue O&M

Tackan Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-0651	Room 7 (Formerly CLASSROOM 1A)	NA	Water Fountain-No Chiller	Applicable	12/4/2025	OOS			Testing Required Before Return to Service
SMTH-0652	Room 8 (Formerly CLASSROOM 2A)	NA	Water Fountain-No Chiller	Applicable	12/4/2025	OOS			Testing Required Before Return to Service
SMTH-0653	Room 11 (Formerly Classroom 1)	1052	Water Fountain-No Chiller	Applicable	12/4/2025	OOS			Testing Required Before Return to Service
SMTH-0654	Room 10 (Formerly Classroom 2)	1053	Water Fountain-No Chiller	Applicable	12/4/2025	OOS			Testing Required Before Return to Service
SMTH-0655	Room 13 (Formerly Classroom 3)	1054	Water Fountain-No Chiller	Applicable	12/4/2025	OOS			Testing Required Before Return to Service
SMTH-0656	Room 12 (Formerly Classroom 4)	1055	Water Fountain-No Chiller	Applicable	12/4/2025	OOS			Testing Required Before Return to Service
SMTH-0657	Room 15 (Formerly Classroom 5)	1056	Water Fountain-No Chiller	Applicable	12/4/2025	OOS			Testing Required Before Return to Service
SMTH-0658	Room 14 (Formerly Classroom 6)	1057	Water Fountain-No Chiller	Applicable	12/4/2025	OOS			Testing Required Before Return to Service
SMTH-0659	Room 16 (Formerly Classroom 8 Resource Room)	1050	Water Fountain-No Chiller	Applicable	12/4/2025	OOS			Testing Required Before Return to Service
SMTH-0660	Social Worker Office	1041	Water Fountain-No Chiller	Applicable	12/4/2025	OOS			Testing Required Before Return to Service
SMTH-0661	LIBRARY	1037	Kitchen Faucet (Cold)	Applicable	12/4/2025	19.9			Removed From Service, Pending Remediation
SMTH-0662	NURSES OFFICE	1042	Nurse's Office Sink	Applicable	12/4/2025	19.3			Removed From Service, Pending Remediation
SMTH-0663	Custodail Closet O/S Library	1040	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0664	Main Office Mail Room	1038C	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0665	Main Lobby	1036	Water Cooler	Applicable	12/4/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-0666	Room 4 (Formerly Classroom 9)	1048	Water Fountain-No Chiller	Applicable	12/4/2025	OOS			Testing Required Before Return to Service
SMTH-0667	Room 3 (Formerly Classroom 10)	1047	Water Fountain-No Chiller	Applicable	12/4/2025	OOS			Testing Required Before Return to Service
SMTH-0668	Room 2 (Formerly CLASSROOM 11B)	NA	Water Fountain-No Chiller	Applicable	12/4/2025	OOS			Testing Required Before Return to Service
SMTH-0669	CLASSROOM 12A	NA	Water Fountain-No Chiller	Applicable	12/4/2025	OOS			Testing Required Before Return to Service
SMTH-0670	CLASSROOM 12A	NA	Water Cooler	Applicable	12/4/2025	<1.00 ND			Result Below Action Level Continue O&M

Tackan Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-0671	CLASSROOM 12A	NA	Bottle Fill Station	Applicable	12/4/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-0672	Custodial Closet O/S 12A	NA	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0673	Room 17 (Formerly Classroom 7)	1049	Kitchen Faucet (Cold)	Applicable	12/4/2025	3.0			Result Below Action Level Continue O&M
SMTH-0674	FACULTY	NA	Kitchen Faucet (Cold)	Applicable	12/4/2025	1.8			Result Below Action Level Continue O&M
SMTH-0675	Bathroom o/s Faculty Lounge	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0676	KITCHEN	NA	Spray Nozzle	Applicable	12/4/2025	15.1	12/31/2025	4.0	Outlet Remediated and Returned to Service, Continue O&M
SMTH-0677	KITCHEN	NA	Hand Wash Only	Applicable	12/4/2025	22.9			Further Investigation Determined Outlet Use to be Non-Applicable. Placarded for Non-Drinking Use
SMTH-0679	KITCHEN	NA	Hand Wash Only	Applicable	12/4/2025	9.2			Placarded for Non-Drinking Use Until Remediated
SMTH-0680	Room 28 (Formerly Room 30)	1019	Water Fountain-No Chiller	Applicable	12/4/2025	OOS			Testing Required Before Return to Service
SMTH-0681	Custodial Closet O/S Room 30	1017	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0682	Room 30 (Formerly Room 31)	1015	Water Fountain-No Chiller	Applicable	12/4/2025	OOS			Testing Required Before Return to Service
SMTH-0683	Room 32	1014	Water Cooler	Applicable	12/4/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-0684	Room 32 (Music room)	1014	Water Fountain-No Chiller	Applicable	12/4/2025	OOS			Testing Required Before Return to Service
SMTH-0685	Room 34	1011	Water Fountain-No Chiller	Applicable	12/4/2025	OOS			Testing Required Before Return to Service
SMTH-0686	Room 29 (Formerly Room 33)	1012	Water Fountain-No Chiller	Applicable	12/4/2025	OOS			Testing Required Before Return to Service
SMTH-0687	Room 36	1009	Water Fountain-No Chiller	Applicable	12/4/2025	OOS			Testing Required Before Return to Service
SMTH-0688	Room 31 (Formerly Room 35)	1010	Water Fountain-No Chiller	Applicable	12/4/2025	OOS			Testing Required Before Return to Service
SMTH-0689	Room 38	1007	Water Fountain-No Chiller	Applicable	12/4/2025	OOS			Testing Required Before Return to Service
SMTH-0690	Room 33 (Formerly Room 37)	1008	Water Fountain-No Chiller	Applicable	12/4/2025	OOS			Testing Required Before Return to Service
SMTH-0691	Room 40 (Formerly Room 41)	1004	Water Fountain-No Chiller	Applicable	12/4/2025	OOS			Testing Required Before Return to Service

Tackan Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-0692	Room 37 (Formerly Room 40)	1005	Water Fountain-No Chiller	Applicable	12/4/2025	OOS			Testing Required Before Return to Service
SMTH-0693	Room 42 (Formerly Room 43)	1002	Water Fountain-No Chiller	Applicable	12/4/2025	OOS			Testing Required Before Return to Service
SMTH-0694	Room 39 (Formerly Room 42)	1003	Water Fountain-No Chiller	Applicable	12/4/2025	OOS			Testing Required Before Return to Service
SMTH-0695	Room 44 (Formerly Room 45)	1000	Water Fountain-No Chiller	Applicable	12/4/2025	OOS			Testing Required Before Return to Service
SMTH-0696	Room 41 (Formerly Room 44)	1001	Water Fountain-No Chiller	Applicable	12/4/2025	OOS			Testing Required Before Return to Service
SMTH-0697	Corridor next to room 45 (Formerly CLASSROOM 46)	NA	Water Cooler	Applicable	12/4/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-0698	Corridor next to room 45(Formerly CLASSROOM 46)	NA	Water Cooler	Applicable	12/4/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-0699	Adjacent to Room 46	NA	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0700	CLASSROOM 46	NA	Water Fountain-No Chiller	Applicable	12/4/2025	OOS			Testing Required Before Return to Service
SMTH-0701	Corridor by Room 32	1014	Bottle Fill Station	Applicable	12/4/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-0702	Boiler Room	1031	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0703	CLASSROOM 1A	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0704	CLASSROOM 2A	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0705	Classroom 1	1052	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0706	Classroom 2	1053	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0707	Classroom 3	1054	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0708	Classroom 4	1055	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0709	Classroom 5	1056	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0710	Classroom 6	1057	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0711	Classroom 8 Resource Room	1050	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Tackan Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-0712	Social Worker Office	1041	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0713	Classroom 9	1048	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0714	Classroom 10	1047	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0715	CLASSROOM 11B	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0716	CLASSROOM 12A	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0717	Boiler Room Bathroom	1031A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0718	Room 30	1019	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0719	Room 31	1015	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0720	Room 32	1014	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0721	Room 34	1011	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0722	Room 33	1012	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0723	Room 36	1009	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0724	Room 35	1010	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0725	Room 38	1007	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0726	Room 37	1008	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0727	Room 41	1004	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0728	Room 40	1005	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0729	Room 43	1002	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0730	Room 42	1003	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0731	Room 45	1000	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Tackan Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-0732	Room 44	1001	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0733	CLASSROOM 46	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0734	Main Lobby	1036	Bottle Fill Station	Applicable	12/4/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-0735	BATHROOM	1035	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0736	BATHROOM	1035	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0737	MENS BATHROOM	1039	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0738	WOMENS BATHROOM	1024	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0739	WOMENS BATHROOM	1024	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0740	BATHROOM	1021	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0741	BATHROOM	1021	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0742	BATHROOM	1016	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0743	BATHROOM	1016	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0744	BATHROOM	1016	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0745	KITCHEN	NA	Kitchen Faucet (Cold)	Applicable	12/4/2025	7.3	12/31/2025	< 1.0	Outlet Remediated and Returned to Service, Continue O&M
SMTH-0746	KITCHEN	NA	Kitchen Faucet (Cold)	Applicable	12/4/2025	139	12/31/2025	< 1.0	Outlet Remediated and Returned to Service, Continue O&M
SMTH-0747	NURSES OFFICE BATH	1042C	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3104	Room 37	1008	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3105	Boys Bathroom	1016	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3106	Girls Bathroom	1021	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3107	Ladies Faculty Bathroom	1024	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

Tackan Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-3108	Maintenance Room	1031	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3109	Maintenance Room	1031	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3110	Boiler Room	1033	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3111	Boiler Room	1033	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3112	Boiler Room	1033	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3113	Womens Bathroom	1035	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3114	Library Bathroom	1037B	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3115	Social Worker Office Bathroom	1041B	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3116	Health Office Bathroom	1042C	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3117	Classroom 11B Bathroom	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3118	Classroom 12A Bathroom	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3119	Classroom 8 Resource Room Bathroom	1050B	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3120	Classroom 1 Closet	1052A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3121	Classroom 2 Bathroom	1053B	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3122	Classroom 4 Bathroom	1055B	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3123	Classroom 6 Bathroom	1057B	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3124	Kitchen	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3125	Custodial Closet in Cafeteria	NA	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3128	Exterior o/s Classroom 9	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3129	Exterior o/s Classroom 2A	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

Tackan Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTM-3130	Exterior o/s Classroom 46	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3131	Exterior o/s Classroom 38	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3132	Exterior o/s Classroom 30	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3133	Exterior o/s Boiler Room	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3134	Exterior o/s Classroom 12A	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

Smithtown High School East

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-0748	Kitchen	1040	Kitchen Faucet (Cold)	Applicable	12/13/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-0749	Kitchen	1040	Kitchen Faucet (Cold)	Applicable	12/13/2025	OOS			Testing Required Before Return to Service
SMTH-0750	Kitchen	1040	Kitchen Faucet (Cold)	Applicable	12/13/2025	2.9			Result Below Action Level Continue O&M
SMTH-0751	Kitchen	1040	Kitchen Faucet (Cold)	Applicable	12/13/2025	3.0			Result Below Action Level Continue O&M
SMTH-0752	Kitchen	1040	Hand Wash Only	RFI	12/13/2025	209			Outlet Permanently Removed
SMTH-0753	Custodial Office	1051	Kitchen Faucet (Cold)	Applicable	12/13/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-0754	Custodial Office Bathroom (Men's)	1051	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0755	Custodial Office Bathroom (Women's)	1051	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0756	Boys Bathroom	1049	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0757	Boys Bathroom	1049	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0758	Boys Bathroom	1049	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0759	Girls Bathroom	1048	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0760	Girls Bathroom	1048	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0761	Custodial Closet	1047	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0762	Cafeteria Bathroom	1046	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0763	Kitchen Custodial Closet	1040A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0764	Commons Cafeteria	1036	Water Fountain-No Chiller	Applicable	12/13/2025	31.1			Removed From Service, Pending Remediation
SMTH-0765	Commons Cafeteria	1036	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0766	Commons Cafeteria	1036	Water Fountain-No Chiller	Applicable	12/13/2025	OOS			Testing Required Before Return to Service
SMTH-0767	School Store	1042	Kitchen Faucet (Cold)	Applicable	12/13/2025	8.9			Removed From Service, Pending Remediation

Smithtown High School East

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-0768	School Store	1042	Kitchen Faucet (Cold)	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0770	Corridor (School Store - Room 105)	1123	Water Fountain-No Chiller	Applicable	12/13/2025	1.5			Result Below Action Level Continue O&M
SMTH-0771	Men's Bathroom	1125	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0772	Men's Bathroom	1125	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0773	Men's Bathroom	1125	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0774	Women's Bathroom	1126	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0775	Women's Bathroom	1126	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0776	Women's Bathroom	1126	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0777	Women's Bathroom	1126	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0778	Main Office Hallway	1129	Bottle Fill Station	Applicable	12/13/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-0779	Main Office Hallway	1129	Water Cooler	Applicable	12/13/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-0780	Main Office	1128	Water Cooler	Applicable	12/13/2025	OOS			Testing Required Before Return to Service
SMTH-0781	Main Office Bathroom	1128B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0782	Main Office Kitchen	1128C	Kitchen Faucet (Cold)	Applicable	12/13/2025	1.8			Result Below Action Level Continue O&M
SMTH-0783	Mens Bathroom	1170A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0785	Main Cafeteria Dish Room	1124A	Kitchen Faucet (Cold)	Applicable	12/13/2025	2.5			Result Below Action Level Continue O&M
SMTH-0786	Main Cafeteria Dish Room	1124A	Hand Wash Only	Applicable	12/13/2025	12.8			Placarded for Non-Drinking Use Until Remediated
SMTH-0788	Women's Handicapped Bathroom	1114	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0789	Men's Handicapped Bathroom	1113	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0790	Room 184	1112A	Water Fountain-No Chiller	Applicable	12/13/2025	2.4			Result Below Action Level Continue O&M

Smithtown High School East

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-0791	Room 186	1111	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0792	Women's Faculty Room Electric Room	1108B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0793	Men's Faculty Room Electric Room	1108C	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0794	Men's Faculty Room Slop	1108A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0795	Room 168	1098	Water Fountain-No Chiller	Applicable	12/13/2025	OOS			Testing Required Before Return to Service
SMTH-0796	Women's Bathroom	1105	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0797	Women's Bathroom	1105	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0798	Women's Bathroom	1105	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0799	Men's Bathroom	1104	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0800	Men's Bathroom	1104	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0801	Men's Bathroom	1104	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0802	Room 168	1098	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0803	Room 168	1098	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0804	Room 168	1098	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0805	Room 169	1103	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0806	Room 169	1103	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0807	Girls Bathroom	1131	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0808	Girls Bathroom	1131	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0809	Boys Bathroom	1132	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0810	Boys Bathroom	1132	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Smithtown High School East

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-0811	Library Vestibule	1134	Bottle Fill Station	Applicable	12/13/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-0812	Library Vestibule	1134	Water Cooler	Applicable	12/13/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-0813	Room 158 And 160	1089	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0814	Room 158 And 160	1089	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0815	Room 158 And 160	1089	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0816	Room 158 And 160	1089	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0817	Room 158 And 160	1089	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0818	Room 158 And 160	1089	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0820	Room 158 And 160	1089	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0821	Room 158 And 160	1089	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0822	Room 158 And 160	1089	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0823	Rooms 157 And 161 (Hallway)	1106	Water Fountain-No Chiller	Applicable	12/13/2025	OOS			Testing Required Before Return to Service
SMTH-0824	Rooms 157 And 161	1091	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0825	Rooms 157 And 161	1091	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0826	Rooms 157 And 161	1091	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0827	Rooms 157 And 161	1091	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0828	Rooms 157 And 161	1091	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0829	NURSES OFFICE	1088	Nurse's Office Sink	Applicable	12/13/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-0830	NURSES OFFICE	1088	Nurse's Office Sink	Applicable	12/13/2025	1.2			Result Below Action Level Continue O&M
SMTH-0831	Nurses Office Bathroom	1088B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Smithtown High School East

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-0832	Corridor Outside Trainers Office	1143	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0833	Gym Storage	1143	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0834	Gym Storage	1143	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0835	Gym Storage	1143	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0837	Girls Locker Room	1145	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0838	Girls Locker Room	1145	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0839	Girls Locker Room	1145	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0840	Girls Locker Room Coach's Office Bathroom	1145B1A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0841	Locker Rooms Field Hockey/Lacrosse	1146A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0842	Locker Rooms Field Hockey/Lacrosse	1146A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0843	Team Locker Room 2	1146B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0844	Team Locker Room 2	1146B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0845	Girls Locker Room (Hallway)	1145	Bottle Fill Station	Applicable	12/13/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-0846	Girls Locker Room	1145	Water Cooler	Applicable	12/13/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-0847	Women's Bathroom	1167	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0848	Women's Bathroom	1167	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0849	Men's Bathroom	1166	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0850	Men's Bathroom	1166	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0851	Small Gym	1147	Water Fountain-No Chiller	Applicable	12/13/2025	8.2			Removed From Service, Pending Remediation
SMTH-0852	Small Gym	1147	Water Fountain-No Chiller	Applicable	12/13/2025	6.5			Removed From Service, Pending Remediation

Smithtown High School East

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-0853	Ice Machine Room	1139	Ice Machine	Applicable	12/13/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-0854	Boys Team Locker Room Coaches Office Bathroom	1152A1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0855	Boys Team Locker Room	1152	Water Fountain-No Chiller	Applicable	12/13/2025	1.9			Result Below Action Level Continue O&M
SMTH-0856	Boys Team Locker Room	1152	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0857	Boys Locker Room Coach's Office Bathroom	1163A1	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0858	BOYS LOCKER ROOM	1163	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0859	BOYS LOCKER ROOM	1163	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0860	BOYS LOCKER ROOM	1163	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0861	Boys Locker Room Storage 4	1163F	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0862	Trainers Room Bathroom	1164A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0863	Women's Bathroom	1159	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0864	Women's Bathroom	1159	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0865	Large Gymnasium (Hallway)	1162	Water Fountain-No Chiller	Applicable	12/13/2025	1.7			Result Below Action Level Continue O&M
SMTH-0866	Men's Bathroom	1160	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0867	Men's Bathroom	1160	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0868	Custodial Closet	1156	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0876	WOMENS BATHROOM	1081	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0877	WOMENS BATHROOM	1081	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0878	WOMENS BATHROOM	1081	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0879	Custodial Closet	1080	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use

Smithtown High School East

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-0880	Room 150	1077	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0881	Room 150	1077	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0882	Room 150	1077	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0883	Room 150	1077	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0884	Room 150	1077	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0885	Room 150	1077	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0886	Room 150	1077	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0887	Room 150	1077	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0888	Room 150	1077	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0889	Room 150	1077	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0890	Room D Office	1076A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0891	Room 148	1075	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0892	Room 148	1075	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0893	Room 148	1075	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0894	Room 148	1075	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0895	Room 148	1075	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0896	Room 148	1075	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0897	Room 148	1075	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0898	Room 148	1075	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0899	Room 148	1075	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

Smithtown High School East

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-0900	Hallway Across Room 150	1074	Water Fountain-No Chiller	Applicable	12/13/2025	5.7			Removed From Service, Pending Remediation
SMTH-0901	Custodial Closet	1063	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0902	Room 146 Auto Shop	1069	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0903	Men's Bathroom	1072	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0904	Women's Bathroom	1071	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0905	Room 145 Wood Shop	1070	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0906	Room 144	1067	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0907	STAGE	1078	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0908	Room 138	1032	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0909	Room 138	1032	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0910	Room 138	1032	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0911	Room 138	1032	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0912	Room 138	1032	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0913	Room 138	1032	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0914	Room 138	1032	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0915	Room 138	1032	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0916	Room 138	1032	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0917	Room 138	1032	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0918	Room 149A Prep Room	1032A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0919	Room 136	1030	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

Smithtown High School East

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-0920	Room 136	1030	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0921	Room 136	1030	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0922	Room 136	1030	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0923	Room 136	1030	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0924	Room 136	1030	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0925	Room 136	1030	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0926	Room 136	1030	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0927	Room 136	1030	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0928	Room 137	1031	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0929	Room 137	1031	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0930	Room 137	1031	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0931	Room 137	1031	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0932	Room 137	1031	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0933	Room 137	1031	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0934	Room 137	1031	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0935	Room 137	1031	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0936	Room 137	1031	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0937	Room 137	1031	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0938	Room 137A Prep Room	1031B	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0939	Room 150A Prep Room	1031A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

Smithtown High School East

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-0940	Room 135	1029	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0941	Room 135	1029	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0942	Room 135	1029	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0943	Room 135	1029	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0944	Room 135	1029	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0945	Room 135	1029	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0946	Room 135	1029	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0947	Room 135	1029	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0948	Room 135	1029	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0949	Women's Faculty Bathroom	1026	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0950	Women's Faculty Bathroom	1026	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0951	Room 133A (Hallway)	1018	Water Fountain-No Chiller	Applicable	12/13/2025	OOS			Testing Required Before Return to Service
SMTH-0952	Custodial Closet	1025	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0953	Men's Faculty Bathroom	1024	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0954	Men's Faculty Bathroom	1024	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0955	Room 133D	1021	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0956	Room 133D	1021	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0957	Room 133D	1021	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0958	Room 133D	1021	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0959	Room 133D	1021	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

Smithtown High School East

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-0960	Room 133D	1021	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0961	Room 133D	1021	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0962	Room 133D	1021	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0963	Room 133D	1021	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0964	Room 133D	1021	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0965	Room 133D	1021	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0966	Room 133C	1020	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0967	Room 133C	1020	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0968	Room 133C	1020	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0969	Room 133C	1020	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0970	Room 133C	1020	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0971	Room 133C	1020	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0972	Room 133C	1020	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0973	Room 133C	1020	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0974	Room 133C	1020	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0975	Room 133C	1020	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0976	Room 133C	1020	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0977	Room 133C	1020	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0978	Room 133C	1020	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0979	Room 133B	1019	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

Smithtown High School East

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-0980	Room 133B	1019	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0981	Room 133B	1019	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0982	Room 133B	1019	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0983	Room 133B	1019	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0984	Room 133B	1019	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0985	Room 133B	1019	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0986	Room 133B	1019	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0987	Room 133B	1019	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0988	Room 133B	1019	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0989	Room 133B	1019	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0990	Room 133A	1018	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0991	Room 133A	1018	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0992	Room 133A	1018	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0993	Room 133A	1018	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0994	Room 133A	1018	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0995	Room 133A	1018	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0996	Room 133A	1018	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0997	Room 133A	1018	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0998	Room 133A	1018	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-0999	Room 133A	1018	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

Smithtown High School East

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-1000	Room 133A	1018	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1001	Room 131	1013	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1002	Room 131	1013	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1003	Room 131	1013	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1004	Room 131	1013	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1005	Room 131	1013	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1006	Room 131	1013	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1007	Room 131	1013	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1008	Room 131	1013	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1009	Room 131	1013	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1010	Science Prep Room	1027	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1011	Room 132	1012	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1012	Room 132	1012	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1013	Room 132	1012	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1014	Room 132	1012	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1015	Room 132	1012	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1016	Room 132	1012	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1017	Room 132	1012	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1018	Room 132	1012	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1019	Room 132	1012	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

Smithtown High School East

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-1020	Room 130 Science Prep	1010	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1021	Room 128	1008	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1022	Room 128	1008	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1023	Room 128	1008	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1024	Room 128	1008	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1025	Room 128	1008	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1026	Room 128	1008	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1027	Room 128	1008	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1028	Room 128	1008	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1029	Room 128	1008	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1030	Room 127	1009	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1031	Room 127	1009	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1032	Room 127	1009	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1033	Room 127	1009	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1034	Room 127	1009	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1035	Room 127	1009	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1036	Room 127	1009	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1037	Room 127	1009	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1038	Room 127	1009	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1040	Room 120 (Hallway)	1000	Bottle Fill Station	Applicable	12/13/2025	<1.00 ND			Result Below Action Level Continue O&M

Smithtown High School East

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-1041	Room 120 (Hallway)	1000	Water Fountain-No Chiller	Applicable	12/13/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-1042	Custodial Closet	2012	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1043	Faculty Male	2013	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1044	Faculty Male	2013	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1045	Faculty Female	2014	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1046	Faculty Female	2014	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1047	Corridor by Computer Server Room	2015	Water Fountain-No Chiller	Applicable	12/13/2025	64.0			Removed From Service, Pending Remediation
SMTH-1048	Room 233 Kitchen	2008C	Kitchen Faucet (Cold)	Applicable	12/13/2025	11.7			Removed From Service, Pending Remediation
SMTH-1049	Girls' Bathroom	3013	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1050	Girls' Bathroom	3013	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1051	Boys' Bathroom	3012	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1052	Boys' Bathroom	3012	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1053	Custodial Closet	3011	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1054	3rd Floor Lobby North	3016	Water Fountain-No Chiller	Applicable	12/13/2025	OOS			Testing Required Before Return to Service
SMTH-1055	Female Faculty Room	3019B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1056	Female Faculty Room	3019B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1057	Male Faculty Room	3019A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1058	Math Office Kitchenette	3029	Kitchen Faucet (Cold)	Applicable	12/13/2025	3.7			Result Below Action Level Continue O&M
SMTH-1059	Men's Bathroom	3031	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1060	Girls' Bathroom	3033	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Smithtown High School East

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-1061	Custodial Closet	3032	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1062	Corridor by Girls' Bathroom	3045	Bottle Fill Station	Applicable	12/13/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-1063	Corridor by Girls' Bathroom	3045	Water Cooler	Applicable	12/13/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-1064	Faculty Female	3046C	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1065	Faculty Female	3046C	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1066	Faculty Male	3046B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1068	Custodial Closet	3060	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1069	Men's Bathroom	3061	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1070	Men's Bathroom	3061	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1071	Women's Bathroom	3062	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1072	Women's Bathroom	3062	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1073	Room 330 North Social Studies	3020	Kitchen Faucet (Cold)	Applicable	12/13/2025	17.2			Removed From Service, Pending Remediation
SMTH-1074	Corridor by Women's Bathroom	3047	Water Fountain-No Chiller	Applicable	12/13/2025	9.4			Removed From Service, Pending Remediation
SMTH-1075	Custodial Closet	2028	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1076	Men's Faculty Bathroom	2029	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1077	Men's Faculty Bathroom	2029	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1079	Women's Faculty Bathroom	2030	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1080	Women's Faculty Bathroom	2030	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1081	210 English Dept Break Room	2024C	Kitchen Faucet (Cold)	Applicable	12/13/2025	1.4			Result Below Action Level Continue O&M
SMTH-1083	(Courtyard) Room 135	1029	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

Smithtown High School East

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-1084	(Courtyard) Auditorium	1035	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1085	Courtyard (Room 123 Business/Science Teachers	1005	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1086	Guidance Office, Side Corridor Office	1122L	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1087	Men's Bathroom	1125	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1088	Boiler Room Near Main Office	1170G	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1089	Main Office Room With Safe	1128D	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1090	Corridor (Ramp Outside Main Office - Main Office)	1129	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1091	Main Cafeteria	1124	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1092	Main Cafeteria Custodial Closet	1124B	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1093	Little Theatre Side Storage	1130A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1094	Boys Bathroom Storage	1132A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1095	Library	1133	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1096	Library	1133	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1097	Locker Rooms Field Hockey/Lacrosse	1146A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1098	Large Gymnasium	1162	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1099	Large Gymnasium Vestibule Closet 2	1162B1	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1100	Large Gymnasium	1162	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1101	Large Gymnasium Vestibule Closet	1162A1	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1102	Room 146 Auto Shop	1069	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1103	Boiler Room	1066	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

Smithtown High School East

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-1104	Room 133C	1020	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1105	Room 133B	1019	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1106	Room 124	1002	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2402	Kitchen	1040	Hand Wash Only	Applicable	12/13/2025	12.6			Further Investigation Determined Outlet Use to be Non-Applicable. Placarded for Non-Drinking Use
SMTH-2403	Room 123	1005	Kitchen Faucet (Cold)	Applicable	12/13/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-2406	Room 127	1009	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2407	Room 128	1008	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2408	Science Prep Room 130	1010	Ice Machine	Applicable	12/13/2025	6.4			Further Investigation Determined Outlet Use to be Non-Applicable. Placarded for Non-Drinking Use
SMTH-2409	Room 132	1012	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2410	Science Prep	1027	Ice Machine	Applicable	12/13/2025	1.3			Further Investigation Determined Outlet Use to be Non-Applicable. Placarded for Non-Drinking Use
SMTH-2411	Room 131	1013	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2412	Room 137A Greenhouse	1031B	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2413	Room 136	1030	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2414	Science Storage	1034	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2415	Room 142	1061	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2416	Room 142	1061	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2417	Room 142	1061	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2418	Room 145 Woodshop	1070A	Bottled Water Dispenser (Hot)	Applicable	12/13/2025	OOS			Testing Required Before Return to Service
SMTH-2419	Room 145 Woodshop	1070A	Bottled Water Dispenser (Cold)	Applicable	12/13/2025	OOS			Testing Required Before Return to Service
SMTH-2420	Room 146 Auto Shop	1069	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

Smithtown High School East

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-2421	Room 146 Auto Shop	1069	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2422	Room 150	1077	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2423	Front Office Between Room 149 And 151	1083A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2424	Room 152 Technology Room Workshop	1085A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2425	Boy's Locker Room	1063	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2426	Boy's Locker Room	1063	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2427	Boy's Locker Room	1063	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2428	Athletic Trainer Bathroom	1164A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2429	Women's Bathroom	1159	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2430	Boy's Locker Room Storage 4	1163F	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2431	Boy's Locker Room Storage 4	1163F	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2432	Men's Bathroom	1160	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2433	Girls Coach's Office Bathroom	1145B1A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2434	Girl's Locker Room	1145	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2435	Girl's Locker Room	1145	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2436	Girl's Locker Room	1145	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2437	Team Locker Room	1146A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2438	Team Locker Room	1146B	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2439	Custodial Closet by Girl's Locker Room	NA	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2440	Men's Bathroom	1166	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Smithtown High School East

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-2441	Men's Bathroom	1166	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2442	Women's Bathroom	1167	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2443	Room 158 And 160	1089	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2444	Room 164	1096	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2445	Room 164	1096	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2446	Women's Bathroom	1131	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2447	Women's Bathroom	1131	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2448	Men's Bathroom	1132	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2449	Men's Bathroom	1132	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2450	Women's Bathroom	1105	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2451	Main Cafeteria Closet	1124D	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2452	Faculty Male	2013	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2453	Faculty Male	2013	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2454	Faculty Female	2014	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2457	Boy's Bathroom	3012	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2458	Boy's Bathroom	3012	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2459	Girl's Bathroom	3013	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2460	Girl's Bathroom	3013	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2461	Women's Bathroom	3019B	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2462	Men's Bathroom	3019A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Smithtown High School East

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-2463	Men's Bathroom	3019A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2464	Women's Bathroom	3033	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2465	Women's Bathroom	3033	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2466	Men's Bathroom	3031	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2467	Women's Bathroom	3046C	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2468	Women's Bathroom	3046C	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2469	Women's Bathroom	3046C	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2470	Men's Bathroom	3046B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2471	Men's Bathroom	3046B	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2472	Men's Bathroom	3061	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2473	Men's Bathroom	3061	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2474	Women's Bathroom	3062	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2475	Men's Bathroom	2029	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2476	Women's Bathroom	2030	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2649	Kitchen	1040	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2956	Vestibule And Corridor Between Library And Little	1135	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2957	Kitchen	1040	Kitchen Faucet (Cold)	Applicable	12/13/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-2958	Room 143 Bathroom	1064A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3224	Corridor by Women's Faculty Bathroom	2031	Bottle Fill Station	Applicable	12/13/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-3225	Corridor by Women's Faculty Bathroom	2031	Water Cooler	Applicable	12/13/2025	<1.00 ND			Result Below Action Level Continue O&M

Smithtown High School East

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-3244	New Concession Area	N/A	Kitchen Faucet (Cold)	Applicable	12/13/2025	OOS			Testing Required Before Return to Service
SMTH-3245	New Concession Area	N/A	Kitchen Faucet (Cold)	Applicable	12/13/2025	OOS			Testing Required Before Return to Service
SMTH-3246	New Concession Custodial Closet	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3247	New Concession Men's Bathroom	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3248	New Concession Men's Bathroom	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3249	New Concession Men's Bathroom	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3250	New Concession Men's Bathroom	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3251	New Concession Women's Bathroom	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3252	New Concession Women's Bathroom	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3253	New Concession Women's Bathroom	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3254	New Concession Women's Bathroom	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3255	Concession/Storage	5001	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3256	Concession/Storage	5001	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3257	Exterior of Concession/Storage	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3258	Exterior of New Concession Area	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3312	Kitchen	1040	Spray Nozzle	Applicable	12/13/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-3343	Ice Machine Rooms	1139	Hose Bib	Applicable	12/13/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-3350	Room 149	1083	Home Economics Faucet (Cold)	Applicable	12/13/2025	18.5			Removed From Service, Pending Remediation
SMTH-3351	Room 149	1083	Home Economics Faucet (Cold)	Applicable	12/13/2025	6.6			Removed From Service, Pending Remediation
SMTH-3352	Room 149	1083	Home Economics Faucet (Cold)	Applicable	12/13/2025	2.7			Result Below Action Level Continue O&M

Smithtown High School East

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTM-3353	Room 149	1083	Home Economics Faucet (Cold)	Applicable	12/13/2025	3.9			Result Below Action Level Continue O&M
SMTM-3354	Room 151	1084	Home Economics Faucet (Cold)	Applicable	12/13/2025	2.4			Result Below Action Level Continue O&M
SMTM-3355	Room 151	1084	Home Economics Faucet (Cold)	Applicable	12/13/2025	1.9			Result Below Action Level Continue O&M
SMTM-3356	Room 151	1084	Home Economics Faucet (Cold)	Applicable	12/13/2025	6.9			Removed From Service, Pending Remediation

Barton Administration Building

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-1217	Women's Bathroom	3012	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1218	Women's Bathroom	3012	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1219	Women's Bathroom	3012	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1220	Custodial Closet Storage	3011A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1221	Men's Bathroom	3009A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1222	Men's Bathroom	3009A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1223	Men's Bathroom	3009A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1225	Closet	3008	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1227	Women's Bathroom	2012	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1228	Women's Bathroom	2012	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1229	Storage Room	2011	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1230	Men's Bathroom	2007	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1231	Men's Bathroom	2007	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1232	Assistant Superintendent's Office/Curriculum Sink Room	2006D	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1233	Superintendent's Office Conference Room Bathroom	2004A1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1234	Women's Bathroom	1016	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1235	Room 115 Printing Room	1025	Kitchen Faucet (Cold)	Applicable	12/11/2025	65.8			Removed From Service, Pending Remediation
SMTH-1236	Lounge off Lunch Room Bathroom	1032A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1237	Lounge off Lunch Room Bathroom	1032A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1238	Lunch Room	1033	Kitchen Faucet (Cold)	Applicable	12/11/2025	11.8			Removed From Service, Pending Remediation

Barton Administration Building

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-1241	Room 106 Custodial Closet	1007	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1242	Men's Bathroom	1009	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2377	Corridor (Security Office - Room 134)	1023	Bottle Fill Station	Applicable	12/11/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-2378	Corridor (Security Office - Room 134)	1023	Water Cooler	Applicable	12/11/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-2379	Corridor o/s Accounting Offices	3013	Bottle Fill Station	Applicable	12/11/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-2380	Corridor o/s Accounting Offices	3013	Water Cooler	Applicable	12/11/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-2892	Fan Room next to Room 106	1008	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2893	Men's Bathroom	1009	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2894	Women's Bathroom	1016	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2895	Boiler Room	0106	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2896	Corridor o/s Special Ed Suite	2014	Bottle Fill Station	Applicable	12/11/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-2897	Corridor o/s Special Ed Suite	2014	Water Cooler	Applicable	12/11/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-2898	Women's Bathroom	2012	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2940	Exterior o/s Security Camera Office	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2944	Exterior o/s Room 115 Printing Room	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

Dogwood Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-1276	Boiler Room	1021B	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1277	Boiler Room	1021B	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1278	Receiving/Storage Room Bathroom	1021B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1279	Receiving/Storage Room Closet	1021A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1280	Faculty Room	1025	Kitchen Faucet (Cold)	Applicable	12/5/2025	1.9			Result Below Action Level Continue O&M
SMTH-1281	Corridor by Boiler Room	1021B	Bottle Fill Station	Applicable	12/5/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-1282	Corridor by Boiler Room	1021B	Water Cooler	Applicable	12/5/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-1283	Room 18	1027C	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1284	Health Office	1028	Nurse's Office Sink	Applicable	12/5/2025	1.5			Result Below Action Level Continue O&M
SMTH-1285	Health Office Bathroom	1028D	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1286	Men's Bathroom	1031	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1287	Custodial Closet (13)	1032	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1288	Women's Bathroom Inner Room	1033A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1289	Women's Bathroom	1033	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1290	Speech Room (7)	1038	Kitchen Faucet (Cold)	Applicable	12/5/2025	9.4			Removed From Service, Pending Remediation
SMTH-1291	Room 5	1040	Water Fountain-No Chiller	Applicable	12/5/2025	OOS			Testing Required Before Return to Service
SMTH-1292	Room 5	1040	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1293	Room 3	1042	Water Fountain-No Chiller	Applicable	12/5/2025	OOS			Testing Required Before Return to Service
SMTH-1294	Room 3	1042	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1295	Room 1	1044	Water Fountain-No Chiller	Applicable	12/5/2025	OOS			Testing Required Before Return to Service

Dogwood Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTM-1296	Room 1	1044	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1297	Room 2	1043	Water Fountain-No Chiller	Applicable	12/5/2025	OOS			Testing Required Before Return to Service
SMTM-1298	Room 2	1043	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1299	Room 4	1041	Water Fountain-No Chiller	Applicable	12/5/2025	OOS			Testing Required Before Return to Service
SMTM-1300	Room 4	1041	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1301	Room 6	1039	Water Fountain-No Chiller	Applicable	12/5/2025	OOS			Testing Required Before Return to Service
SMTM-1302	Room 6	1039	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1303	Room 8	1037	Water Fountain-No Chiller	Applicable	12/5/2025	OOS			Testing Required Before Return to Service
SMTM-1304	Room 8	1037	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1305	Reading Room (14)	1030	Water Fountain-No Chiller	Applicable	12/5/2025	OOS			Testing Required Before Return to Service
SMTM-1306	Reading Room (14)	1030	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1307	Library Sink Room	1029A	Kitchen Faucet (Cold)	Applicable	12/5/2025	12.5			Removed From Service, Pending Remediation
SMTM-1308	Corridor by Room C	NA	Bottle Fill Station	Applicable	12/5/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTM-1309	Corridor by Room C	NA	Water Cooler	Applicable	12/5/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTM-1310	Room B	NA	Water Fountain-No Chiller	Applicable	12/5/2025	OOS			Testing Required Before Return to Service
SMTM-1311	Room B	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1312	Room B Bathroom	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1313	Art Storage Room	NA	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1314	Room C	NA	Water Fountain-No Chiller	Applicable	12/5/2025	OOS			Testing Required Before Return to Service
SMTM-1315	Room C	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Dogwood Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-1316	Room C Bathroom	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1317	Room D	NA	Water Fountain-No Chiller	Applicable	12/5/2025	OOS			Testing Required Before Return to Service
SMTH-1318	Room D	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1319	Room D Bathroom	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1320	Faculty Bathroom	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1321	Room A	NA	Water Fountain-No Chiller	Applicable	12/5/2025	OOS			Testing Required Before Return to Service
SMTH-1322	Room A	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1323	Room A Bathroom	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1324	Women Staff Bathroom	1016	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1325	Women Staff Bathroom	1016	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1326	Girls' Bathroom	1012	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1327	Girls' Bathroom	1012	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1328	Girls' Bathroom	1012	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1329	Corridor by Room 31	1013	Bottle Fill Station	Applicable	12/5/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-1330	Corridor by Room 31	1013	Water Cooler	Applicable	12/5/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-1331	Boys' Bathroom	1011	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1332	Boys' Bathroom	1011	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1333	Custodial Closet	1010	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1334	Kitchen	NA	Hand Wash Only	Applicable	12/5/2025	22.5			Placarded for Non-Drinking Use Until Remediated
SMTH-1335	Kitchen	NA	Hand Wash Only	Applicable	12/5/2025	32.9			Placarded for Non-Drinking Use Until Remediated

Dogwood Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-1336	Kitchen	NA	Spray Nozzle	Applicable	12/5/2025	4.0			Result Below Action Level Continue O&M
SMTH-1337	Kitchen	NA	Kitchen Faucet (Cold)	Applicable	12/5/2025	1.7			Result Below Action Level Continue O&M
SMTH-1338	Kitchen	NA	Kitchen Faucet (Cold)	Applicable	12/5/2025	3.6			Result Below Action Level Continue O&M
SMTH-1339	Custodial Closet	NA	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1340	Bathroom	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1341	Room 29	1008	Water Fountain-No Chiller	Applicable	12/5/2025	OOS			Testing Required Before Return to Service
SMTH-1342	Room 29	1008	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1343	Room 30	1007	Water Fountain-No Chiller	Applicable	12/5/2025	OOS			Testing Required Before Return to Service
SMTH-1344	Room 30	1007	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1345	Room 31	1006	Water Fountain-No Chiller	Applicable	12/5/2025	OOS			Testing Required Before Return to Service
SMTH-1346	Room 31	1006	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1347	Room 32	1004	Water Fountain-No Chiller	Applicable	12/5/2025	OOS			Testing Required Before Return to Service
SMTH-1348	Room 32	1004	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1349	Room 34	1002	Water Fountain-No Chiller	Applicable	12/5/2025	OOS			Testing Required Before Return to Service
SMTH-1350	Room 34	1002	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1351	Room 36	1000	Water Fountain-No Chiller	Applicable	12/5/2025	OOS			Testing Required Before Return to Service
SMTH-1352	Room 36	1000	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1353	Room 38	NA	Water Fountain-No Chiller	Applicable	12/5/2025	OOS			Testing Required Before Return to Service
SMTH-1354	Room 38	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1355	Bathroom	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Dogwood Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-1356	Bathroom	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1357	Room 40	NA	Water Fountain-No Chiller	Applicable	12/5/2025	OOS			Testing Required Before Return to Service
SMTH-1358	Room 40	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1359	Room 44	NA	Water Fountain-No Chiller	Applicable	12/5/2025	OOS			Testing Required Before Return to Service
SMTH-1360	Room 44	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1362	Room 46	NA	Water Fountain-No Chiller	Applicable	12/5/2025	OOS			Testing Required Before Return to Service
SMTH-1363	Room 46	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1364	Room 45	NA	Water Fountain-No Chiller	Applicable	12/5/2025	OOS			Testing Required Before Return to Service
SMTH-1365	Room 45	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1366	Room 43	NA	Water Fountain-No Chiller	Applicable	12/5/2025	1.7			Result Below Action Level Continue O&M
SMTH-1367	Room 43	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1368	Custodial Closet	NA	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1369	Room 41	NA	Water Fountain-No Chiller	Applicable	12/5/2025	OOS			Testing Required Before Return to Service
SMTH-1370	Room 41	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1371	Bathroom	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1372	Bathroom	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1373	Room 39	NA	Water Fountain-No Chiller	Applicable	12/5/2025	OOS			Testing Required Before Return to Service
SMTH-1374	Room 39	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1375	Room 37	1001	Water Fountain-No Chiller	Applicable	12/5/2025	OOS			Testing Required Before Return to Service
SMTH-1376	Room 37	1001	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Dogwood Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-1377	Room 35	1003	Water Fountain-No Chiller	Applicable	12/5/2025	OOS			Testing Required Before Return to Service
SMTH-1378	Room 35	1003	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1379	Room 33	1005	Water Fountain-No Chiller	Applicable	12/5/2025	OOS			Testing Required Before Return to Service
SMTH-1380	Room 33	1005	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3172	Bathroom	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3173	Bathroom	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3174	Bathroom	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3175	Bathroom	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3176	Room 44 Bathroom	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3177	Room 46 Bathroom	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3178	Room 43 Bathroom	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3179	Room 30	1007	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3180	Boys' Bathroom	1011	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3182	Girls' Bathroom	1012	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3183	Kitchen	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3184	Room 45 Bathroom	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3185	Exterior o/s Room 46	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3186	Exterior o/s Room 45	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3187	Exterior o/s Room 2	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-3188	Exterior o/s Room 2	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

Dogwood Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTM-3189	Exterior o/s Faculty Room	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3190	Exterior o/s Boiler Room	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

Nesaquake Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-1381	Room 503	5005	Home Economics Faucet (Cold)	Applicable	12/2/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-1382	Room 503	5005	Home Economics Faucet (Cold)	Applicable	12/2/2025	4.0			Result Below Action Level Continue O&M
SMTH-1383	Room 503	5005	Home Economics Faucet (Cold)	Applicable	12/2/2025	2.3			Result Below Action Level Continue O&M
SMTH-1384	Room 503	5005	Home Economics Faucet (Cold)	Applicable	12/2/2025	22.9			Removed From Service, Pending Remediation
SMTH-1385	Corridor 5012 o/s 5003	5012	Water Fountain-No Chiller	Applicable	12/2/2025	1.2			Result Below Action Level Continue O&M
SMTH-1386	Room 502	5004	Home Economics Faucet (Cold)	Applicable	12/2/2025	1.3			Result Below Action Level Continue O&M
SMTH-1387	Room 502	5004	Home Economics Faucet (Cold)	Applicable	12/2/2025	11.6			Removed From Service, Pending Remediation
SMTH-1388	Room 502	5004	Home Economics Faucet (Cold)	Applicable	12/2/2025	3.0			Result Below Action Level Continue O&M
SMTH-1389	Room 502	5004	Home Economics Faucet (Cold)	Applicable	12/2/2025	2.3			Result Below Action Level Continue O&M
SMTH-1390	Room 504	5003	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1391	WOMENS BATHROOM	5010	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1392	WOMENS BATHROOM	5010	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1393	Room 555N Office	Corridor 5012 o/s	Water Fountain-No Chiller	RFI	12/2/2025	OOS			Outlet Permanently Removed
SMTH-1394	MENS BATHROOM	5009	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1395	Faculty Lounge	5011H	Kitchen Faucet (Cold)	Applicable	12/2/2025	1.5			Result Below Action Level Continue O&M
SMTH-1396	Room 310 Rear Shop	3019B	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1397	Corridor 3030 o/s 3020	3030	Water Fountain-No Chiller	Applicable	12/2/2025	OOS			Testing Required Before Return to Service
SMTH-1398	Room 309 Rear Shop	3020A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1399	Room 308 Art	3023	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1400	Room 308 Art	3023	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Nesaquake Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-1401	Room 308 Art	3023	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1402	Room 312F Faculty Bathroom	3025	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1403	Corridor 3030 o/s 3027	3030	Bottle Fill Station	Applicable	12/2/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-1404	Corridor 3030 o/s 3027	3030	Water Cooler	Applicable	12/2/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-1405	Room 307 Art	3028	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1406	Room 307 Art	3028	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1407	Room 307 Art	3028	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1408	Corridor 4001 o/s 4003	4001	Water Fountain-No Chiller	Applicable	12/2/2025	5.8			Removed From Service, Pending Remediation
SMTH-1409	BOYS BATHROOM	4003	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1410	BOYS BATHROOM	4003	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1411	GIRLS BATHROOM	4026	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1412	GIRLS BATHROOM	4026	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1413	Custodial Closet	4015	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1414	Corridor 3006 o/s 3008	3006	Bottle Fill Station	Applicable	12/2/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-1415	Corridor 3006 o/s 3008	3006	Water Cooler	Applicable	12/2/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-1416	Library Office/Kitchen	3009	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1417	Room 300 Greenhouse	3000A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1418	Room 300	3000	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1419	Room 300	3000	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1420	Room 300	3000	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

Nesaquake Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTM-1421	Room 300	3000	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1422	Room 300	3000	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1423	Room 300	3000	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1424	Room 300	3000	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1425	Room 300	3000	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1426	Room 300	3000	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1427	Room 300	3000	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1428	Room 300	3000	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1429	Room 300	3000	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1430	Room 301	3001	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1431	Room 301	3001	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1432	Room 301	3001	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1433	Room 301	3001	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1434	Room 301	3001	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1435	Room 301	3001	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1436	Room 301	3001	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1437	Room 301	3001	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1438	Room 301	3001	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1439	Room 301	3001	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1440	Room 301	3001	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

Nesaquake Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTM-1441	Room 301	3001	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1442	Room 301 Back Hallway	3001B	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1443	Room 301 Prep Room	3001A	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1444	Room 302 Rear Hallway	3002B	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1445	Room 302	3002	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1446	Room 302	3002	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1447	Room 302	3002	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1448	Room 302	3002	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1449	Room 302	3002	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1450	Room 302	3002	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1451	Room 302	3002	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1452	Room 302	3002	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1453	Room 302	3002	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1454	Room 302	3002	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1455	Room 302	3002	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1456	Room 302	3002	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1457	Room 303 Prep Room	3003B	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1458	Room 303 Prep Room	3003B	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1459	Room 303	3003	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-1460	Room 303	3003	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

Nesaquake Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-1461	Room 303	3003	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1462	Room 303	3003	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1463	Room 303	3003	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1464	Room 303	3003	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1465	Room 303	3003	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1466	Room 303	3003	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1467	Room 303	3003	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1468	Room 303	3003	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1469	Room 303	3003	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1470	Room 303	3003	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1471	Room 304 Rear Hallway	3004B	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1472	Room 304	3004	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1473	Room 304	3004	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1474	Room 304	3004	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1475	Room 304	3004	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1476	Room 304	3004	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1477	Room 304	3004	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1478	Room 304	3004	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1479	Room 304	3004	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1480	Room 304	3004	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

Nesaquake Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-1481	Room 304	3004	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1482	Room 304	3004	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1483	Room 304	3004	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1484	Room 305 Rear Hallway	3005B	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1485	Room 305	3005	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1486	Room 305	3005	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1487	Room 305	3005	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1488	Room 305	3005	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1489	Room 305	3005	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1490	Room 305	3005	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1491	Room 305	3005	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1492	Room 305	3005	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1493	Room 305	3005	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1494	Room 305	3005	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1495	Room 305	3005	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1496	Room 305	3005	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1497	Room 317 Attendance Office	3014A	Nurse's Office Sink	Applicable	12/2/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-1498	NURSES OFFICE	3014A	Nurse's Office Sink	Applicable	12/2/2025	1.8			Result Below Action Level Continue O&M
SMTH-1499	Room 318	3012	Kitchen Faucet (Cold)	Applicable	12/2/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-1500	Corridor 1023 o/s 1040	1023	Bottle Fill Station	Applicable	12/2/2025	<1.00 ND			Result Below Action Level Continue O&M

Nesaquake Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-1501	Corridor 1023 o/s 1040	1023	Water Cooler	Applicable	12/2/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-1502	Room 200D Custodial	1040	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1503	BOYS BATHROOM	1044	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1504	BOYS BATHROOM	1044	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1505	BOYS BATHROOM	1044	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1506	GIRLS BATHROOM	1026	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1507	GIRLS BATHROOM	1026	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1510	Room 102 Instrument Storage	1021	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1511	Women's Faculty Bathroom	1017	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1512	Men's Faculty Bathroom	1016	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1513	BOYS LOCKER ROOM	1002	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1514	BOYS LOCKER ROOM	1002	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1515	Boys' Locker Room Coach's Office Bathroom	1002A1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1516	Corridor 1005 o/s 1002D	1005	Bottle Fill Station	Applicable	12/2/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-1517	Corridor 1005 o/s 1002D	1005	Water Cooler	Applicable	12/2/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-1519	GIRLS LOCKER ROOM	1001	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1520	GIRLS LOCKER ROOM	1001	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1521	Girls' Locker Room Coach's Office Bathroom	1001A1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1522	KITCHEN	1021	Hand Wash Only	Applicable	12/2/2025	2.3			Result Below Action Level Continue O&M
SMTH-1523	KITCHEN	1020	Hand Wash Only	Applicable	12/2/2025	9.0			Further Investigation Determined Outlet Use to be Non-Applicable. Placarded for Non-Drinking Use

Nesaquake Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-1524	KITCHEN	1020	Kitchen Faucet (Cold)	Applicable	12/2/2025	13.1	12/31/2025	1.4	Outlet Remediated and Returned to Service, Continue O&M
SMTH-1525	KITCHEN	1020	Kitchen Faucet (Cold)	Applicable	12/2/2025	2.9			Result Below Action Level Continue O&M
SMTH-1526	KITCHEN	1020	Hand Wash Only	Applicable	12/2/2025	1.3			Result Below Action Level Continue O&M
SMTH-1527	KITCHEN	1020	Kitchen Faucet (Cold)	Applicable	12/2/2025	6.1	12/31/2025	< 1.0	Outlet Remediated and Returned to Service, Continue O&M
SMTH-1528	KITCHEN	1020	Spray Nozzle	Applicable	12/2/2025	1.6	12/31/2025	< 1.0	Result Below Action Level Continue O&M
SMTH-1529	Custodial Closet in New Addition Near Gym (#1000)	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1530	Corridor 1005 o/s Gym	1005	Bottle Fill Station	Applicable	12/2/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-1531	Corridor 1005 o/s Gym	1005	Water Cooler	Applicable	12/2/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-1532	BATHROOM	New Addition	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1533	GIRLS LOCKER ROOM	1001	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1534	GIRLS LOCKER ROOM	1001	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-1535	GIRLS LOCKER ROOM	1001	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2342	Custodial Closet	1015	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2343	Custodial Closet	1013	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2815	Exterior o/s New Gym	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2816	Exterior o/s New Band Room	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2817	Fan Room Above Gym Closets	1000C1	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2818	Fan Room Above Gym Closets	1000C1	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2819	Girls' Locker Room	1001	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2820	Girls' Locker Room	1001	Shower Head	Non-Applicable					Placarded for Non-Drinking Use

Nesaquake Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-2821	Girls' Locker Room	1001	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2822	Girls' Locker Room	1001	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2823	Girls' Locker Room	1001	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2824	Girls' Locker Room	1001	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2825	Girls' Locker Room	1001	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2826	Girls' Locker Room	1001	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2827	Girls' Locker Room	1001	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2828	Girls' Locker Room	1001	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2829	Girls' Locker Room	1001	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2830	Girls' Locker Room	1001	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2831	Girls' Locker Room	1001	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2832	Girls' Locker Room	1001	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2833	Girls' Locker Room	1001	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2834	Girls' Locker Room	1001	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2835	Girls' Locker Room	1001	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2836	Girls' Locker Room	1001	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2837	Girls' Locker Room	1001	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2838	Girls' Locker Room	1001	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2839	Girls' Locker Room	1001	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2840	Girls' Locker Room	1001	Shower Head	Non-Applicable					Placarded for Non-Drinking Use

Nesaquake Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-2841	Girls' Locker Room	1001	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2842	Girls' Locker Room	1001	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2843	Girls' Locker Room	1001	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2844	Girls' Locker Room	1001	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2845	Girls' Locker Room Coach Office Bathroom	1001A1	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2846	Boys' Locker Room	1002	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2847	Boys' Locker Room	1002	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2848	Boys' Locker Room	1002	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2849	Boys' Locker Room	1002	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2850	Boys' Locker Room	1002	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2851	Boys' Locker Room	1002	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2852	Boys' Locker Room	1002	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2853	Boys' Locker Room	1002	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2854	Boys' Locker Room	1002	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2855	Boys' Locker Room	1002	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2856	Boys' Locker Room	1002	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2857	Boys' Locker Room Coach's Office Bathroom	1002A1	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2858	Boiler Room	0001	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2859	Boiler Room	0001	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2860	Boiler Room	0001	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

Nesaquake Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-2861	Boiler Room	0001	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2862	Boiler Room	0001	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2863	Boiler Room	0001	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2864	Room 109 HVAC	1008	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2865	Room 109 HVAC	1008	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2866	Room 109 HVAC	1008	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2867	Room 109 HVAC	1008	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2868	Room 109 HVAC	1008	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2869	Room 108A Incinerator Room	1011	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2870	Room 108A Incinerator Room	1011	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2871	Kitchen Office	1020B	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2872	Room 301 Back Hallway	3001B	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2873	Room 303 Rear Hallway	3003A	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2874	Room 303 Prep Room	3003B	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2875	Room 502	5004	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2876	Room 502	5004	Dish Washer	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2877	Room 502 Kitchenette	5004A	Washing Machine	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2878	Room 502 Kitchenette	5004A	Washing Machine	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2879	Room 503	5005	Dish Washer	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2880	Room 508 Faculty Men's Bathroom	5009	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

Nesaquake Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-2881	Room 509 Faculty Women's Bathroom	5010	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2882	Room 401B Bathroom	4003	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2883	Room 414A Girl's Bathroom	4026	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2884	Exterior o/s Gym	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

Branch Brook Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-2001	Room 38	1049	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2002	Room 37	1050	Water Fountain-No Chiller	Applicable	11/26/2025	OOS			Testing Required Before Return to Service
SMTH-2003	Room 37	1050	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2004	Room 36	1047	Water Fountain-No Chiller	Applicable	11/26/2025	OOS			Testing Required Before Return to Service
SMTH-2005	Room 36	1047	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2006	Room 35	1048	Water Fountain-No Chiller	Applicable	11/26/2025	OOS			Testing Required Before Return to Service
SMTH-2007	Room 35	1048	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2008	Room 33	1046	Water Fountain-No Chiller	Applicable	11/26/2025	OOS			Testing Required Before Return to Service
SMTH-2009	Room 33	1046	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2010	Room 34	1045	Water Fountain-No Chiller	Applicable	11/26/2025	OOS			Testing Required Before Return to Service
SMTH-2011	Room 34	1045	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2012	Women's Bathroom	1037	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2013	Women's Bathroom	1037	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2014	Women's Bathroom	1037	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2015	Room 32	1043	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2016	Room 32	1043	Water Fountain-No Chiller	Applicable	11/26/2025	OOS			Testing Required Before Return to Service
SMTH-2017	Men's Bathroom	1038	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2018	Men's Bathroom	1038	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2019	Men's Bathroom	1038	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2020	Custodial Closet	1039	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use

Branch Brook Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-2021	Room 31	1042	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2022	Room 31	1042	Water Fountain-No Chiller	Applicable	11/26/2025	OOS			Testing Required Before Return to Service
SMTH-2023	Room 30	1041	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2024	Room 30	1041	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2025	Room 30	1041	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2026	KITCHEN	NA	Kitchen Faucet (Cold)	Applicable	11/26/2025	95.3			Removed From Service, Pending Remediation
SMTH-2027	KITCHEN	NA	Hand Wash Only	Applicable	11/26/2025	16.3			Placarded for Non-Drinking Use Until Remediated
SMTH-2028	KITCHEN	NA	Kitchen Faucet (Cold)	Applicable	11/26/2025	OOS			Testing Required Before Return to Service
SMTH-2029	KITCHEN	NA	Kitchen Faucet (Cold)	Applicable	11/26/2025	OOS			Testing Required Before Return to Service
SMTH-2030	Custodial Closet in Cafeteria	NA	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2031	Bathroom Near Cafeteria	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2032	Boiler Room Receiving Bathroom	1027A1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2033	Boiler Room Receiving	1027A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2034	Ladies' Bathroom	1025	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2035	Ladies' Bathroom	1025	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2036	Lobby/Entrance	1024	Bottle Fill Station	Applicable	11/26/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-2037	Lobby/Entrance	1024	Water Cooler	Applicable	11/26/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-2038	Ladies' Bathroom	1034	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2039	Ladies' Bathroom	1034	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2040	Library Kitchenette	1020	Kitchen Faucet (Cold)	Non-Applicable					Placarded for Non-Drinking Use

Branch Brook Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-2041	Main Office Mail Room	1021A	Kitchen Faucet (Cold)	Applicable	11/26/2025	46.1			Removed From Service, Pending Remediation
SMTH-2042	Men's Room	1018	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2043	Custodial Closet	1017	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2044	Nurse's Office Bathroom	1015D	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2046	Room 16	1016	Water Fountain-No Chiller	Applicable	11/26/2025	OOS			Testing Required Before Return to Service
SMTH-2047	Room 16	1016	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2048	Room 8	1007	Water Fountain-No Chiller	Applicable	11/26/2025	OOS			Testing Required Before Return to Service
SMTH-2049	Room 8	1007	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2050	Faculty Room 7	1006	Kitchen Faucet (Cold)	Applicable	11/26/2025	7.6			Removed From Service, Pending Remediation
SMTH-2051	Room 11	1012	Water Fountain-No Chiller	Applicable	11/26/2025	OOS			Testing Required Before Return to Service
SMTH-2052	Room 11	1012	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2053	Room 11	1012	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2054	Room 12	1013	Water Fountain-No Chiller	Applicable	11/26/2025	OOS			Testing Required Before Return to Service
SMTH-2055	Room 12	1013	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2056	Corridor by Room 12A	NA	Water Cooler	Applicable	11/26/2025	1.1			Result Below Action Level Continue O&M
SMTH-2057	Corridor by Room 12A	NA	Water Cooler	Applicable	11/26/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-2058	Room 12A	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2059	Room 12A	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2060	Room 5	1004	Water Fountain-No Chiller	Applicable	11/26/2025	OOS			Testing Required Before Return to Service
SMTH-2061	Room 5	1004	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service RFI = Removed from Inventory

Branch Brook Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-2062	Room 6	1005	Water Fountain-No Chiller	Applicable	11/26/2025	OOS			Testing Required Before Return to Service
SMTH-2063	Room 6	1005	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2064	Room 4	1003	Water Fountain-No Chiller	Applicable	11/26/2025	OOS			Testing Required Before Return to Service
SMTH-2065	Room 4	1003	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2066	Room 3	1002	Water Fountain-No Chiller	Applicable	11/26/2025	OOS			Testing Required Before Return to Service
SMTH-2067	Room 3	1002	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2068	Room 1	1000	Water Fountain-No Chiller	Applicable	11/26/2025	OOS			Testing Required Before Return to Service
SMTH-2069	Room 1	1000	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2070	Room 2	1001	Water Fountain-No Chiller	Applicable	11/26/2025	OOS			Testing Required Before Return to Service
SMTH-2071	Room 2	1001	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2072	Class Adjacent to Room 1	NA	Water Fountain-No Chiller	Applicable	11/26/2025	OOS			Testing Required Before Return to Service
SMTH-2073	Class Adjacent to Room 1	NA	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2074	Room 4A	NA	Water Fountain-No Chiller	Applicable	11/26/2025	OOS			Testing Required Before Return to Service
SMTH-2075	Room 4A	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2076	Class Two Doors From Room 1	NA	Water Fountain-No Chiller	Applicable	11/26/2025	OOS			Testing Required Before Return to Service
SMTH-2077	Class Two Doors From Room 1	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2078	Class Two Doors From Room 2	NA	Water Fountain-No Chiller	Applicable	11/26/2025	OOS			Testing Required Before Return to Service
SMTH-2079	Class Two Doors From Room 2	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2775	Room 12A Bathroom	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2776	Custodial Closet by Room 12A	NA	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use

Branch Brook Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTM-2778	Boiler Room Receiving	1027A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2779	Boiler Room Receiving	1027A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2780	Boiler Room Receiving	1027A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2781	Kitchen	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2782	Ladies Bathroom	1034	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2783	Women's Bathroom	1037	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2784	Men's Bathroom	1038	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2785	Room 38	1049	Water Fountain-No Chiller	Applicable	11/26/2025	OOS			Testing Required Before Return to Service
SMTM-2786	Exterior o/s Room 12A	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2787	Exterior o/s Room 12A	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2788	Exterior o/s New Addition	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2789	Exterior o/s Room 38	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2790	Exterior o/s Room 30	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3327	Room 12	1013	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Nesconset Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-2151	Kitchen	1028	Spray Nozzle	Applicable	12/5/2025	311			Placarded for Non-Drinking Use Until Remediated
SMTH-2152	Kitchen	1028	Kitchen Faucet (Cold)	Applicable	12/5/2025	156			Removed From Service, Pending Remediation
SMTH-2153	Kitchen	1028	Kitchen Faucet (Cold)	Applicable	12/5/2025	116			Removed From Service, Pending Remediation
SMTH-2154	Kitchen	1028	Kitchen Faucet (Cold)	Applicable	12/5/2025	3.9			Result Below Action Level Continue O&M
SMTH-2155	Faculty Bathroom	1037	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2156	Corridor by Gym	1038	Water Cooler	Applicable	12/5/2025	74.6			Removed From Service, Pending Remediation
SMTH-2157	Room 10	1045	Water Fountain-No Chiller	Applicable	12/5/2025	OOS			Testing Required Before Return to Service
SMTH-2158	Room 10	1045	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2159	Room 8	1046	Water Fountain-No Chiller	Applicable	12/5/2025	OOS			Testing Required Before Return to Service
SMTH-2160	Room 8	1046	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2161	Room 6	1048	Water Fountain-No Chiller	Applicable	12/5/2025	OOS			Testing Required Before Return to Service
SMTH-2162	Room 6	1048	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2163	Girls' Bathroom	1050	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2164	Girls' Bathroom	1050	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2165	Girls' Bathroom	1050	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2166	Boys' Bathroom	1052	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2167	Boys' Bathroom	1052	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2168	Boys' Bathroom	1052	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2169	Room 4	1059	Water Fountain-No Chiller	Applicable	12/5/2025	OOS			Testing Required Before Return to Service
SMTH-2170	Room 4	1059	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Nesconset Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-2171	Room 2	1058	Water Fountain-No Chiller	Applicable	12/5/2025	OOS			Testing Required Before Return to Service
SMTH-2172	Room 2	1058	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2173	Room 1A	1057	Water Fountain-No Chiller	Applicable	12/5/2025	OOS			Testing Required Before Return to Service
SMTH-2174	Room 1A	1057	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2175	Room 1	1056	Water Fountain-No Chiller	Applicable	12/5/2025	OOS			Testing Required Before Return to Service
SMTH-2176	Room 1 Bathroom	1056C	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2177	Room 1 Bathroom	1056C	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2178	Principal's Office Bathroom	1055A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2179	Main Office Bathroom	1049A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2180	Room 7	1047	Water Fountain-No Chiller	Applicable	12/5/2025	OOS			Testing Required Before Return to Service
SMTH-2181	Room 7	1047	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2182	Custodial Office Bathroom	1043A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2183	Faculty Room	1025	Kitchen Faucet (Cold)	Applicable	12/10/2025	5.1			Removed From Service, Pending Remediation
SMTH-2184	Girls' Bathroom	1021	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2185	Girls' Bathroom	1021	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2186	Boys' Bathroom	1018	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2187	Boys' Bathroom	1018	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2188	Room 30	1005	Water Fountain-No Chiller	Applicable	12/5/2025	OOS			Testing Required Before Return to Service
SMTH-2189	Room 30	1005	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2190	Room 29	1003	Water Fountain-No Chiller	Applicable	12/5/2025	OOS			Testing Required Before Return to Service

Nesconset Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-2191	Room 29	1003	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2192	Room 28	1000	Water Fountain-No Chiller	Applicable	12/5/2025	OOS			Testing Required Before Return to Service
SMTH-2193	Room 28	1000	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2194	North Portable	NA	Water Fountain-No Chiller	Applicable	12/5/2025	OOS			Testing Required Before Return to Service
SMTH-2195	North Portable	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2196	Room 27	1015	Water Fountain-No Chiller	Applicable	12/5/2025	OOS			Testing Required Before Return to Service
SMTH-2197	Room 27	1015	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2198	Room 26	1013	Water Fountain-No Chiller	Applicable	12/5/2025	OOS			Testing Required Before Return to Service
SMTH-2199	Room 26	1013	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2200	Room 25	1010	Water Fountain-No Chiller	Applicable	12/5/2025	OOS			Testing Required Before Return to Service
SMTH-2201	Room 25	1010	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2203	Room 17	1019	Hand Wash Only	Applicable	12/5/2025	21.7			Placarded for Non-Drinking Use Until Remediated
SMTH-2204	Faculty Bathroom	1020	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2205	Women's Bathroom	1022	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2206	Classroom Adjacent to Room 25	NA	Water Fountain-No Chiller	Applicable	12/5/2025	8.5			Removed From Service, Pending Remediation
SMTH-2207	Classroom Adjacent to Room 25	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2208	Classroom Adjacent to Room 26	NA	Water Fountain-No Chiller	Applicable	12/5/2025	OOS			Testing Required Before Return to Service
SMTH-2209	Classroom Adjacent to Room 26	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2210	Corridor by New Gym Entrance	NA	Water Fountain-No Chiller	Applicable	12/5/2025	8.4			Removed From Service, Pending Remediation
SMTH-2211	Corridor Around Corner from New Gym	NA	Water Cooler	Applicable	12/5/2025	1.4			Result Below Action Level Continue O&M

Nesconset Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-2212	Boys' Bathroom by New Gym	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2213	Girls' Bathroom by New Gym	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2214	Men's Bathroom by New Gym	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2215	Women's Bathroom by New Gym	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2216	Art Room	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2217	Art Room	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2218	Art Room	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2219	Classroom Adjacent to Room 36	NA	Water Fountain-No Chiller	Applicable	12/5/2025	OOS			Testing Required Before Return to Service
SMTH-2220	Classroom Adjacent to Room 36	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2221	Room 35	1076	Water Fountain-No Chiller	Applicable	12/5/2025	OOS			Testing Required Before Return to Service
SMTH-2222	Room 35	1076	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2223	Room 34	1074	Water Fountain-No Chiller	Applicable	12/5/2025	OOS			Testing Required Before Return to Service
SMTH-2224	Room 34	1074	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2225	CLASSROOM 42	NA	Water Fountain-No Chiller	Applicable	12/5/2025	OOS			Testing Required Before Return to Service
SMTH-2226	CLASSROOM 42	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2227	CLASSROOM 43	NA	Water Fountain-No Chiller	Applicable	12/5/2025	OOS			Testing Required Before Return to Service
SMTH-2228	CLASSROOM 43	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2229	CLASSROOM 45	NA	Water Fountain-No Chiller	Applicable	12/5/2025	OOS			Testing Required Before Return to Service
SMTH-2230	CLASSROOM 45	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2231	CLASSROOM 44	NA	Water Fountain-No Chiller	Applicable	12/5/2025	6.5			Removed From Service, Pending Remediation

Nesconset Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTM-2232	CLASSROOM 44	NA	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2233	Room 31	1062	Water Fountain-No Chiller	Applicable	12/5/2025	OOS			Testing Required Before Return to Service
SMTM-2234	Room 31	1062	Nurse's Office Sink	Applicable	12/5/2025	84.9			Removed From Service, Pending Remediation
SMTM-2235	Room 31 Bathroom	1062B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2236	Boys' Bathroom	1069	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2237	Boys' Bathroom	1069	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2238	Girls' Bathroom	1071	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2239	Girls' Bathroom	1071	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2240	Room 37	1073	Water Fountain-No Chiller	Applicable	12/5/2025	239			Removed From Service, Pending Remediation
SMTM-2241	Room 37	1073	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2242	Room 36	1075	Water Fountain-No Chiller	Applicable	12/5/2025	OOS			Testing Required Before Return to Service
SMTM-2243	Room 36	1075	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2281	Custodial Closet 22	1027	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2282	Gym Storage	1029A	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2284	Custodial Closet	1051	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2285	Custodial Closet	1051	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2286	Boiler Room	1044	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2398	South Portable	NA	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2399	Corridor Closet	1014	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2400	Custodial Closet	1051	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

Nesconset Elementary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTM-2713	Boys Bathroom	1069	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2714	Custodial Closet	1070	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2715	Girls Bathroom	1071	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2716	Custodial Closet by New Gym	NA	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2717	Men's Bathroom by New Gym	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2718	East Courtyard	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2719	West Courtyard	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2720	Exterior o/s Room 30	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2721	Exterior o/s Room 45	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2722	Exterior o/s Office 31B	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2723	Exterior o/s Room 2	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2724	Exterior o/s Room 1	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2725	Exterior o/s Room 7	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2726	Exterior o/s Room 19	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

Commissary Warehouse

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-2244	Main Warehouse Area Locker Room	1002	Kitchen Faucet (Cold)	Applicable	11/26/2025	2.5			Result Below Action Level Continue O&M
SMTH-2245	Main Warehouse Area Locker Room Bathroom	1002A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2246	Kitchen Women's Bathroom	1011	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2247	Kitchen	1012	Hand Wash Only	Applicable	11/26/2025	5.1	12/31/2025	6.0	Further Investigation Determined Outlet Use to be Non-Applicable. Placarded for Non-Drinking Use
SMTH-2248	Kitchen	1012	Hand Wash Only	Applicable	11/26/2025	5.0			Result Below Action Level Continue O&M
SMTH-2249	Kitchen	1012	Kitchen Faucet (Cold)	Applicable	11/26/2025	9.3	12/31/2025	2.3	Outlet Remediated and Returned to Service, Continue O&M
SMTH-2250	Kitchen	1012	Kitchen Faucet (Cold)	Applicable	11/26/2025	12.5	12/31/2025	1.2	Outlet Remediated and Returned to Service, Continue O&M
SMTH-2252	Kitchen	1012	Kitchen Faucet (Cold)	Applicable	11/26/2025	9.4	12/31/2025	< 1.0	Outlet Remediated and Returned to Service, Continue O&M
SMTH-2253	Kitchen School Lunch Office	1013	Kitchen Faucet (Cold)	Applicable	11/26/2025	6.8	12/31/2025	1.9	Outlet Remediated and Returned to Service, Continue O&M
SMTH-2254	Main Warehouse Area Bathroom	1005	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2385	Main Warehouse Area Custodial Closet	1006	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2386	Main Warehouse Area Office	1001	Bottle Fill Station (Hot)	Applicable	11/26/2025	OOS			Testing Required Before Return to Service
SMTH-2387	Main Warehouse Area Office	1001	Bottle Fill Station (Cold)	Applicable	11/26/2025	OOS			Testing Required Before Return to Service
SMTH-2388	Kitchen	1012	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2389	Kitchen	1012	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2390	Kitchen	1012	Hand Wash Only	Applicable	11/26/2025	43.9	12/31/2025	139	Further Investigation Determined Outlet Use to be Non-Applicable. Placarded for Non-Drinking Use
SMTH-2391	Kitchen	1012	Pasta Pot/Steam Kettle	Applicable	11/26/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTH-2392	Kitchen	1012	Pasta Pot/Steam Kettle	Applicable	11/26/2025	3.3			Result Below Action Level Continue O&M
SMTH-2393	Kitchen	1012	Pasta Pot/Steam Kettle	Applicable	11/26/2025	2.0			Result Below Action Level Continue O&M
SMTH-2394	Kitchen	1012	Pasta Pot/Steam Kettle	Applicable	11/26/2025	OOS			Testing Required Before Return to Service

Commissary Warehouse

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTM-2395	Kitchen	1012	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2712	Main Warehouse Area	1000	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-3278	Corridor (Warehouse-Kitchen Area)	1009	Bottle Fill Station	Applicable	11/26/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTM-3279	Corridor (Warehouse-Kitchen Area)	1009	Water Cooler	Applicable	11/26/2025	<1.00 ND			Result Below Action Level Continue O&M
SMTM-3299	Kitchen School Lunch Office	1013	Bottled Water Dispenser	Applicable	11/26/2025	<1.00 ND			Result Below Action Level Continue O&M

Little Red School House

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTM-2257	Corridor	1003	Water Fountain-No Chiller	Applicable	11/26/2025	OOS			Testing Required Before Return to Service
SMTM-2258	Men's Room	1001	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2259	Ladies' Room	1002	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2260	Bathroom	0002	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2261	Main Basement	0001	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2262	Main Basement	0001	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2287	Classroom	1004	Water Fountain-No Chiller	Applicable	11/26/2025	OOS			Testing Required Before Return to Service
SMTM-2288	Classroom	1004	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Facilities and Transportation

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTH-2263	Equipment Room Bathroom	B&G1000 B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2264	Equipment Room	B&G1000	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2265	Trailer Garage	B&G1005	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2266	Corridor	B&G1003	Water Cooler	Applicable	12/2/2025	OOS			Testing Required Before Return to Service
SMTH-2267	Men's Bathroom	B&G1003 A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2268	Women's Bathroom	B&G1003 B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2269	Kitchen	1003	Kitchen Faucet (Cold)	Applicable	12/2/2025	1.4			Result Below Action Level Continue O&M
SMTH-2270	Kitchen Ladies Bathroom	1003A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2271	Kitchenette	1009	Kitchen Faucet (Cold)	Applicable	12/2/2025	3.0			Result Below Action Level Continue O&M
SMTH-2272	Women's Bathroom	2010A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2273	Men's Bathroom	2003	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2274	Corridor Closet	2004	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2275	Corridor	B&G1003	Bottle Fill Station	Applicable	12/2/2025	11.0			Removed From Service, Pending Remediation
SMTH-2945	Men's Bathroom	2003	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2946	Men's Bathroom	2003	Shower Head	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2947	Women's Bathroom	2010A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2948	Trailer Garage	B&G1005	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2949	Trailer Garage	B&G1005	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2950	Exterior o/s B&G Trailer Garage	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTH-2951	Exterior o/s B&G Equipment Room	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

Facilities and Transportation

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTM-2952	Exterior o/s B&G Equipment Room	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2953	Exterior o/s Mail Room	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2954	Exterior o/s Mail Room	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2955	Exterior o/s Conference Room	NA	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

Arthur House

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/Non-Applicable/RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
SMTM-2886	Basement Main Area	0001	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2887	Basement Main Area	0001	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2888	Basement Main Area	0001	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2889	Kitchen	1002	Kitchen Faucet (Cold)	Applicable	11/26/2025	OOS			Testing Required Before Return to Service
SMTM-2890	Bathroom	1004	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
SMTM-2891	Vestibule South Bathroom	2002A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Attachment 3:

Laboratory Analytical Reports



J.C. Broderick & Associates, Inc.
Environmental Consulting & Testing
1775 Expressway Drive North
Hauppauge, New York 11788
631.584.5492 fax 631.584.3395



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

ED57607

JCB #:

23-54650

Building: Accomset Elementary School

ACE

Client:

Smithtown Central School District

Retest/New Install

Turn Around: Normal 1 wk Rush _____

Courier

Sample ID	Functional Space Type	AHERA ID	Common Room Name	RECEIVED BY EMSL ANALYTICAL, INC.	Outlet Type Carryover REC'D 12/3/25	Sample Date	Sample Time
SMTH-0050	KI	NA	KITCHEN		KC	12/3/2025	6:10:00 AM
SMTH-0051	KI	NA	KITCHEN		KC	12/3/2025	6:11:00 AM
SMTH-0052	KI	NA	KITCHEN		KC	12/3/2025	6:11:00 AM
SMTH-0053	KI	NA	KITCHEN		KC	12/3/2025	6:12:00 AM
SMTH-0054	KI	NA	KITCHEN		SN	12/3/2025	6:12:00 AM
SMTH-0055	FL	NA	FACULTY ROOM		KC	12/3/2025	6:15:00 AM
SMTH-0066	NO	1037	NURSING OFFICE		KC	12/3/2025	6:16:00 AM
SMTH-0073	OF	1040	Psychologist Office		KC	12/3/2025	6:20:00 AM
SMTH-0098	HA	NA	o/s CLASSROOM 14		WF	12/3/2025	6:47:00 AM
SMTH-0099	HA	NA	o/s CLASSROOM 14		WC	12/3/2025	6:48:00 AM
SMTH-0101	HA	NA	Hallway O/S 62		WF	12/3/2025	6:50:00 AM
SMTH-0102	HA	NA	Hallway O/S 62		WC	12/3/2025	6:51:00 AM
SMTH-0103	OF	NA	MAIN OFFICE		KC	12/3/2025	7:02:00 AM
SMTH-1992	HA	1026	Corridor o/s 1032		WC	12/3/2025	5:43:00 AM
SMTH-1993	HA	1026	Corridor o/s 1031		WF	12/3/2025	5:43:00 AM
SMTH-2382	HA	N/A	Corridor by Room 58		WC	12/3/2025	5:47:00 AM
SMTH-2383	HA	N/A	Corridor by Room 58		WF	12/3/2025	5:47:00 AM
SMTH-3276	HA	1020	Corridor (Room 30-Room 45)		WF	12/3/2025	6:26:00 AM

Building Address

1 Lincoln Street

Smithtown, NY 11787

12/10/25
12/11/25

Analysis Type: ELAP 200.5

Lab Received: DAVID WHARTON 12/10/25

Signature: David Wharton

Samplers Name: Wilson Zheng

Samplers Signature: 

JCB Project Manager: Bryan Tedesco



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

ED57607

Page 2 of 2

JCB #:

23-54650

Building: Accompeſt Elementary School

ACE

Client:

Smithtown Central School District

Retest/New Install

Turn Around: Normal 1 wk Rush _____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
SMTH-3277	HA	1020	Corridor (Room 30-Room 45)	WC	12/3/2025	6:26:00 AM

Samples Submitted 19

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
DEC 10 25, PM01:49

Pb 200.8
Kathleen
12/11/25

Building Address

1 Lincoln Street

Smithtown, NY 11787

Analysis Type: ELAP 200.5

Lab Received: DAVID WHARTON 12/10/25
1:49 PM

Signature: David Wharton

Samplers Name: Wilson, Zheng

Samplers Signature: [Signature]

JCB Project Manager: Bryan Eichm

Page 7 of 7

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557607**LIMS Reference ID:** ED57607**EMSL Customer ID:** JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 23-54650 / Smithtown Central School District /
Accompsett Elementary School ACE / 1 Lincoln
Street, Smithtown, NY 11787
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/10/2025 13:49
Reported: 12/23/2025 10:21

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SMTM-0050									
Metals									
Lead	< 1.0		1	1.0	µg/L	12/10/25 20:10	12/10/25 20:10	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: SMTM-0051									
Metals									
Lead	3.4		1	1.0	µg/L	12/10/25 20:11	12/10/25 20:11	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: SMTM-0052									
Metals									
Lead	5.8		1	1.0	µg/L	12/11/25 18:12	12/11/25 18:12	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: SMTM-0053									
Metals									
Lead	2.2		1	1.0	µg/L	12/11/25 18:16	12/11/25 18:16	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: SMTM-0054									
Metals									
Lead	29.2		1	1.0	µg/L	12/11/25 18:17	12/11/25 18:17	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: SMTM-0055									
Metals									
Lead	8.4		1	1.0	µg/L	12/11/25 18:21	12/11/25 18:21	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: SMTM-0066									
Metals									
Lead	1.5		1	1.0	µg/L	12/11/25 18:22	12/11/25 18:22	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: SMTM-0073									
Metals									
Lead	8.5		1	1.0	µg/L	12/11/25 18:24	12/11/25 18:24	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: SMTM-0098									
Metals									

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557607**LIMS Reference ID:** ED57607**EMSL Customer ID:** JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 23-54650 / Smithtown Central School District /
Accompsett Elementary School ACE / 1 Lincoln
Street, Smithtown, NY 11787
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/10/2025 13:49
Reported: 12/23/2025 10:21

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SMTM-0098 (Continued)									
Metals (Continued)									
Lead	< 1.0	1	1.0	µg/L	12/11/25 18:25	12/11/25 18:25	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTM-0099									
Metals									
Lead	< 1.0	1	1.0	µg/L	12/11/25 18:26	12/11/25 18:26	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTM-0101									
Metals									
Lead	< 1.0	1	1.0	µg/L	12/11/25 18:28	12/11/25 18:28	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTM-0102									
Metals									
Lead	< 1.0	1	1.0	µg/L	12/11/25 18:29	12/11/25 18:29	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTM-0103									
Metals									
Lead	2.5	1	1.0	µg/L	12/11/25 18:30	12/11/25 18:30	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTM-1992									
Metals									
Lead	< 1.0	1	1.0	µg/L	12/11/25 18:37	12/11/25 18:37	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTM-1993									
Metals									
Lead	< 1.0	1	1.0	µg/L	12/11/25 18:38	12/11/25 18:38	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTM-2382									
Metals									
Lead	< 1.0	1	1.0	µg/L	12/11/25 18:39	12/11/25 18:39	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTM-2383									
Metals									



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557607

LIMS Reference ID: ED57607

EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 23-54650 / Smithtown Central School District /
Accompsett Elementary School ACE / 1 Lincoln
Street, Smithtown, NY 11787

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeremy Bish

Received: 12/10/2025 13:49

Reported: 12/23/2025 10:21

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method		
Sample: SMTH-2383 (Continued)											
Metals (Continued)											
Lead	< 1.0	1	1.0	µg/L	12/11/25 18:41	12/11/25 18:41	KT1	EPA 200.8 (DA)/EPA 200.8			
Sample: SMTH-3276											
Metals											
Lead	< 1.0	1	1.0	µg/L	12/11/25 18:42	12/11/25 18:42	KT1	EPA 200.8 (DA)/EPA 200.8			
Sample: SMTH-3277											
Metals											
Lead	< 1.0	1	1.0	µg/L	12/11/25 18:43	12/11/25 18:43	KT1	EPA 200.8 (DA)/EPA 200.8			

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557607

LIMS Reference ID: ED57607

EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 23-54650 / Smithtown Central School District /
Accompsett Elementary School ACE / 1 Lincoln
Street, Smithtown, NY 11787
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/10/2025 13:49
Reported: 12/23/2025 10:21

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com for a complete listing of parameters for which EMSL is certified.



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557607

LIMS Reference ID: ED57607

EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 23-54650 / Smithtown Central School District /
Accompsett Elementary School ACE / 1 Lincoln
Street, Smithtown, NY 11787
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/10/2025 13:49
Reported: 12/23/2025 10:21


Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

ED57609

JCB #:

23-54650

Building: Accompeſett Middle School

ACM

Client:

Smithtown Central School District

Retest/New Install

Turn Around: Normal 1 wk Rush

RECEIVED
ENSL ANALYTICAL INC.
Carle Place, NY

DEC 10 2015, PM 01:51
Carle Place, NY

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
SMTH-0241	OF	1013C	Main Office Closet	KC	12/9/2015	5:57:00 AM
SMTH-0244	NO	1013K	Nurse's Office	NS	12/9/2015	6:01:00 AM
SMTH-0248	HA	1014	Corridor by Men's Faculty Restroom	DW	12/9/2015	5:59:00 AM
SMTH-0260	HA	1006	Corridor by Women's Faculty Restroom	DW	12/9/2015	6:03:00 AM
SMTH-0261	OF	1051	Room 203	KC	12/9/2015	6:07:00 AM
SMTH-0264	HA	1048	Corridor o/s Boys' Bathroom	WF	12/9/2015	6:12:00 AM
SMTH-0265	HA	1048	Corridor o/s Boys' Bathroom	WC	12/9/2015	6:12:00 AM
SMTH-0281	HA	1026	Corridor o/s Girls' Locker Room	DW	12/9/2015	6:19:00 AM
SMTH-0297	KI	1015B	Main Lobby/Cafeteria Kitchen	KC	12/9/2015	5:46:00 AM
SMTH-0298	KI	1015B	Main Lobby/Cafeteria Kitchen	KC	12/9/2015	5:46:00 AM
SMTH-0309	ST	1020D	Boys' Locker Room Ice Room	IM	12/9/2015	6:28:00 AM
SMTH-0319	HE	0003	Room 145	EC	12/9/2015	6:41:00 AM
SMTH-0320	HE	0003	Room 145	EC	12/9/2015	6:41:00 AM
SMTH-0321	HE	0003	Room 145	EC	12/9/2015	6:40:00 AM
SMTH-0322	HE	0003	Room 145	EC	12/9/2015	6:40:00 AM
SMTH-0324	HE	0043	Room 139	EC	12/9/2015	6:45:00 AM
SMTH-0325	HE	0043	Room 139	EC	12/9/2015	6:45:00 AM
SMTH-0326	HE	0043	Room 139	EC	12/9/2015	6:46:00 AM

Building Address

660 Meadow Road

Smithtown, NY 11787

Pb 200.8
Last Update 12/11/25

Analysis Type: ELAP 200.5


Lab Received: DAVID WHITTON 12/10/25 1:51 PM

Signature: David Whitten

Samplers Name: Vinton Hines

Samplers Signature: [Signature]

JCB Project Manager: Bryan Ezelius



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

ED57609

JCB #:

23-54650

Building: Accompeett Middle School

ACM

Client:

Smithtown Central School District

Retest/New Install

Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
SMTH-0327	HE	0043	Room 139	EC	12/9/2025	6:47:00 AM
SMTH-0367	HA	0030	Corridor by Boys' Bathroom	WF	12/9/2025	6:49:00 AM
SMTH-0368	HA	0030	Corridor by Boys' Bathroom	WC	12/9/2025	6:49:00 AM
SMTH-2984	KI	1015B	Main Lobby/Cafeteria Kitchen	SN	12/9/2025	5:47:00 AM
SMTH-3231	CA	1015	Main Lobby/Cafeteria	WF	12/9/2025	5:54:00 AM
SMTH-3232	CA	1015	Main Lobby/Cafeteria	WC	12/9/2025	5:54:00 AM
SMTH-3304	KI	1015B	Main Lobby/Cafeteria Kitchen	HW	12/9/2025	5:51:00 AM
SMTH-3305	HA	1027	Corridor (Boy's Bathroom-Gym)	DW	12/9/2025	6:25:00 AM

Samples Submitted 26

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
DEC 10 25, PM01:51

Pb 200.8
Kathleen
12/11/25

Building Address

660 Meadow Road

Smithtown, NY 11787

Analysis Type: ELAP 200.5

Lab Received: DAVID WHITTON 12/10/25
1:51 PM

Signature: David Whitten

Samplers Name: Vinson Zheng

Samplers Signature: Vin

JCB Project Manager: Bryan Erdius

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
 Telephone: 516.997.7251 Fax: 856-786-5974
 EMSL-CP-06

EMSL Order ID: 062557609**LIMS Reference ID:** ED57609**EMSL Customer ID:** JCBR50

Attention: Bryan Ezelius
 J.C. Broderick & Associates [JCBR50]
 1775 Expressway Drive North, Suite 1
 Hauppauge, NY 11788
 (631) 584-5492
 bezelius@jcbroderick.com

Project Name: 23-54650 / Smithtown Central School District /
 Accompsett Middle School ACM / 660 Meadow
 Road, Smithtown, NY 11787
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/10/2025 13:51
Reported: 12/23/2025 10:23

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SMTM-0241									
Metals									
Lead	1.4	1	1.0	µg/L	12/10/25 23:22	12/10/25 23:22	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTM-0244									
Metals									
Lead	3.7	1	1.0	µg/L	12/10/25 23:26	12/10/25 23:26	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTM-0248									
Metals									
Lead	1.4	1	1.0	µg/L	12/10/25 23:28	12/10/25 23:28	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTM-0260									
Metals									
Lead	3.2	1	1.0	µg/L	12/10/25 23:29	12/10/25 23:29	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTM-0261									
Metals									
Lead	4.4	1	1.0	µg/L	12/10/25 23:33	12/10/25 23:33	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTM-0264									
Metals									
Lead	< 1.0	1	1.0	µg/L	12/10/25 23:34	12/10/25 23:34	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTM-0265									
Metals									
Lead	< 1.0	1	1.0	µg/L	12/10/25 23:36	12/10/25 23:36	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTM-0281									
Metals									
Lead	1.6	1	1.0	µg/L	12/10/25 23:37	12/10/25 23:37	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTM-0297									
Metals									

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557609**LIMS Reference ID:** ED57609**EMSL Customer ID:** JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 23-54650 / Smithtown Central School District /
Accompsett Middle School ACM / 660 Meadow
Road, Smithtown, NY 11787
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/10/2025 13:51
Reported: 12/23/2025 10:23

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SMTM-0297 (Continued)									
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	12/10/25 23:38	12/10/25 23:38	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: SMTM-0298									
Metals									
Lead	2.8		1	1.0	µg/L	12/10/25 23:39	12/10/25 23:39	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: SMTM-0309									
Metals									
Lead	< 1.0		1	1.0	µg/L	12/11/25 17:17	12/11/25 17:17	JH	EPA 200.8 (Dig)/EPA 200.8
Sample: SMTM-0319									
Metals									
Lead	4.8		1	1.0	µg/L	12/10/25 23:41	12/10/25 23:41	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: SMTM-0320									
Metals									
Lead	7.4		1	1.0	µg/L	12/10/25 23:45	12/10/25 23:45	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: SMTM-0321									
Metals									
Lead	12.1		1	1.0	µg/L	12/10/25 23:49	12/10/25 23:49	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: SMTM-0322									
Metals									
Lead	14.8		1	1.0	µg/L	12/10/25 23:50	12/10/25 23:50	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: SMTM-0324									
Metals									
Lead	4.6		1	1.0	µg/L	12/10/25 23:51	12/10/25 23:51	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: SMTM-0325									
Metals									

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557609**LIMS Reference ID:** ED57609**EMSL Customer ID:** JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 23-54650 / Smithtown Central School District /
Accompsett Middle School ACM / 660 Meadow
Road, Smithtown, NY 11787
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/10/2025 13:51
Reported: 12/23/2025 10:23

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SMTH-0325 (Continued)									Sampled: 12/09/25 00:00:00
Metals (Continued)									
Lead	3.2	1	1.0	µg/L	12/10/25 23:53	12/10/25 23:53	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-0326									Sampled: 12/09/25 00:00:00
Metals									
Lead	2.4	1	1.0	µg/L	12/10/25 23:54	12/10/25 23:54	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-0327									Sampled: 12/09/25 00:00:00
Metals									
Lead	14.7	1	1.0	µg/L	12/10/25 23:55	12/10/25 23:55	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-0367									Sampled: 12/09/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	12/10/25 23:57	12/10/25 23:57	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-0368									Sampled: 12/09/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	12/10/25 23:58	12/10/25 23:58	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-2984									Sampled: 12/09/25 00:00:00
Metals									
Lead	6.1	1	1.0	µg/L	12/11/25 18:45	12/11/25 18:45	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-3231									Sampled: 12/09/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	12/11/25 18:46	12/11/25 18:46	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-3232									Sampled: 12/09/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	12/11/25 18:47	12/11/25 18:47	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-3304									Sampled: 12/09/25 00:00:00
Metals									



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557609

LIMS Reference ID: ED57609

EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 23-54650 / Smithtown Central School District /
Accompsett Middle School ACM / 660 Meadow
Road, Smithtown, NY 11787
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/10/2025 13:51
Reported: 12/23/2025 10:23

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SMTM-3304 (Continued)									
Metals (Continued)									
Lead	1.6		1	1.0	µg/L	12/11/25 19:02	12/11/25 19:02	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: SMTM-3305									
Metals									
Lead	2.3		1	1.0	µg/L	12/11/25 19:06	12/11/25 19:06	KT1	EPA 200.8 (DA)/EPA 200.8



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557609

LIMS Reference ID: ED57609

EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 23-54650 / Smithtown Central School District /
Accompsett Middle School ACM / 660 Meadow
Road, Smithtown, NY 11787
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/10/2025 13:51
Reported: 12/23/2025 10:23

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com for a complete listing of parameters for which EMSL is certified.



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557609

LIMS Reference ID: ED57609

EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 23-54650 / Smithtown Central School District /
Accompsett Middle School ACM / 660 Meadow
Road, Smithtown, NY 11787
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/10/2025 13:51
Reported: 12/23/2025 10:23

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

ED57692

JCB #:

23-54650

Building: Saint James Elementary School

STJ

RECEIVED
EMSL ANALYTICAL, INC.

Page 1 of 3

Client:

Carle Place, NY

Smithtown Central School District

DEC 12 25, PM01:37

Retest/New Install []

Turn Around: Normal 1 wk Rush _____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
SMTH-0121	HA	NA	Hallway O/S New Gym	WF	12/4/2025	5:43:00 AM
SMTH-0122	HA	NA	Hallway O/S New Gym	WC	12/4/2025	5:43:00 AM
SMTH-0128	CR	NA	CLASSROOM 50	DW	12/4/2025	5:46:00 AM
SMTH-0131	CR	NA	CLASSROOM 51	DW	12/4/2025	5:47:00 AM
SMTH-0135	CR	NA	CLASSROOM 49	DW	12/4/2025	5:48:00 AM
SMTH-0136	CR	NA	CLASSROOM 46	DW	12/4/2025	5:49:00 AM
SMTH-0139	CR	NA	CLASSROOM 47	DW	12/4/2025	5:50:00 AM
SMTH-0141	CR	NA	CLASSROOM 44	DW	12/4/2025	5:51:00 AM
SMTH-0142	CR	NA	CLASSROOM 45	DW	12/4/2025	5:52:00 AM
SMTH-0145	CR	NA	CLASSROOM 43	DW	12/4/2025	5:53:00 AM
SMTH-0147	CR	NA	CLASSROOM 42	DW	12/4/2025	5:54:00 AM
SMTH-0149	CR	NA	CLASSROOM 41	DW	12/4/2025	5:55:00 AM
SMTH-0151	CR	NA	CLASSROOM 40	DW	12/4/2025	5:58:00 AM
SMTH-0160	CR	1061	Room 11	DW	12/4/2025	5:58:00 AM
SMTH-0165	CR	1050	Room 7	DW	12/4/2025	6:04:00 AM
SMTH-0166	CR	1052	Room 8	DW	12/4/2025	6:05:00 AM
SMTH-0171	CR	NA	CLASSROOM 52	DW	12/4/2025	6:10:00 AM
SMTH-0177	CR	NA	CLASSROOM 54	DW	12/4/2025	6:12:00 AM

Building Address

580 Lake Avenue

St. James, NY 11780

Courier

Analysis Type: ELAP 200.5

Lab Received: DAVID WHARTON

Signature: David Wharton

12/12/25
1:37 PM


Samplers Name: Wilson Zheng

Samplers Signature:

JCB Project Manager: Bryan Ezelius

Page 9 of 11

PL 200.8
Kathleen
12/15/25



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #:

ED57692

23-54650

Building: Saint James Elementary School

STJ

RECEIVED

EMSL ANALYTICAL, INC. Page 2 of 3

Carle Place, NY

Smithtown Central School District
DEC 12 2017 10:01:37

Retest/New Install

Turn Around: Normal 1 wk Rush _____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
SMTH-0179	CR	NA	CLASSROOM 55	DW	12/4/2025	6:12:00 AM
SMTH-0181	CR	1039	Room 6	DW	12/4/2025	6:18:00 AM
SMTH-0184	CR	1036	Room 5	DW	12/4/2025	6:19:00 AM
SMTH-0187	CR	1034	Room 4	DW	12/4/2025	6:19:00 AM
SMTH-0188	CR	1031	Room 3	DW	12/4/2025	6:21:00 AM
SMTH-0191	CR	1028	Room 2	DW	12/4/2025	6:22:00 AM
SMTH-0192	CR	1026	Third Grade Art (1)	DW	12/4/2025	6:23:00 AM
SMTH-0198	HA	1024	Corridor by Boys Bathroom	WF	12/4/2025	6:25:00 AM
SMTH-0199	HA	1024	Corridor by Boys Bathroom	WC	12/4/2025	6:26:00 AM
SMTH-0201	KI	1047	Kitchen	KC	12/4/2025	6:34:00 AM
SMTH-0202	KI	1047	Kitchen	KC	12/4/2025	6:28:00 AM
SMTH-0203	KI	1047	Kitchen	KC	12/4/2025	6:29:00 AM
SMTH-0204	KI	1047	Kitchen	KC	12/4/2025	6:29:00 AM
SMTH-0205	KI	1047	Kitchen	SN	12/4/2025	6:31:00 AM
SMTH-0206	KI	1047	Kitchen	KC	12/4/2025	6:32:00 AM
SMTH-0207	KI	1047	Kitchen	KC	12/4/2025	6:32:00 AM
SMTH-0208	KI	1047	Kitchen	SN	12/4/2025	6:32:00 AM
SMTH-0213	CR	1001	Room 20 Music	DW	12/4/2025	6:45:00 AM

Building Address

580 Lake Avenue
St. James, NY 11780

Analysis Type: ELAP 200.5

Lab Received: DAVID WHALEON 12/12/25
1:37 PM


Signature: David Whalen

Samplers Name: Vinson Zheng

Samplers Signature: Vincent Zheng

JCB Project Manager: Bryan Fehius

12/2008
Vinson Zheng
12/15/2025



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #:

ED57692

23-54650

Building: Saint James Elementary School

STJ

Client:

EMSL ANALYTICAL, INC.
Smithtown Central School District
Carle Place, NY

Page 3 of 3

Retest/New Install DEC 12 25, PM 01:37
Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
SMTH-0215	CR	1001	Room 20 Music	DW	12/4/2025	6:46:00 AM
SMTH-0216	CR	1000A	Room 21 Music	DW	12/4/2025	6:47:00 AM
SMTH-0229	NO	1018A	Health Office	DW	12/4/2025	6:41:00 AM
SMTH-0236	HA	2017	Corridor by Girls' Bathroom	DW	12/4/2025	6:56:00 AM
SMTH-0237	HA	2017	Corridor by Custodial Closet	WF	12/4/2025	6:54:00 AM
SMTH-0238	HA	2017	Corridor by Custodial Closet	WF	12/4/2025	6:54:00 AM
SMTH-3144	CR	NA	CLASSROOM 53	DW	12/4/2025	7:05:00 AM
SMTH-3361	HA	1063	Corridor 11B To New Addition	WF	12/4/2025	7:07:00 AM
SMTH-3362	HA	1063	Corridor 11B To New Addition	WC	12/4/2025	7:07:00 AM

Samples Submitted 45

Pb 200.8
Kathleen
12/15/25

Building Address
580 Lake Avenue
St. James, NY 11780

Analysis Type: ELAP 200.5

Lab Received: DAVID WHITTON 12/12/25 1:37 PM

Signature: David Whitten

Samplers Name: _____

Samplers Signature: _____

JCB Project Manager: _____

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
 Telephone: 516.997.7251 Fax: 856-786-5974
 EMSL-CP-06

EMSL Order ID: 062557692**LIMS Reference ID:** ED57692**EMSL Customer ID:** JCBR50

Attention: Bryan Ezelius
 J.C. Broderick & Associates [JCBR50]
 1775 Expressway Drive North, Suite 1
 Hauppauge, NY 11788
 (631) 584-5492
 bezelius@jcbroderick.com

Project Name: 23-54650 / Smithtown Central School District / Saint James Elementary School STJ / 580 Lake Avenue, St. James, NY 11780
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/12/2025 13:37
Reported: 12/23/2025 10:51

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SMTM-0121									
Metals									
Lead	< 1.0		1	1.0	µg/L	12/15/25 19:14	12/15/25 19:14	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: SMTM-0122									
Metals									
Lead	< 1.0		1	1.0	µg/L	12/15/25 19:18	12/15/25 19:18	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: SMTM-0128									
Metals									
Lead	1.3		1	1.0	µg/L	12/15/25 19:19	12/15/25 19:19	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: SMTM-0131									
Metals									
Lead	1.3		1	1.0	µg/L	12/15/25 19:23	12/15/25 19:23	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: SMTM-0135									
Metals									
Lead	< 1.0		1	1.0	µg/L	12/15/25 19:24	12/15/25 19:24	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: SMTM-0136									
Metals									
Lead	2.2		1	1.0	µg/L	12/15/25 19:26	12/15/25 19:26	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: SMTM-0139									
Metals									
Lead	1.8		1	1.0	µg/L	12/15/25 19:27	12/15/25 19:27	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: SMTM-0141									
Metals									
Lead	< 1.0		1	1.0	µg/L	12/20/25 11:41	12/20/25 11:41	JH	EPA 200.8 (Dig)/EPA 200.8
Sample: SMTM-0142									
Metals									

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557692**LIMS Reference ID:** ED57692**EMSL Customer ID:** JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 23-54650 / Smithtown Central School District / Saint James Elementary School STJ / 580 Lake Avenue, St. James, NY 11780
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/12/2025 13:37
Reported: 12/23/2025 10:51

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SMTM-0142 (Continued)									Sampled: 12/04/25 00:00:00
Metals (Continued)									
Lead	1.4	1	1.0	µg/L	12/15/25 19:28	12/15/25 19:28	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTM-0145									Sampled: 12/04/25 00:00:00
Metals									
Lead	1.3	1	1.0	µg/L	12/15/25 19:29	12/15/25 19:29	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTM-0147									Sampled: 12/04/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	12/15/25 19:31	12/15/25 19:31	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTM-0149									Sampled: 12/04/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	12/15/25 19:32	12/15/25 19:32	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTM-0151									Sampled: 12/04/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	12/15/25 19:39	12/15/25 19:39	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTM-0160									Sampled: 12/04/25 00:00:00
Metals									
Lead	7.9	1	1.0	µg/L	12/15/25 19:40	12/15/25 19:40	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTM-0165									Sampled: 12/04/25 00:00:00
Metals									
Lead	1.9	1	1.0	µg/L	12/15/25 19:41	12/15/25 19:41	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTM-0166									Sampled: 12/04/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	12/15/25 19:43	12/15/25 19:43	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTM-0171									Sampled: 12/04/25 00:00:00
Metals									

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557692**LIMS Reference ID:** ED57692**EMSL Customer ID:** JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 23-54650 / Smithtown Central School District / Saint James Elementary School STJ / 580 Lake Avenue, St. James, NY 11780
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/12/2025 13:37
Reported: 12/23/2025 10:51

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SMTM-0171 (Continued)									Sampled: 12/04/25 00:00:00
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	12/15/25 19:44	12/15/25 19:44	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: SMTM-0177									Sampled: 12/04/25 00:00:00
Metals									
Lead	1.3		1	1.0	µg/L	12/15/25 19:45	12/15/25 19:45	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: SMTM-0179									Sampled: 12/04/25 00:00:00
Metals									
Lead	< 1.0		1	1.0	µg/L	12/15/25 19:47	12/15/25 19:47	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: SMTM-0181									Sampled: 12/04/25 00:00:00
Metals									
Lead	1.7		1	1.0	µg/L	12/15/25 19:48	12/15/25 19:48	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: SMTM-0184									Sampled: 12/04/25 00:00:00
Metals									
Lead	1.5		1	1.0	µg/L	12/15/25 19:49	12/15/25 19:49	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: SMTM-0187									Sampled: 12/04/25 00:00:00
Metals									
Lead	3.6		1	1.0	µg/L	12/15/25 20:07	12/15/25 20:07	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: SMTM-0188									Sampled: 12/04/25 00:00:00
Metals									
Lead	4.1		1	1.0	µg/L	12/20/25 11:48	12/20/25 11:48	JH	EPA 200.8 (Dig)/EPA 200.8
Sample: SMTM-0191									Sampled: 12/04/25 00:00:00
Metals									
Lead	3.3		1	1.0	µg/L	12/15/25 20:08	12/15/25 20:08	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: SMTM-0192									Sampled: 12/04/25 00:00:00
Metals									

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557692**LIMS Reference ID:** ED57692**EMSL Customer ID:** JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 23-54650 / Smithtown Central School District / Saint James Elementary School STJ / 580 Lake Avenue, St. James, NY 11780
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/12/2025 13:37
Reported: 12/23/2025 10:51

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SMTM-0192 (Continued)									Sampled: 12/04/25 00:00:00
Metals (Continued)									
Lead	< 1.0	1	1.0	µg/L	12/15/25 20:10	12/15/25 20:10	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTM-0198									Sampled: 12/04/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	12/15/25 20:14	12/15/25 20:14	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTM-0199									Sampled: 12/04/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	12/15/25 20:15	12/15/25 20:15	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTM-0201									Sampled: 12/04/25 00:00:00
Metals									
Lead	3.3	1	1.0	µg/L	12/15/25 20:16	12/15/25 20:16	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTM-0202									Sampled: 12/04/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	12/15/25 20:18	12/15/25 20:18	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTM-0203									Sampled: 12/04/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	12/20/25 11:52	12/20/25 11:52	JH	EPA 200.8 (Dig)/EPA 200.8	
Sample: SMTM-0204									Sampled: 12/04/25 00:00:00
Metals									
Lead	1.6	1	1.0	µg/L	12/15/25 20:19	12/15/25 20:19	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTM-0205									Sampled: 12/04/25 00:00:00
Metals									
Lead	10.1	1	1.0	µg/L	12/15/25 20:20	12/15/25 20:20	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTM-0206									Sampled: 12/04/25 00:00:00
Metals									

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557692**LIMS Reference ID:** ED57692**EMSL Customer ID:** JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 23-54650 / Smithtown Central School District / Saint James Elementary School STJ / 580 Lake Avenue, St. James, NY 11780
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/12/2025 13:37
Reported: 12/23/2025 10:51

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SMTM-0206 (Continued)									Sampled: 12/04/25 00:00:00
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	12/20/25 11:53	12/20/25 11:53	JH	EPA 200.8 (Dig)/EPA 200.8
Sample: SMTM-0207									Sampled: 12/04/25 00:00:00
Metals									
Lead	16.2		1	1.0	µg/L	12/15/25 20:22	12/15/25 20:22	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: SMTM-0208									Sampled: 12/04/25 00:00:00
Metals									
Lead	< 1.0		1	1.0	µg/L	12/15/25 20:26	12/15/25 20:26	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: SMTM-0213									Sampled: 12/04/25 00:00:00
Metals									
Lead	6.0		1	1.0	µg/L	12/15/25 20:30	12/15/25 20:30	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: SMTM-0215									Sampled: 12/04/25 00:00:00
Metals									
Lead	2.2		1	1.0	µg/L	12/15/25 20:31	12/15/25 20:31	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: SMTM-0216									Sampled: 12/04/25 00:00:00
Metals									
Lead	7.2		1	1.0	µg/L	12/15/25 20:32	12/15/25 20:32	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: SMTM-0229									Sampled: 12/04/25 00:00:00
Metals									
Lead	4.1		1	1.0	µg/L	12/20/25 11:55	12/20/25 11:55	JH	EPA 200.8 (Dig)/EPA 200.8
Sample: SMTM-0236									Sampled: 12/04/25 00:00:00
Metals									
Lead	4.8		1	1.0	µg/L	12/20/25 11:56	12/20/25 11:56	JH	EPA 200.8 (Dig)/EPA 200.8
Sample: SMTM-0237									Sampled: 12/04/25 00:00:00
Metals									

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557692**LIMS Reference ID:** ED57692**EMSL Customer ID:** JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 23-54650 / Smithtown Central School District / Saint James Elementary School STJ / 580 Lake Avenue, St. James, NY 11780
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/12/2025 13:37
Reported: 12/23/2025 10:51

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SMTM-0237 (Continued)									
Metals (Continued)									
Lead < 1.0 1 1.0 µg/L 12/15/25 20:34 12/15/25 20:34 KT1 EPA 200.8 (DA)/EPA 200.8									
Sample: SMTM-0238									
Metals									
Lead < 1.0 1 1.0 µg/L 12/15/25 20:35 12/15/25 20:35 KT1 EPA 200.8 (DA)/EPA 200.8									
Sample: SMTM-3144									
Metals									
Lead < 1.0 1 1.0 µg/L 12/15/25 20:36 12/15/25 20:36 KT1 EPA 200.8 (DA)/EPA 200.8									
Sample: SMTM-3361									
Metals									
Lead < 1.0 1 1.0 µg/L 12/15/25 20:38 12/15/25 20:38 KT1 EPA 200.8 (DA)/EPA 200.8									
Sample: SMTM-3362									
Metals									
Lead < 1.0 1 1.0 µg/L 12/15/25 20:39 12/15/25 20:39 KT1 EPA 200.8 (DA)/EPA 200.8									



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557692

LIMS Reference ID: ED57692

EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 23-54650 / Smithtown Central School District / Saint James Elementary School STJ / 580 Lake Avenue, St. James, NY 11780
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/12/2025 13:37
Reported: 12/23/2025 10:51

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com for a complete listing of parameters for which EMSL is certified.



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557692

LIMS Reference ID: ED57692

EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 23-54650 / Smithtown Central School District / Saint James Elementary School STJ / 580 Lake Avenue, St. James, NY 11780
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/12/2025 13:37
Reported: 12/23/2025 10:51

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

ED57980

JCB #:

23-54650

Building: Saint James Elementary School

STJ

Client:

Smithtown Central School District

Retest/New Install []

Turn Around: Normal 1 wk Rush

48 HR

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
SMTH-0205	KI	1047	Kitchen	SN	12/31/2025	8:25:00 AM
SMTH-0207	KI	1047	Kitchen	KC	12/31/2025	8:25:00 AM
SMTH-0208	KI	1047	Kitchen	SN	12/31/2025	8:27:00 AM

Samples Submitted 3

RECEIVED

EMSL ANALYTICAL, INC.

Carle Place, NY

DEC 31 25, AM10:40

Pb 200.8 Billing 1/2/26



Building Address

580 Lake Avenue

St. James, NY 11780

Analysis Type: ELAP 200.5

Lab Received: DAVID WHARTON 12/31/25
10:40 AM

Signature: David wharton

Samplers Name: Brett Bonface

Samplers Signature:

JCB Project Manager:

Bryan tree

Page 4 of 4

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557980**LIMS Reference ID:** ED57980**EMSL Customer ID:** JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 23-54650 / Smithtown Central School District / Saint James Elementary School STJ / 580 Lake Avenue, St. James, NY 11780
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/31/2025 10:40
Reported: 01/02/2026 12:28

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SMTM-0205									
Metals									
Lead									
< 1.0									
Sample: SMTM-0207									
Metals									
Lead									
< 1.0									
Sample: SMTM-0208									
Metals									
Lead									
< 1.0									



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062555980

LIMS Reference ID: ED57980

EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 23-54650 / Smithtown Central School District / Saint James Elementary School STJ / 580 Lake Avenue, St. James, NY 11780
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/31/2025 10:40
Reported: 01/02/2026 12:28

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com for a complete listing of parameters for which EMSL is certified.



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557980

LIMS Reference ID: ED57980

EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 23-54650 / Smithtown Central School District / Saint James Elementary School STJ / 580 Lake Avenue, St. James, NY 11780
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/31/2025 10:40
Reported: 01/02/2026 12:28

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.


James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #:

23-54650

Building: Smithtown Elementary School

SMES

ED57617

Client:

Smithtown Central School District

Retest New Install []

Turn Around: Normal 1 wk Rush _____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
SMTH-0379	KI	1015B	Cafeteria Kitchen	SN	12/6/2025	8:00:00 AM
SMTH-0381	KI	1015B	Cafeteria Kitchen	HW	12/6/2025	6:00:00 AM
SMTH-0383	KI	1015B	Cafeteria Kitchen	KC	12/6/2025	8:04:00 AM
SMTH-0384	KI	1015B	Cafeteria Kitchen	KC	12/6/2025	8:05:00 AM
SMTH-0385	NO	1029C	Nurses Office	KC	12/6/2025	6:09:00 AM
SMTH-0424	HA	1025	Corridor by Orchestra Room	DW	12/6/2025	7:22:00 AM
SMTH-0426	HA	NA	Corridor by CLASSROOM 55	DW	12/6/2025	7:18:00 AM
SMTH-1852	HA	1010	Corridor by Room 25	WF	12/6/2025	7:47:00 AM
SMTH-1853	HA	1010	Corridor by Room 25	DW	12/6/2025	7:47:00 AM
SMTH-1854	HA	NA	Corridor by CLASSROOM 55	WF	12/6/2025	7:51:00 AM
SMTH-1855	HA	1025	Corridor by Orchestra Room	WF	12/6/2025	7:51:00 AM
SMTH-3367	FL	1023C	Faculty Room Small Corridor Kitchenette	KC	12/6/2025	6:53:00 AM

Samples Submitted 12

Courier

Building Address

51 Lawrence Avenue
Smithtown, NY 11787

Analysis Type: ELAP 200.5

Lab Received: DAVID WHITTON

Signature: David Whitton

10/25
1:49 pm

Samplers Name: Matthew Lane

Samplers Signature:

JCB Project Manager: Bryan Ezelius

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557617**LIMS Reference ID:** ED57617**EMSL Customer ID:** JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 23-54650 / Smithtown Central School District /
Smithtown Elementary School SMES / 51 Lawrence
Avenue, Smithtown, NY 11787
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/10/2025 13:49
Reported: 12/23/2025 12:12

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SMTH-0379									
Metals									
Lead	10.7	1	1.0	µg/L	12/11/25 20:15	12/11/25 20:15	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-0381									
Metals									
Lead	1.2	1	1.0	µg/L	12/11/25 20:16	12/11/25 20:16	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-0383									
Metals									
Lead	< 1.0	1	1.0	µg/L	12/11/25 20:17	12/11/25 20:17	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-0384									
Metals									
Lead	< 1.0	1	1.0	µg/L	12/11/25 20:21	12/11/25 20:21	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-0385									
Metals									
Lead	21.4	1	1.0	µg/L	12/11/25 20:25	12/11/25 20:25	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-0424									
Metals									
Lead	< 1.0	1	1.0	µg/L	12/11/25 20:27	12/11/25 20:27	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-0426									
Metals									
Lead	< 1.0	1	1.0	µg/L	12/11/25 20:28	12/11/25 20:28	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-1852									
Metals									
Lead	< 1.0	1	1.0	µg/L	12/11/25 20:29	12/11/25 20:29	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-1853									
Metals									
Lead	< 1.0	1	1.0	µg/L	12/11/25 20:30	12/11/25 20:30	KT1	EPA 200.8 (DA)/EPA 200.8	

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557617**LIMS Reference ID:** ED57617**EMSL Customer ID:** JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 23-54650 / Smithtown Central School District /
Smithtown Elementary School SMES / 51 Lawrence
Avenue, Smithtown, NY 11787
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/10/2025 13:49
Reported: 12/23/2025 12:12

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SMTH-1853 (Continued)									
Metals (Continued)									
Lead < 1.0 1 1.0 µg/L 12/11/25 20:31 12/11/25 20:31 KT1 EPA 200.8 (DA)/EPA 200.8									
Sample: SMTH-1854									
Metals									
Lead < 1.0 1 1.0 µg/L 12/11/25 20:32 12/11/25 20:32 KT1 EPA 200.8 (DA)/EPA 200.8									
Sample: SMTH-1855									
Metals									
Lead < 1.0 1 1.0 µg/L 12/11/25 20:33 12/11/25 20:33 KT1 EPA 200.8 (DA)/EPA 200.8									
Sample: SMTH-3367									
Metals									
Lead < 1.0 1 1.0 µg/L 12/11/25 20:35 12/11/25 20:35 KT1 EPA 200.8 (DA)/EPA 200.8									

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557617

LIMS Reference ID: ED57617

EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 23-54650 / Smithtown Central School District /
Smithtown Elementary School SMES / 51 Lawrence
Avenue, Smithtown, NY 11787
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/10/2025 13:49
Reported: 12/23/2025 12:12

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com for a complete listing of parameters for which EMSL is certified.



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557617

LIMS Reference ID: ED57617

EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 23-54650 / Smithtown Central School District /
Smithtown Elementary School SMES / 51 Lawrence
Avenue, Smithtown, NY 11787
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/10/2025 13:49
Reported: 12/23/2025 12:12

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

ED57615

JCB #:

23-54650

Building: Mills Pond Elementary School

MILL

Client:

Smithtown Central School District

Retest/New Install

Turn Around: Normal 1 wk Rush

Page 7

Courier

EMSL ANALYTICAL, INC.

Carle Place, NY

DEC 10 2025 PM01:52

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time	RECEIVED
SMTH-1118	HA	NA	Corridor by Classroom 44	WF	12/10/2025	6:05:00 AM	EMSL ANALYTICAL, INC.
SMTH-1119	HA	NA	Corridor by Classroom 44	WC	12/10/2025	6:06:00 AM	
SMTH-1120	HA	NA	Corridor by Classroom 44	WC	12/10/2025	6:06:00 AM	
SMTH-1160	HA	NA	Corridor by Gym	WF	12/10/2025	6:09:00 AM	
SMTH-1161	HA	NA	Corridor by Gym	WC	12/10/2025	6:10:00 AM	
SMTH-1162	HA	NA	Corridor by Gym	WC	12/10/2025	6:10:00 AM	
SMTH-1165	KI	NA	Kitchen	KC	12/10/2025	5:46:00 AM	
SMTH-1166	KI	NA	Kitchen	KC	12/10/2025	5:40:00 AM	
SMTH-1167	KI	NA	Kitchen	KC	12/10/2025	5:40:00 AM	
SMTH-1168	KI	NA	Kitchen	SN	12/10/2025	5:42:00 AM	
SMTH-1169	KI	NA	Kitchen	KC	12/10/2025	5:43:00 AM	
SMTH-1170	FL	NA	Faculty Room	KC	12/10/2025	5:49:00 AM	
SMTH-1176	HA	1025	Main Lobby	WF	12/10/2025	5:53:00 AM	
SMTH-1177	HA	1025	Main Lobby	WC	12/10/2025	5:53:00 AM	
SMTH-1182	NO	1016	Nurse's Office	KC	12/10/2025	5:55:00 AM	
SMTH-1194	HA	NA	Corridor from Room 1 - 6	WC	12/10/2025	5:58:00 AM	
SMTH-1195	HA	NA	Corridor from Room 1 - 6	WC	12/10/2025	5:58:00 AM	

Building Address

246 Moriches Road

St. James, NY 11780

Analysis Type: ELAP 200.5


Lab Received: DAVID WILKINSON 12/10/25
1:52 PM

Signature: David Wilkinson

Samplers Name: Jayell Bonface

Samplers Signature: Jayell Bonface

JCB Project Manager: Bryan Ezelius Page 6 of 7



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

ED57615

JCB #: 23-54650
Building: Mills Pond Elementary School
MILL

Client:
Smithtown Central School District

Retest/New Install

Turn Around: Normal 1 wk Rush _____


Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
-----------	-----------------------	----------	------------------	-------------	-------------	-------------

Samples Submitted 17

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
DEC 10 25, PM01:52

Building Address
246 Moriches Road
St. James, NY 11780

Analysis Type: ELAP 200.5
Lab Received: DAVID WHARTON 10/10/25
Signature: David Wharton

Samplers Name: Jarett Bonface
Samplers Signature: 
JCB Project Manager: Bryan Ekelus

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557615**LIMS Reference ID:** ED57615**EMSL Customer ID:** JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 23-54650 / Smithtown Central School District / Mills Pond Elementary School MILL / 246 Moriches Road, St. James, NY 11780
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/10/2025 13:52
Reported: 12/23/2025 10:32

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SMTH-1118									
Metals									
Lead	< 1.0	1	1.0	µg/L	12/11/25 19:59	12/11/25 19:59	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-1119									
Metals									
Lead	< 1.0	1	1.0	µg/L	12/11/25 21:14	12/11/25 21:14	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-1120									
Metals									
Lead	< 1.0	1	1.0	µg/L	12/11/25 21:18	12/11/25 21:18	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-1160									
Metals									
Lead	< 1.0	1	1.0	µg/L	12/11/25 21:20	12/11/25 21:20	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-1161									
Metals									
Lead	< 1.0	1	1.0	µg/L	12/11/25 21:21	12/11/25 21:21	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-1162									
Metals									
Lead	< 1.0	1	1.0	µg/L	12/11/25 21:22	12/11/25 21:22	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-1165									
Metals									
Lead	13.0	1	1.0	µg/L	12/11/25 21:24	12/11/25 21:24	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-1166									
Metals									
Lead	10.4	1	1.0	µg/L	12/11/25 21:25	12/11/25 21:25	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-1167									
Metals									

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557615**LIMS Reference ID:** ED57615**EMSL Customer ID:** JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 23-54650 / Smithtown Central School District / Mills Pond Elementary School MILL / 246 Moriches Road, St. James, NY 11780
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/10/2025 13:52
Reported: 12/23/2025 10:32

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SMTH-1167 (Continued)									Sampled: 12/10/25 00:00:00
Metals (Continued)									
Lead	3.6	1	1.0	µg/L	12/11/25 21:29	12/11/25 21:29	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-1168									Sampled: 12/10/25 00:00:00
Metals									
Lead	6.4	1	1.0	µg/L	12/11/25 21:30	12/11/25 21:30	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-1169									Sampled: 12/10/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	12/11/25 21:34	12/11/25 21:34	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-1170									Sampled: 12/10/25 00:00:00
Metals									
Lead	421	10	10.0	µg/L	12/11/25 22:12	12/11/25 22:12	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-1176									Sampled: 12/10/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	12/11/25 21:37	12/11/25 21:37	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-1177									Sampled: 12/10/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	12/11/25 21:38	12/11/25 21:38	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-1182									Sampled: 12/10/25 00:00:00
Metals									
Lead	1.0	1	1.0	µg/L	12/11/25 21:40	12/11/25 21:40	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-1194									Sampled: 12/10/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	12/11/25 21:41	12/11/25 21:41	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-1195									Sampled: 12/10/25 00:00:00
Metals									



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557615

LIMS Reference ID: ED57615

EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 23-54650 / Smithtown Central School District / Mills Pond Elementary School MILL / 246 Moriches Road, St. James, NY 11780
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/10/2025 13:52
Reported: 12/23/2025 10:32

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SMTM-1195 (Continued)				Lims Reference ID: ED57615-17 Matrix: Drinking Water					Sampled: 12/10/25 00:00:00
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	12/11/25 21:42	12/11/25 21:42	DAZ	EPA 200.8 (DA)/EPA 200.8



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557615

LIMS Reference ID: ED57615

EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 23-54650 / Smithtown Central School District / Mills Pond Elementary School MILL / 246 Moriches Road, St. James, NY 11780
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/10/2025 13:52
Reported: 12/23/2025 10:32

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com for a complete listing of parameters for which EMSL is certified.



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557615

LIMS Reference ID: ED57615

EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 23-54650 / Smithtown Central School District / Mills Pond Elementary School MILL / 246 Moriches Road, St. James, NY 11780
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/10/2025 13:52
Reported: 12/23/2025 10:32


Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

ED57984

Page 1 of 1

JCB #:

23-54650

Building: Mills Pond Elementary School

MILL

Client:

Smithtown Central School District

Retest/New Install

Turn Around: Normal 1 wk Rush 48 HR

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
SMTH-1166	KI	NA	Kitchen	KC	12/31/2025	8:12:00 AM
SMTH-1168	KI	NA	Kitchen	SN	12/31/2025	8:10:00 AM

Samples Submitted 2

Pb 200.8 Bkng 1/2/26

RECEIVED

EMSL ANALYTICAL, INC.

Carle Place, NY

DEC 31 25, AM10:40

Building Address
246 Moriches Road
St. James, NY 11780

Analysis Type: ELAP 200.5

Lab Received: DAVID WHARTON 12/31/2025 10:40 AM

Signature: David whr

Samplers Name: Jarett Benifice

Samplers Signature: J

JCB Project Manager: Bryan Freitas

Page 4 of 4

Walk In

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557984**LIMS Reference ID:** ED57984**EMSL Customer ID:** JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 23-54650 / Smithtown Central School District / Mills Pond Elementary School MILL / 246 Moriches Road, St. James, NY 11780
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/31/2025 10:40
Reported: 01/02/2026 12:33

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SMTH-1166									
Metals									
Lead	1.5		1	1.0	µg/L	01/02/26 11:35	01/02/26 11:35	BP	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH-1168									
Metals									
Lead	16.5		1	1.0	µg/L	01/02/26 11:36	01/02/26 11:36	BP	EPA 200.8 (DA)/EPA 200.8



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557984

LIMS Reference ID: ED57984

EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 23-54650 / Smithtown Central School District / Mills Pond Elementary School MILL / 246 Moriches Road, St. James, NY 11780
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/31/2025 10:40
Reported: 01/02/2026 12:33

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com for a complete listing of parameters for which EMSL is certified.



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557984

LIMS Reference ID: ED57984

EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 23-54650 / Smithtown Central School District / Mills Pond Elementary School MILL / 246 Moriches Road, St. James, NY 11780
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/31/2025 10:40
Reported: 01/02/2026 12:33

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

ED57817

Client:

Smithtown Central School District

Walk In

of 3

JCB #:

23-54650

Building: Great Hollow Middle School

GHMS

Retest/New Install

Turn Around: Normal 1 w^k Rush _____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time	Sample Place, NY
SMTH-0501	HA	1055	Corridor by Room 128	DW	11/26/2025	6:15:00 AM	RECEIVED 10/23/2025 Cawley Place, NY
SMTH-0502	CR	1046A	Room 127	EC	11/26/2025	6:19:00 AM	RECEIVED 10/23/2025 Cawley Place, NY
SMTH-0503	CR	1046A	Room 127	EC	11/26/2025	6:19:00 AM	RECEIVED 10/23/2025 Cawley Place, NY
SMTH-0504	CR	1046A	Room 127	EC	11/26/2025	6:19:00 AM	RECEIVED 10/23/2025 Cawley Place, NY
SMTH-0505	CR	1046A	Room 127	EC	11/26/2025	6:19:00 AM	RECEIVED 10/23/2025 Cawley Place, NY
SMTH-0506	CR	1046C	Room 128	EC	11/26/2025	6:22:00 AM	RECEIVED 10/23/2025 Cawley Place, NY
SMTH-0507	CR	1046C	Room 128	EC	11/26/2025	6:22:00 AM	RECEIVED 10/23/2025 Cawley Place, NY
SMTH-0508	CR	1046C	Room 128	EC	11/26/2025	6:22:00 AM	RECEIVED 10/23/2025 Cawley Place, NY
SMTH-0509	CR	1046C	Room 128	EC	11/26/2025	6:23:00 AM	RECEIVED 10/23/2025 Cawley Place, NY
SMTH-0510	CR	1045	Room 126	EC	11/26/2025	6:24:00 AM	RECEIVED 10/23/2025 Cawley Place, NY
SMTH-0511	CR	1045	Room 126	EC	11/26/2025	6:25:00 AM	RECEIVED 10/23/2025 Cawley Place, NY
SMTH-0512	CR	1045	Room 126	EC	11/26/2025	6:25:00 AM	RECEIVED 10/23/2025 Cawley Place, NY
SMTH-0513	CR	1045	Room 126	EC	11/26/2025	6:26:00 AM	RECEIVED 10/23/2025 Cawley Place, NY
SMTH-0527	OF	1006C	109C	KC	11/26/2025	6:33:00 AM	RECEIVED 10/23/2025 Cawley Place, NY
SMTH-0530	NO	1009	Health Office	KC	11/26/2025	6:34:00 AM	RECEIVED 10/23/2025 Cawley Place, NY
SMTH-0531	FL	1011	Room 104	KC	11/26/2025	6:36:00 AM	RECEIVED 10/23/2025 Cawley Place, NY
SMTH-0532	FL	1011	Room 104	IM	11/26/2025	6:38:00 AM	RECEIVED 10/23/2025 Cawley Place, NY
SMTH-0545	KI	1023	Serving Area 139	KC	11/26/2025	7:03:00 AM	RECEIVED 10/23/2025 Cawley Place, NY

Building Address

150 Southern Boulevard

Nesconset, NY 11767

Analysis Type: ELAP 200.5

Lab Received: DAVID WILKINSON 10/19/25

3:16 PM

Signature: David Wilkinson

Samplers Name: Vinson Zheng

Samplers Signature: Vinson Zheng

JCB Project Manager: Bryan Ezelius


10/20/25

Pb 200.5

10/23/25

2018

DEC 19 2025 PM03:16



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

ED51817

JCB #:

23-54650

Building: Great Hollow Middle School

GHMS

Client:

Smithtown Central School District

Retest/New Install

Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time	Comments
SMTH-0548	KI	1023	Serving Area 139	HW	11/26/2025	7:06:00 AM	RECEIVED 11/26/2025 Carrie Place, NY DEC 19 2025, PHM3216
SMTH-0549	KI	1022	Kitchen	HW	11/26/2025	7:07:00 AM	
SMTH-0550	KI	1022	Kitchen	HW	11/26/2025	7:11:00 AM	
SMTH-0551	KI	1022	Kitchen	KC	11/26/2025	7:11:00 AM	
SMTH-0552	KI	1022	Kitchen	KC	11/26/2025	7:08:00 AM	
SMTH-0553	KI	1022	Kitchen	KC	11/26/2025	7:09:00 AM	
SMTH-0557	HA	1032	Corridor by Storage 137	DW	11/26/2025	7:09:00 AM	
SMTH-0560	HA	NA	Corridor by Faculty Men's Bathroom 141	WC	11/26/2025	7:02:00 AM	
SMTH-0561	HA	NA	Corridor by Faculty Men's Bathroom 141	WF	11/26/2025	7:02:00 AM	
SMTH-0578	OF	NA	MAIN OFFICE	KC	11/26/2025	7:45:00 AM	
SMTH-0611	HA	NA	Corridor by Room 256	WC	11/26/2025	7:51:00 AM	
SMTH-1922	KI	1022	Kitchen	SN	11/26/2025	8:20:00 AM	
SMTH-3086	HA	NA	Corridor by Room 185	WF	11/26/2025	6:50:00 AM	
SMTH-3087	HA	NA	Corridor by Room 185	WC	11/26/2025	6:50:00 AM	
SMTH-3094	SA	NA	Cafeteria West Serving Area	HW	11/26/2025	7:18:00 AM	
SMTH-3283	HA	1042	Corridor (Art Room 119-Main Lobby)	WF	11/26/2025	6:30:00 AM	
SMTH-3284	HA	1042	Corridor (Art Room 119-Main Lobby)	WC	11/26/2025	6:30:00 AM	
SMTH-3285	LR	1017	Boy's Locker Room	WF	11/26/2025	6:55:00 AM	

Building Address

150 Southern Boulevard
Nesconset, NY 11767

Analysis Type: ELAP 200.5

Lab Received: DAVID WHARTON 12/19/25
3:16 PM

Signature: David Wharton

Lab Due: 12/22/25

Samplers Name: Vinson Zheng

Samplers Signature: Vin Zheng

JCB Project Manager: Bryan Ezrilia

12/23/25
Samp 200.5
12/23/25



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

ED57817

JCB #: 23-54650
Building: Great Hollow Middle School
GHMS

Client:
Smithtown Central School District

Retest/New Install

Turn Around: Normal 1 w/ Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
SMTH-3286	LR	1017	Boy's Locker Room	WC	11/26/2025	6:55:00 AM
SMTH-3288	LR	N/A	Girls Locker Room	WF	11/26/2025	7:40:00 AM
SMTH-3292	HA	2045	Corridor (Room 211-Room 231B)	DW	11/26/2025	7:59:00 AM
SMTH-3296	OF	2053	Room 204	HW	11/26/2025	8:11:00 AM
SMTH-3297	OF	2053	Room 204	IM	11/26/2025	8:12:00 AM
SMTH-3298	HA	2054	Corridor (Room 204-Room 210)	DW	11/26/2025	8:15:00 AM

Samples Submitted 42

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
DEC 19 25, PM03:16

Building Address

150 Southern Boulevard
Nesconset, NY 11767

Analysis Type: ELAP 200.5

Lab Received: DAVID WHARTON 10/19/25
3:16 PM

Signature: David Wharton

Samplers Name: Vinson Zheng

Samplers Signature: Vinson Zheng

JCB Project Manager: Bryan Ezelius

Pb200.8 2025 12/22/25

Pb 200.8 2025 12/22/25

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557817**LIMS Reference ID:** ED57817**EMSL Customer ID:** JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 23-54650 / Smithtown Central School District / Great Hollow Middle School GHMS / 150 Southern Boulevard, Nesconset, NY 11767
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/19/2025 15:16
Reported: 12/23/2025 12:52

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SMTM-0501									
Metals									
Lead	10.0		1	1.0	µg/L	12/20/25 15:10	12/20/25 15:10	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: SMTM-0502									
Metals									
Lead	6.2		1	1.0	µg/L	12/20/25 15:14	12/20/25 15:14	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: SMTM-0503									
Metals									
Lead	1.1		1	1.0	µg/L	12/20/25 15:15	12/20/25 15:15	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: SMTM-0504									
Metals									
Lead	8.0		1	1.0	µg/L	12/20/25 15:16	12/20/25 15:16	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: SMTM-0505									
Metals									
Lead	1.6		1	1.0	µg/L	12/20/25 15:18	12/20/25 15:18	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: SMTM-0506									
Metals									
Lead	94.6		1	1.0	µg/L	12/20/25 15:22	12/20/25 15:22	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: SMTM-0507									
Metals									
Lead	82.2		1	1.0	µg/L	12/20/25 15:23	12/20/25 15:23	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: SMTM-0508									
Metals									
Lead	5.1		1	1.0	µg/L	12/20/25 15:24	12/20/25 15:24	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: SMTM-0509									
Metals									

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557817**LIMS Reference ID:** ED57817**EMSL Customer ID:** JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 23-54650 / Smithtown Central School District / Great Hollow Middle School GHMS / 150 Southern Boulevard, Nesconset, NY 11767
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/19/2025 15:16
Reported: 12/23/2025 12:52

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SMTH-0509 (Continued)									Sampled: 11/26/25 00:00:00
Metals (Continued)									
Lead	182	9	9.0	µg/L	12/20/25 16:03	12/20/25 16:03	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-0510									Sampled: 11/26/25 00:00:00
Metals									
Lead	3.6	1	1.0	µg/L	12/20/25 15:27	12/20/25 15:27	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-0511									Sampled: 11/26/25 00:00:00
Metals									
Lead	2.9	1	1.0	µg/L	12/20/25 15:28	12/20/25 15:28	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-0512									Sampled: 11/26/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	12/20/25 15:32	12/20/25 15:32	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-0513									Sampled: 11/26/25 00:00:00
Metals									
Lead	1.2	1	1.0	µg/L	12/20/25 15:34	12/20/25 15:34	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-0527									Sampled: 11/26/25 00:00:00
Metals									
Lead	149	9	9.0	µg/L	12/20/25 16:10	12/20/25 16:10	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-0530									Sampled: 11/26/25 00:00:00
Metals									
Lead	11.9	1	1.0	µg/L	12/20/25 15:39	12/20/25 15:39	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-0531									Sampled: 11/26/25 00:00:00
Metals									
Lead	42.7	1	1.0	µg/L	12/20/25 15:40	12/20/25 15:40	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-0532									Sampled: 11/26/25 00:00:00
Metals									

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557817**LIMS Reference ID:** ED57817**EMSL Customer ID:** JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 23-54650 / Smithtown Central School District / Great Hollow Middle School GHMS / 150 Southern Boulevard, Nesconset, NY 11767
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/19/2025 15:16
Reported: 12/23/2025 12:52

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SMTM-0532 (Continued)									Sampled: 11/26/25 00:00:00
Metals (Continued)									
Lead	1.5	1	1.0	µg/L	12/23/25 11:39	12/23/25 11:39	BP	EPA 200.8 (Dig)/EPA 200.8	
Sample: SMTM-0545									Sampled: 11/26/25 00:00:00
Metals									
Lead	6.0	1	1.0	µg/L	12/20/25 15:42	12/20/25 15:42	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTM-0548									Sampled: 11/26/25 00:00:00
Metals									
Lead	18.6	1	1.0	µg/L	12/23/25 11:43	12/23/25 11:43	BP	EPA 200.8 (Dig)/EPA 200.8	
Sample: SMTM-0549									Sampled: 11/26/25 00:00:00
Metals									
Lead	11.7	1	1.0	µg/L	12/20/25 15:43	12/20/25 15:43	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTM-0550									Sampled: 11/26/25 00:00:00
Metals									
Lead	1.1	1	1.0	µg/L	12/20/25 15:44	12/20/25 15:44	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTM-0551									Sampled: 11/26/25 00:00:00
Metals									
Lead	4.8	1	1.0	µg/L	12/20/25 15:45	12/20/25 15:45	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTM-0552									Sampled: 11/26/25 00:00:00
Metals									
Lead	1.8	1	1.0	µg/L	12/22/25 18:37	12/22/25 18:37	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTM-0553									Sampled: 11/26/25 00:00:00
Metals									
Lead	31.6	1	1.0	µg/L	12/23/25 11:45	12/23/25 11:45	BP	EPA 200.8 (Dig)/EPA 200.8	
Sample: SMTM-0557									Sampled: 11/26/25 00:00:00
Metals									

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
 Telephone: 516.997.7251 Fax: 856-786-5974
 EMSL-CP-06

EMSL Order ID: 062557817**LIMS Reference ID:** ED57817**EMSL Customer ID:** JCBR50

Attention: Bryan Ezelius
 J.C. Broderick & Associates [JCBR50]
 1775 Expressway Drive North, Suite 1
 Hauppauge, NY 11788
 (631) 584-5492
 bezelius@jcbroderick.com

Project Name: 23-54650 / Smithtown Central School District / Great Hollow Middle School GHMS / 150 Southern Boulevard, Nesconset, NY 11767
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/19/2025 15:16
Reported: 12/23/2025 12:52

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SMTM-0557 (Continued)									Sampled: 11/26/25 00:00:00
Metals (Continued)									
Lead	34.6		1	1.0	µg/L	12/22/25 18:41	12/22/25 18:41	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: SMTM-0560									Sampled: 11/26/25 00:00:00
Metals									
Lead	< 1.0		1	1.0	µg/L	12/22/25 18:43	12/22/25 18:43	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: SMTM-0561									Sampled: 11/26/25 00:00:00
Metals									
Lead	< 1.0		1	1.0	µg/L	12/22/25 18:44	12/22/25 18:44	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: SMTM-0578									Sampled: 11/26/25 00:00:00
Metals									
Lead	< 1.0		1	1.0	µg/L	12/22/25 18:45	12/22/25 18:45	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: SMTM-0611									Sampled: 11/26/25 00:00:00
Metals									
Lead	< 1.0		1	1.0	µg/L	12/22/25 18:47	12/22/25 18:47	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: SMTM-1922									Sampled: 11/26/25 00:00:00
Metals									
Lead	1.2		1	1.0	µg/L	12/22/25 18:48	12/22/25 18:48	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: SMTM-3086									Sampled: 11/26/25 00:00:00
Metals									
Lead	< 1.0		1	1.0	µg/L	12/22/25 18:49	12/22/25 18:49	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: SMTM-3087									Sampled: 11/26/25 00:00:00
Metals									
Lead	< 1.0		1	1.0	µg/L	12/22/25 18:51	12/22/25 18:51	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: SMTM-3094									Sampled: 11/26/25 00:00:00
Metals									
Lead	< 1.0		1	1.0	µg/L	12/22/25 18:51	12/22/25 18:51	KT1	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
 Telephone: 516.997.7251 Fax: 856-786-5974
 EMSL-CP-06

EMSL Order ID: 062557817**LIMS Reference ID:** ED57817**EMSL Customer ID:** JCBR50

Attention: Bryan Ezelius
 J.C. Broderick & Associates [JCBR50]
 1775 Expressway Drive North, Suite 1
 Hauppauge, NY 11788
 (631) 584-5492
 bezelius@jcbroderick.com

Project Name: 23-54650 / Smithtown Central School District / Great Hollow Middle School GHMS / 150 Southern Boulevard, Nesconset, NY 11767
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/19/2025 15:16
Reported: 12/23/2025 12:52

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SMTM-3094 (Continued)									Sampled: 11/26/25 00:00:00
Metals (Continued)									
Lead	3.5	1	1.0	µg/L	12/22/25 19:18	12/22/25 19:18	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTM-3283									Sampled: 11/26/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	12/22/25 19:19	12/22/25 19:19	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTM-3284									Sampled: 11/26/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	12/22/25 19:21	12/22/25 19:21	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTM-3285									Sampled: 11/26/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	12/22/25 19:22	12/22/25 19:22	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTM-3286									Sampled: 11/26/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	12/22/25 19:23	12/22/25 19:23	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTM-3288									Sampled: 11/26/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	12/22/25 19:27	12/22/25 19:27	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTM-3292									Sampled: 11/26/25 00:00:00
Metals									
Lead	29.3	1	1.0	µg/L	12/22/25 19:31	12/22/25 19:31	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTM-3296									Sampled: 11/26/25 00:00:00
Metals									
Lead	7.6	1	1.0	µg/L	12/23/25 11:46	12/23/25 11:46	BP	EPA 200.8 (Dig)/EPA 200.8	
Sample: SMTM-3297									Sampled: 11/26/25 00:00:00
Metals									



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557817

LIMS Reference ID: ED57817

EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 23-54650 / Smithtown Central School District / Great Hollow Middle School GHMS / 150 Southern Boulevard, Nesconset, NY 11767
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/19/2025 15:16
Reported: 12/23/2025 12:52

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SMTH-3297 (Continued)									
Metals (Continued)									
Lead									
1.8									
Sample: SMTH-3298									
Metals									
Lead									
1.0									
Lims Reference ID: ED57817-41 Matrix: Drinking Water									
Sampled: 11/26/25 00:00:00									
Lims Reference ID: ED57817-42 Matrix: Drinking Water									
Sampled: 11/26/25 00:00:00									



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557817

LIMS Reference ID: ED57817

EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 23-54650 / Smithtown Central School District / Great Hollow Middle School GHMS / 150 Southern Boulevard, Nesconset, NY 11767
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/19/2025 15:16
Reported: 12/23/2025 12:52

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com for a complete listing of parameters for which EMSL is certified.



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557817

LIMS Reference ID: ED57817

EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 23-54650 / Smithtown Central School District / Great Hollow Middle School GHMS / 150 Southern Boulevard, Nesconset, NY 11767
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/19/2025 15:16
Reported: 12/23/2025 12:52

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #:

23-54650

Building: Barton Administration Annex

NYAA

Courier

EDS 7651

Page 1 of 1

Client:

Smithtown Central School District

Retest/New Install

Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
SMTH-1261	CR	1521	Multi Purpose Kitchen	KC	12/11/2025	6:27:00 AM
SMTH-1269	OF	2500D	Room 225A	KC	12/11/2025	6:30:00 AM
SMTH-1272	OF	0009D	Room Across from Room 4 Office	KC	12/11/2025	6:34:00 AM

Samples Submitted 3

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
DEC 11 25, PM01:47

Pb 200.8
Kastliolow
12/15/25

Building Address

26 New York Avenue
Smithtown, NY 11787

Analysis Type: ELAP 200.5

Lab Received:

Signature:

Samplers Name: Vinson Zhang

Samplers Signature: V. Zhang

JCB Project Manager: bryan Eccles

Page 4 of 4

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557651**LIMS Reference ID:** ED57651**EMSL Customer ID:** JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 26 New York Avenue Smithtown NY 11787, Barton Administration Annex, JCB#:23-54650, Smithtown Central School District
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/11/2025 13:47
Reported: 12/23/2025 10:44

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SMTH-1261									
Metals									
Lead	9.6		1	1.0	µg/L	12/15/25 17:42	12/15/25 17:42	KT1	EPA 200.8 (Dig)/EPA 200.8
Sample: SMTH-1269									
Metals									
Lead	6.5		1	1.0	µg/L	12/13/25 12:17	12/13/25 12:17	JH	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH-1272									
Metals									
Lead	1.2		1	1.0	µg/L	12/13/25 12:18	12/13/25 12:18	JH	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557651**LIMS Reference ID:** ED57651**EMSL Customer ID:** JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 26 New York Avenue Smithtown NY 11787, Barton Administration Annex, JCB#:23-54650, Smithtown Central School District
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/11/2025 13:47
Reported: 12/23/2025 10:44

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com for a complete listing of parameters for which EMSL is certified.



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557651

LIMS Reference ID: ED57651

EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 26 New York Avenue Smithtown NY 11787, Barton Administration Annex, JCB#:23-54650, Smithtown Central School District
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/11/2025 13:47
Reported: 12/23/2025 10:44


Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

ED57684

RECEIVED

Page 1 of 4

EMSL ANALYTICAL, INC.

Client: Smithtown Central School District, NY

Address: 100 Central Plaza, NY

Phone: (631) 273-2200

Facsimile: (631) 273-2201

EMail: info@emsl.com

Retest/New Install:

Turn Around: Normal 1 wk Rush

Date: DEC 12 25, PM01:35

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
SMTH-1537	HE	1073	Room A102	EC	12/6/2025	6:10:00 AM
SMTH-1538	HE	1073	Room A102	EC	12/6/2025	6:10:00 AM
SMTH-1540	NO	1075	Nurse Suite	KC	12/6/2025	6:15:00 AM
SMTH-1541	NO	1075	Nurse Suite	KC	12/6/2025	6:15:00 AM
SMTH-1543	HA	1078	Corridor 1078 o/s 1074	WF	12/6/2025	6:18:00 AM
SMTH-1544	HA	1078	Corridor 1078 o/s 1074	DW	12/6/2025	6:18:00 AM
SMTH-1545	CR	1076	Room A101	EC	12/6/2025	6:19:00 AM
SMTH-1547	CR	1076	Room A101	EC	12/6/2025	6:20:00 AM
SMTH-1549	CR	1076	Room A101	EC	12/6/2025	6:23:00 AM
SMTH-1550	CR	1076	Room A101	EC	12/6/2025	6:23:00 AM
SMTH-1552	OF	1079K	Main Office Workroom	KC	12/6/2025	6:25:00 AM
SMTH-1558	BR	1053	Custodial	KC	12/6/2025	6:27:00 AM
SMTH-1560	OF	1051	Break Room	KC	12/6/2025	6:28:00 AM
SMTH-1562	KI	1046	Kitchen	HW	12/6/2025	6:30:00 AM
SMTH-1563	KI	1046	Kitchen	KC	12/6/2025	6:31:00 AM
SMTH-1564	KI	1046	Kitchen	SN	12/6/2025	6:31:00 AM
SMTH-1565	KI	1046	Kitchen	KC	12/6/2025	6:31:00 AM
SMTH-1566	KI	1046	Kitchen	HW	12/6/2025	6:33:00 AM

Building Address

100 Central Road
Smithtown, NY 11787

Analysis Type: ELAP 200.5

Lab Received: Abigail Minnfield


Signature: A. Minnfield

Samplers Name: Vincent Zhou

Samplers Signature: Vin. Zhou

JCB Project Manager: Bryan Ezelus

Courier



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #:

23-54650

Building: Smithtown High School West

SMW

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
SMTH-1568	CA	1045	Faculty Dining	KC	12/6/2025	6:35:00 AM
SMTH-1572	HA	1107	Corridor 1107 o/s 1081	DW	12/6/2025	6:37:00 AM
SMTH-1741	HA	1138	Corridor (Wrestling Room-Exit)	DW	12/6/2025	6:50:00 AM
SMTH-1751	BR	1003A	Guidance Suite B Conference Room	KC	12/6/2025	6:57:00 AM
SMTH-1758	CA	1018	Cafeteria F	WC	12/6/2025	7:16:00 AM
SMTH-1759	CA	1018	Cafeteria F	WF	12/6/2025	7:16:00 AM
SMTH-1770	CA	1031	Cafeteria E	WC	12/6/2025	7:28:00 AM
SMTH-1771	CA	1031	Cafeteria E	WF	12/6/2025	7:28:00 AM
SMTH-1772	KI	1032	Kitchen E	KC	12/6/2025	7:32:00 AM
SMTH-1773	KI	1032	Kitchen E	SN	12/6/2025	7:32:00 AM
SMTH-1774	KI	1032	Kitchen E	HW	12/6/2025	7:32:00 AM
SMTH-1775	HA	2096	Corridor Outside Auditorium	WC	12/6/2025	7:55:00 AM
SMTH-1776	HA	2096	Corridor Outside Auditorium	WF	12/6/2025	7:56:00 AM
SMTH-1786	HA	2086	Corridor by Room A208	KC	12/6/2025	8:03:00 AM
SMTH-1790	HA	2092	Corridor by Stage	DW	12/6/2025	8:06:00 AM
SMTH-1791	HA	2096	Corridor by Library Conference Room 3	WC	12/6/2025	8:09:00 AM
SMTH-1792	HA	2096	Corridor by Library Conference Room 3	WF	12/6/2025	8:09:00 AM
SMTH-1799	HA	2109	Corridor Outside Auxiliary Gym	WC	12/6/2025	8:20:00 AM

Building Address

100 Central Road

Smithtown, NY 11787

Analysis Type: ELAP 200.5


Lab Received: Abigail Minnfield

Signature: A. Mysel

Samplers Name: Vinson Zheng

Samplers Signature: Van Zee

JCB Project Manager: Bryan Erdius



Lead in Water: Chain of Custody for **ED57684**

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #:

23-54650

Building: Smithtown High School West

SMW

Client:

RECEIVED

EMSL ANALYTICAL, INC.
Smithtown Central School District
Carrie Place, NY

Retest/New Install **DEC 12 25, PM01:36**

Turn Around: **Normal Wk Rush**

PC 200-8 Blng 12/16/25

PC 200-8 Blng 12/16/25

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
SMTH-1800	HA	2109	Corridor Outside Auxiliary Gym	WF	12/6/2025	8:20:00 AM
SMTH-1802	OF	2060A	Material Production	KC	12/6/2025	8:14:00 AM
SMTH-1803	LI	2063A	Library Office	KC	12/6/2025	8:12:00 AM
SMTH-1805	OF	2048A	English Office Material Production	KC	12/6/2025	8:16:00 AM
SMTH-1806	HA	2064	Corridor Outside Library	DW	12/6/2025	7:53:00 AM
SMTH-1809	HA	2036	Corridor Between Tower F & Tower E	DW	12/6/2025	7:48:00 AM
SMTH-1814	HA	2019	Corridor Between Tower G & Tower F	DW	12/6/2025	7:43:00 AM
SMTH-1817	HA	3032	Corridor by Women's Bathroom	DW	12/6/2025	8:40:00 AM
SMTH-1821	HA	3016	Corridor by Women's Bathroom	DW	12/6/2025	8:47:00 AM
SMTH-1860	ST	2104	Auxiliary Gym IM Room	IM	12/6/2025	8:27:00 AM
SMTH-2494	NO	1075	Nurse Suite	IM	12/6/2025	6:15:00 AM
SMTH-2542	HA	1006	Corridor by Room G102	DW	12/6/2025	6:54:00 AM
SMTH-2543	OF	1003A	Guidance Suite B Conference Room	SN	12/6/2025	6:57:00 AM
SMTH-3259	KI	1019	Kitchen F	HW	12/6/2025	7:18:00 AM
SMTH-3260	KI	1010	Kitchen G	HW	12/6/2025	7:04:00 AM
SMTH-3300	CR	1092	Prep Room	IM	12/6/2025	6:43:00 AM
SMTH-3301	HA	1107	Corridor 1107 o/s 1100	DW	12/6/2025	6:47:00 AM
SMTH-3302	HA	1039	Corridor (Room E101-Cafeteria E)	WC	12/6/2025	7:22:00 AM

Building Address

100 Central Road

Smithtown, NY 11787

Analysis Type: ELAP 200.5


Lab Received: A. Minnfield

Signature: A. Minnfield

Samplers Name: Vinton Zheng

Samplers Signature: V. Zheng

JCB Project Manager: Bryan Ezelius



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #:

23-54650

Building: Smithtown High School West

SMW

ED57684

Client:

Smithtown Central School District

RECEIVED
ENSL ANALYTICAL, INC.

Retest/New Install Carle Place, NY
Turn Around: Normal Work Rush

12/25, PM01:36

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
SMTH-3303	OF	1029	Attendance Office	BW	12/6/2025	7:26:00 AM
SMTH-3344	CA	1011	Cafeteria G	WF	12/6/2025	7:06:00 AM
SMTH-3345	CA	1011	Cafeteria G	WC	12/6/2025	7:06:00 AM
SMTH-3346	HA	1025	Corridor (Room F101-Cafeteria F)	WF	12/6/2025	7:11:00 AM
SMTH-3347	HA	1025	Corridor (Room F101-Cafeteria F)	WC	12/6/2025	7:11:00 AM

Samples Submitted 59

PC
200.8
12/16/125

PC
200.8
12/16/125

Building Address

100 Central Road
Smithtown, NY 11787

Analysis Type: ELAP 200.5

Lab Received: A. Minnifield

Signature: A. Minnifield

Samplers Name: Vinson Zheng

Samplers Signature: Vin Zheng

JCB Project Manager: Bryan Ezeius

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557684**LIMS Reference ID:** ED57684**EMSL Customer ID:** JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 23-54650 / Smithtown High School West / SMW /
Smithtown Central School District / 100 Central
Road, Smithtown, NY 11787
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/12/2025 13:35
Reported: 12/23/2025 10:46

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SMTH- 1537									Sampled: 12/06/25 00:00:00
Metals									
Lead	26.1		1	1.0	µg/L	12/15/25 20:03	12/15/25 20:03	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH- 1538									Sampled: 12/06/25 00:00:00
Metals									
Lead	24.5		1	1.0	µg/L	12/16/25 10:37	12/16/25 10:37	BP	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH- 1540									Sampled: 12/06/25 00:00:00
Metals									
Lead	5.3		1	1.0	µg/L	12/16/25 10:41	12/16/25 10:41	BP	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH- 1541									Sampled: 12/06/25 00:00:00
Metals									
Lead	5.4		1	1.0	µg/L	12/16/25 10:42	12/16/25 10:42	BP	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH- 1543									Sampled: 12/06/25 00:00:00
Metals									
Lead	< 1.0		1	1.0	µg/L	12/16/25 10:43	12/16/25 10:43	BP	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH- 1544									Sampled: 12/06/25 00:00:00
Metals									
Lead	< 1.0		1	1.0	µg/L	12/16/25 10:47	12/16/25 10:47	BP	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH- 1545									Sampled: 12/06/25 00:00:00
Metals									
Lead	10.2		1	1.0	µg/L	12/16/25 10:49	12/16/25 10:49	BP	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH- 1547									Sampled: 12/06/25 00:00:00
Metals									
Lead	1.9		1	1.0	µg/L	12/16/25 10:50	12/16/25 10:50	BP	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH- 1549									Sampled: 12/06/25 00:00:00
Metals									

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557684**LIMS Reference ID:** ED57684**EMSL Customer ID:** JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 23-54650 / Smithtown High School West / SMW /
Smithtown Central School District / 100 Central
Road, Smithtown, NY 11787
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/12/2025 13:35
Reported: 12/23/2025 10:46

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SMTH- 1549 (Continued)									Sampled: 12/06/25 00:00:00
Metals (Continued)									
Lead	1.5	1	1.0	µg/L	12/16/25 10:51	12/16/25 10:51	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH- 1550									Sampled: 12/06/25 00:00:00
Metals									
Lead	3.7	1	1.0	µg/L	12/16/25 10:53	12/16/25 10:53	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH- 1552									Sampled: 12/06/25 00:00:00
Metals									
Lead	33.7	1	1.0	µg/L	12/16/25 10:54	12/16/25 10:54	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH- 1558									Sampled: 12/06/25 00:00:00
Metals									
Lead	1.9	1	1.0	µg/L	12/16/25 10:55	12/16/25 10:55	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH- 1560									Sampled: 12/06/25 00:00:00
Metals									
Lead	16.0	1	1.0	µg/L	12/16/25 10:59	12/16/25 10:59	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH- 1562									Sampled: 12/06/25 00:00:00
Metals									
Lead	4.1	1	1.0	µg/L	12/16/25 11:03	12/16/25 11:03	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH- 1563									Sampled: 12/06/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	12/16/25 11:04	12/16/25 11:04	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH- 1564									Sampled: 12/06/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	12/16/25 11:06	12/16/25 11:06	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH- 1565									Sampled: 12/06/25 00:00:00
Metals									

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557684**LIMS Reference ID:** ED57684**EMSL Customer ID:** JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 23-54650 / Smithtown High School West / SMW /
Smithtown Central School District / 100 Central
Road, Smithtown, NY 11787
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/12/2025 13:35
Reported: 12/23/2025 10:46

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SMTH- 1565 (Continued)									Sampled: 12/06/25 00:00:00
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	12/16/25 11:07	12/16/25 11:07	BP	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH- 1566									Sampled: 12/06/25 00:00:00
Metals									
Lead	4.3		1	1.0	µg/L	12/16/25 11:08	12/16/25 11:08	BP	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH- 1568									Sampled: 12/06/25 00:00:00
Metals									
Lead	4.7		1	1.0	µg/L	12/16/25 11:10	12/16/25 11:10	BP	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH- 1572									Sampled: 12/06/25 00:00:00
Metals									
Lead	4.4		1	1.0	µg/L	12/16/25 11:11	12/16/25 11:11	BP	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH- 1741									Sampled: 12/06/25 00:00:00
Metals									
Lead	6.7		1	1.0	µg/L	12/16/25 11:12	12/16/25 11:12	BP	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH- 1751									Sampled: 12/06/25 00:00:00
Metals									
Lead	2.6		1	1.0	µg/L	12/16/25 11:26	12/16/25 11:26	BP	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH- 1758									Sampled: 12/06/25 00:00:00
Metals									
Lead	< 1.0		1	1.0	µg/L	12/16/25 11:30	12/16/25 11:30	BP	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH- 1759									Sampled: 12/06/25 00:00:00
Metals									
Lead	1.3		1	1.0	µg/L	12/16/25 11:31	12/16/25 11:31	BP	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH- 1770									Sampled: 12/06/25 00:00:00
Metals									

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557684**LIMS Reference ID:** ED57684**EMSL Customer ID:** JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 23-54650 / Smithtown High School West / SMW /
Smithtown Central School District / 100 Central
Road, Smithtown, NY 11787
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/12/2025 13:35
Reported: 12/23/2025 10:46

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SMTH- 1770 (Continued)									Sampled: 12/06/25 00:00:00
Metals (Continued)									
Lead	< 1.0	1	1.0	µg/L	12/16/25 11:33	12/16/25 11:33	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH- 1771									Sampled: 12/06/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	12/16/25 11:37	12/16/25 11:37	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH- 1772									Sampled: 12/06/25 00:00:00
Metals									
Lead	2.9	1	1.0	µg/L	12/16/25 11:38	12/16/25 11:38	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH- 1773									Sampled: 12/06/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	12/16/25 11:39	12/16/25 11:39	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH- 1774									Sampled: 12/06/25 00:00:00
Metals									
Lead	3.0	1	1.0	µg/L	12/16/25 11:41	12/16/25 11:41	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH- 1775									Sampled: 12/06/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	12/16/25 11:42	12/16/25 11:42	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH- 1776									Sampled: 12/06/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	12/16/25 11:43	12/16/25 11:43	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH- 1786									Sampled: 12/06/25 00:00:00
Metals									
Lead	3.0	1	1.0	µg/L	12/16/25 11:45	12/16/25 11:45	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH- 1790									Sampled: 12/06/25 00:00:00
Metals									

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557684**LIMS Reference ID:** ED57684**EMSL Customer ID:** JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 23-54650 / Smithtown High School West / SMW /
Smithtown Central School District / 100 Central
Road, Smithtown, NY 11787
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/12/2025 13:35
Reported: 12/23/2025 10:46

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SMTH- 1790 (Continued)									Sampled: 12/06/25 00:00:00
Metals (Continued)									
Lead	3.5		1	1.0	µg/L	12/16/25 11:49	12/16/25 11:49	BP	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH- 1791									Sampled: 12/06/25 00:00:00
Metals									
Lead	< 1.0		1	1.0	µg/L	12/16/25 11:53	12/16/25 11:53	BP	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH- 1792									Sampled: 12/06/25 00:00:00
Metals									
Lead	< 1.0		1	1.0	µg/L	12/16/25 11:54	12/16/25 11:54	BP	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH- 1799									Sampled: 12/06/25 00:00:00
Metals									
Lead	< 1.0		1	1.0	µg/L	12/16/25 11:55	12/16/25 11:55	BP	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH- 1800									Sampled: 12/06/25 00:00:00
Metals									
Lead	< 1.0		1	1.0	µg/L	12/16/25 11:56	12/16/25 11:56	BP	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH- 1802									Sampled: 12/06/25 00:00:00
Metals									
Lead	2.1		1	1.0	µg/L	12/16/25 11:58	12/16/25 11:58	BP	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH- 1803									Sampled: 12/06/25 00:00:00
Metals									
Lead	3.6		1	1.0	µg/L	12/16/25 11:59	12/16/25 11:59	BP	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH- 1805									Sampled: 12/06/25 00:00:00
Metals									
Lead	3.3		1	1.0	µg/L	12/16/25 12:00	12/16/25 12:00	BP	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH- 1806									Sampled: 12/06/25 00:00:00
Metals									

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557684**LIMS Reference ID:** ED57684**EMSL Customer ID:** JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 23-54650 / Smithtown High School West / SMW /
Smithtown Central School District / 100 Central
Road, Smithtown, NY 11787
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/12/2025 13:35
Reported: 12/23/2025 10:46

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SMTH- 1806 (Continued)									Sampled: 12/06/25 00:00:00
Metals (Continued)									
Lead	4.4	1	1.0	µg/L	12/16/25 12:02	12/16/25 12:02	BP	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH- 1809									Sampled: 12/06/25 00:00:00
Metals									
Lead	5.4	1	1.0	µg/L	12/16/25 12:54	12/16/25 12:54	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH- 1814									Sampled: 12/06/25 00:00:00
Metals									
Lead	2.0	1	1.0	µg/L	12/16/25 12:58	12/16/25 12:58	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH- 1817									Sampled: 12/06/25 00:00:00
Metals									
Lead	5.2	1	1.0	µg/L	12/16/25 12:59	12/16/25 12:59	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH- 1821									Sampled: 12/06/25 00:00:00
Metals									
Lead	7.3	1	1.0	µg/L	12/16/25 13:01	12/16/25 13:01	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH- 1860									Sampled: 12/06/25 00:00:00
Metals									
Lead	1.5	1	1.0	µg/L	12/20/25 11:45	12/20/25 11:45	JH	EPA 200.8 (Dig)/EPA 200.8	
Sample: SMTH- 2494									Sampled: 12/06/25 00:00:00
Metals									
Lead	1.8	1	1.0	µg/L	12/16/25 13:05	12/16/25 13:05	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH- 2542									Sampled: 12/06/25 00:00:00
Metals									
Lead	4.4	1	1.0	µg/L	12/16/25 13:06	12/16/25 13:06	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH- 2543									Sampled: 12/06/25 00:00:00
Metals									

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557684**LIMS Reference ID:** ED57684**EMSL Customer ID:** JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 23-54650 / Smithtown High School West / SMW /
Smithtown Central School District / 100 Central
Road, Smithtown, NY 11787
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/12/2025 13:35
Reported: 12/23/2025 10:46

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SMTH- 2543 (Continued)									Sampled: 12/06/25 00:00:00
Metals (Continued)									
Lead	5.4	1	1.0	µg/L	12/16/25 13:07	12/16/25 13:07	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH- 3259									Sampled: 12/06/25 00:00:00
Metals									
Lead	1.4	1	1.0	µg/L	12/16/25 13:09	12/16/25 13:09	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH- 3260									Sampled: 12/06/25 00:00:00
Metals									
Lead	4.4	1	1.0	µg/L	12/16/25 13:10	12/16/25 13:10	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH- 3300									Sampled: 12/06/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	12/20/25 11:47	12/20/25 11:47	JH	EPA 200.8 (Dig)/EPA 200.8	
Sample: SMTH- 3301									Sampled: 12/06/25 00:00:00
Metals									
Lead	1.2	1	1.0	µg/L	12/16/25 13:11	12/16/25 13:11	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH- 3302									Sampled: 12/06/25 00:00:00
Metals									
Lead	5.0	1	1.0	µg/L	12/16/25 13:12	12/16/25 13:12	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH- 3303									Sampled: 12/06/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	12/16/25 13:16	12/16/25 13:16	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH- 3344									Sampled: 12/06/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	12/16/25 13:20	12/16/25 13:20	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH- 3345									Sampled: 12/06/25 00:00:00
Metals									

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557684**LIMS Reference ID:** ED57684**EMSL Customer ID:** JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 23-54650 / Smithtown High School West / SMW /
Smithtown Central School District / 100 Central
Road, Smithtown, NY 11787
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/12/2025 13:35
Reported: 12/23/2025 10:46

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SMTH- 3345 (Continued)									
Metals (Continued)									
Lead < 1.0 1 1.0 µg/L 12/16/25 13:22 12/16/25 13:22 KT1 EPA 200.8 (DA)/EPA 200.8									
Sample: SMTH- 3346									
Metals									
Lead < 1.0 1 1.0 µg/L 12/16/25 13:23 12/16/25 13:23 KT1 EPA 200.8 (DA)/EPA 200.8									
Sample: SMTH- 3347									
Metals									
Lead < 1.0 1 1.0 µg/L 12/16/25 13:24 12/16/25 13:24 KT1 EPA 200.8 (DA)/EPA 200.8									

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557684

LIMS Reference ID: ED57684

EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 23-54650 / Smithtown High School West / SMW /
Smithtown Central School District / 100 Central
Road, Smithtown, NY 11787
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/12/2025 13:35
Reported: 12/23/2025 10:46

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com for a complete listing of parameters for which EMSL is certified.



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557684

LIMS Reference ID: ED57684

EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 23-54650 / Smithtown High School West / SMW /
Smithtown Central School District / 100 Central
Road, Smithtown, NY 11787
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/12/2025 13:35
Reported: 12/23/2025 10:46

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #:

23-54650

Building: Mount Pleasant Elementary School

MPE

ED57690

Page 1 of 2

Client:

Smithtown Central School District

Retest/New Install

Turn Around: Normal 1 wk Rush

Carle

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
SMTH-1827	OF	1031A	Main Office Supply Room	KC	12/12/2025	5:47:00 AM
SMTH-1848	LI	1029	Library	KC	12/12/2025	5:58:00 AM
SMTH-2086	HA	NA	Corridor by Room 14 & 15 (Formerly by 12)	WF	12/12/2025	6:01:00 AM
SMTH-2096	HA	1013	Corridor by Room 31	WC	12/12/2025	6:10:00 AM
SMTH-2097	HA	1013	Corridor by Room 31	WF	12/12/2025	6:10:00 AM
SMTH-2100	KI	NA	KITCHEN	HW	12/12/2025	6:18:00 AM
SMTH-2101	KI	NA	KITCHEN	KC	12/12/2025	6:18:00 AM
SMTH-2102	KI	NA	KITCHEN	KC	12/12/2025	6:19:00 AM
SMTH-2103	KI	NA	KITCHEN	SN	12/12/2025	6:19:00 AM
SMTH-2105	FL	NA	FACULTY	KC	12/12/2025	6:21:00 AM
SMTH-3306	HA	1028	Main Lobby o/s Women's Bathroom	WC	12/12/2025	5:45:00 AM
SMTH-3307	HA	1028	Main Lobby o/s Women's Bathroom	WF	12/12/2025	5:45:00 AM
SMTH-3308	OF	1031B	Principal's Office	BWC	12/12/2025	6:35:00 AM
SMTH-3309	OF	1031B	Principal's Office	BWH	12/12/2025	6:35:00 AM
SMTH-3310	HA	N/A	Corridor o/s Room 45	WC	12/12/2025	6:25:00 AM
SMTH-3311	HA	N/A	Corridor o/s Room 45	WF	12/12/2025	6:25:00 AM

RECEIVED

ENSL ANALYTICAL, INC.

Carle Place, NY

DEC 12 25, PM01:36

Building Address

33 Plaisted Avenue

Smithtown, NY 11787

Analysis Type: ELAP 200.5

Lab Received: S. Chervofsky 12/12/25

Signature: S. Chervofsky 1:36pm


Samplers Name: Jarett Bonface

Samplers Signature: J. Bonface

JCB Project Manager:

Bryan Erc

Page 5 of 6



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
 1775 Expressway North Hauppauge, NY 11788
 TEL: (631) 584-5492 FAX: (631) 584-3395

ED57690

Page 2 of 2

JCB #: 23-54650
 Building: Mount Pleasant Elementary School
 MPE

Client: Smithtown Central School District
 Retest/New Install
 Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
-----------	-----------------------	----------	------------------	-------------	-------------	-------------

Samples Submitted 16

RECEIVED
 EMSL ANALYTICAL, INC.
 Carle Place, NY
 DEC 12 25, PM01:36

Building Address
 33 Plaisted Avenue
 Smithtown, NY 11787

Analysis Type: ELAP 200.5
 Lab Received: S. Chervotsky 12/12/25
 Signature: S. Chervotsky 1:36 PM

Samplers Name: Jarett Boniface
 Samplers Signature:
 JCB Project Manager: Bryan Ezelius

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
 Telephone: 516.997.7251 Fax: 856-786-5974
 EMSL-CP-06

EMSL Order ID: 062557690**LIMS Reference ID:** ED57690**EMSL Customer ID:** JCBR50

Attention: Bryan Ezelius
 J.C. Broderick & Associates [JCBR50]
 1775 Expressway Drive North, Suite 1
 Hauppauge, NY 11788
 (631) 584-5492
 bezelius@jcbroderick.com

Project Name: JCB# 23-54650, Smithtown Central School District,
 Mount Pleasant Elementary School, 33 Plaisted
 Avenue Smithtown, NY 11787

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeremy Bish

Received: 12/12/2025 13:36

Reported: 12/23/2025 10:49

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SMTH-1827									
Metals									
Lead	1.4	1	1.0	µg/L	12/13/25 12:59	12/13/25 12:59	JH	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-1848									
Metals									
Lead	1.1	1	1.0	µg/L	12/13/25 13:00	12/13/25 13:00	JH	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-2086									
Metals									
Lead	9.2	1	1.0	µg/L	12/13/25 13:02	12/13/25 13:02	JH	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-2096									
Metals									
Lead	< 1.0	1	1.0	µg/L	12/13/25 13:03	12/13/25 13:03	JH	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-2097									
Metals									
Lead	< 1.0	1	1.0	µg/L	12/13/25 13:07	12/13/25 13:07	JH	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-2100									
Metals									
Lead	< 1.0	1	1.0	µg/L	12/13/25 13:08	12/13/25 13:08	JH	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-2101									
Metals									
Lead	5.5	1	1.0	µg/L	12/13/25 13:10	12/13/25 13:10	JH	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-2102									
Metals									
Lead	2.0	1	1.0	µg/L	12/13/25 13:11	12/13/25 13:11	JH	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-2103									
Metals									

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557690**LIMS Reference ID:** ED57690**EMSL Customer ID:** JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: JCB# 23-54650, Smithtown Central School District,
Mount Pleasant Elementary School, 33 Plaisted
Avenue Smithtown, NY 11787

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeremy Bish

Received: 12/12/2025 13:36

Reported: 12/23/2025 10:49

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SMTH-2103 (Continued)									
Metals (Continued)									
Lead	3.3	1	1.0	µg/L	12/13/25 13:12	12/13/25 13:12	JH	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-2105									
Metals									
Lead	3.7	1	1.0	µg/L	12/13/25 13:14	12/13/25 13:14	JH	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-3306									
Metals									
Lead	< 1.0	1	1.0	µg/L	12/13/25 13:18	12/13/25 13:18	JH	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-3307									
Metals									
Lead	< 1.0	1	1.0	µg/L	12/13/25 13:19	12/13/25 13:19	JH	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-3308									
Metals									
Lead	< 1.0	1	1.0	µg/L	12/13/25 13:23	12/13/25 13:23	JH	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-3309									
Metals									
Lead	< 1.0	1	1.0	µg/L	12/13/25 13:24	12/13/25 13:24	JH	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-3310									
Metals									
Lead	< 1.0	1	1.0	µg/L	12/13/25 13:25	12/13/25 13:25	JH	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-3311									
Metals									
Lead	< 1.0	1	1.0	µg/L	12/13/25 13:27	12/13/25 13:27	JH	EPA 200.8 (DA)/EPA 200.8	

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557690

LIMS Reference ID: ED57690

EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: JCB# 23-54650, Smithtown Central School District,
Mount Pleasant Elementary School, 33 Plaisted
Avenue Smithtown, NY 11787
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/12/2025 13:36
Reported: 12/23/2025 10:49

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com for a complete listing of parameters for which EMSL is certified.

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557690

LIMS Reference ID: ED57690

EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: JCB# 23-54650, Smithtown Central School District,
Mount Pleasant Elementary School, 33 Plaisted
Avenue Smithtown, NY 11787
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/12/2025 13:36
Reported: 12/23/2025 10:49

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492

FAX: (631) 584-3395

JCB #:

23-54650

Building: Tackan Elementary School

TAC



ED 57614

Page 1 of 2

Client:

Smithtown Central School District

Retest/New Install

Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	RECEIVED EMSL ANALYTICAL INC. Carrie Place, Nr DEC 10 25, PM 01:53	Outlet Type	Sample Date	Sample Time
SMTH-0661	LI	1037	LIBRARY		KC	12/4/2025	6:09:00 AM
SMTH-0662	NO	1042	NURSES OFFICE		KC	12/4/2025	5:52:00 AM
SMTH-0665	HA	1036	Main Lobby		WC	12/4/2025	6:13:00 AM
SMTH-0670	HA	NA	CLASSROOM 12A		WC	12/4/2025	6:01:00 AM
SMTH-0671	HA	NA	CLASSROOM 12A		WF	12/4/2025	6:01:00 AM
SMTH-0673	CR	1049	Room 17 (Formerly Classroom 7)		KC	12/4/2025	7:19:00 AM
SMTH-0674	FL	NA	FACULTY		KC	12/4/2025	6:47:00 AM
SMTH-0676	KI	NA	KITCHEN		SN	12/4/2025	6:32:00 AM
SMTH-0677	KI	NA	KITCHEN		HW	12/4/2025	6:39:00 AM
SMTH-0679	KI	NA	KITCHEN		KC	12/4/2025	6:44:00 AM
SMTH-0683	HA	1014	Room 32		WC	12/4/2025	6:20:00 AM
SMTH-0697	HA	NA	Corridor next to room 45 (Formerly CLASSROOM 46)		WC	12/4/2025	7:06:00 AM
SMTH-0698	HA	NA	Corridor next to room 45 (Formerly CLASSROOM 46)		WC	12/4/2025	7:06:00 AM
SMTH-0701	HA	1014	Corridor by Room 32		WF	12/4/2025	6:20:00 AM
SMTH-0734	HA	1036	Main Lobby		WF	12/4/2025	6:15:00 AM
SMTH-0745	KI	NA	KITCHEN		HW	12/4/2025	6:35:00 AM
SMTH-0746	KI	NA	KITCHEN		SN	12/4/2025	6:37:00 AM

16 200.8
Kathleen 12/11/25

Building Address

99 Midwood Avenue
Nesconset, NY 11767

Analysis Type: ELAP 200.5

Lab Received: 12/10/25 13:53

Signature:

Samplers Name: Francisco Castillo

Samplers Signature: FC

JCB Project Manager: Bryan Ezelius



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-54650

Building: Tackan Elementary School

TAC

ED 57614

Page 2 of 2

Client:
Smithtown Central School District

Retest/New Install

Turn Around: Normal 1 wk Rush _____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
-----------	-----------------------	----------	------------------	-------------	-------------	-------------

Samples Submitted 17

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
DEC 10 25, PM01:53

Pb 200.8
Kathleen
12/15/25

Pb 200.8
Kathleen
12/11/25

Building Address

99 Midwood Avenue
Nesconset, NY 11767

Analysis Type: ELAP 200.5

Lab Received: 12/10/25 12:53

Signature: 

Samplers Name: Francisco Castillo

Samplers Signature: FC

JCB Project Manager: Bryan Ezelius

Page 7 of 7

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557614**LIMS Reference ID:** ED57614**EMSL Customer ID:** JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: Tackan Elementary School: 99 Midwood Avenue, Nesconset, NY 11767: Smithtown Central School District: Project# 23-54650
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/10/2025 13:53
Reported: 12/23/2025 10:29

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SMTH-0661									
Metals									
Lead	19.9	1	1.0	µg/L	12/11/25 19:07	12/11/25 19:07	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-0662									
Metals									
Lead	19.3	1	1.0	µg/L	12/11/25 19:08	12/11/25 19:08	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-0665									
Metals									
Lead	< 1.0	1	1.0	µg/L	12/11/25 19:12	12/11/25 19:12	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-0670									
Metals									
Lead	< 1.0	1	1.0	µg/L	12/11/25 19:14	12/11/25 19:14	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-0671									
Metals									
Lead	< 1.0	1	1.0	µg/L	12/11/25 19:15	12/11/25 19:15	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-0673									
Metals									
Lead	3.0	1	1.0	µg/L	12/11/25 19:16	12/11/25 19:16	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-0674									
Metals									
Lead	1.8	1	1.0	µg/L	12/11/25 19:18	12/11/25 19:18	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-0676									
Metals									
Lead	15.1	1	1.0	µg/L	12/11/25 19:19	12/11/25 19:19	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-0677									
Metals									

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557614**LIMS Reference ID:** ED57614**EMSL Customer ID:** JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: Tackan Elementary School: 99 Midwood Avenue, Nesconset, NY 11767: Smithtown Central School District: Project# 23-54650
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/10/2025 13:53
Reported: 12/23/2025 10:29

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SMTM-0677 (Continued)									
Metals (Continued)									
Lead									
Sample: SMTM-0679	22.9		1	1.0	µg/L	12/11/25 19:20	12/11/25 19:20	KT1	EPA 200.8 (DA)/EPA 200.8
Metals									
Lead									
Sample: SMTM-0683	9.2		1	1.0	µg/L	12/11/25 19:24	12/11/25 19:24	KT1	EPA 200.8 (DA)/EPA 200.8
Metals									
Lead									
Sample: SMTM-0697	< 1.0		1	1.0	µg/L	12/11/25 19:28	12/11/25 19:28	KT1	EPA 200.8 (DA)/EPA 200.8
Metals									
Lead									
Sample: SMTM-0698	< 1.0		1	1.0	µg/L	12/11/25 19:30	12/11/25 19:30	KT1	EPA 200.8 (DA)/EPA 200.8
Metals									
Lead									
Sample: SMTM-0701	< 1.0		1	1.0	µg/L	12/11/25 19:31	12/11/25 19:31	KT1	EPA 200.8 (DA)/EPA 200.8
Metals									
Lead									
Sample: SMTM-0734	< 1.0		1	1.0	µg/L	12/11/25 19:32	12/11/25 19:32	KT1	EPA 200.8 (DA)/EPA 200.8
Metals									
Lead									
Sample: SMTM-0745	< 1.0		1	1.0	µg/L	12/11/25 19:34	12/11/25 19:34	KT1	EPA 200.8 (DA)/EPA 200.8
Metals									
Lead									
Sample: SMTM-0746	7.3		1	1.0	µg/L	12/15/25 17:27	12/15/25 17:27	KT1	EPA 200.8 (Dig)/EPA 200.8
Metals									



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557614

LIMS Reference ID: ED57614

EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: Tackan Elementary School: 99 Midwood Avenue, Nesconset, NY 11767: Smithtown Central School District: Project# 23-54650
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/10/2025 13:53
Reported: 12/23/2025 10:29

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SMTM-0746 (Continued)									Lims Reference ID: ED57614-17 Matrix: Drinking Water
Metals (Continued)									
Lead	139		2	2.0	µg/L	12/15/25 17:52	12/15/25 17:52	KT1	EPA 200.8 (Dig)/EPA 200.8



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557614

LIMS Reference ID: ED57614

EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: Tackan Elementary School: 99 Midwood Avenue, Nesconset, NY 11767: Smithtown Central School District: Project# 23-54650
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/10/2025 13:53
Reported: 12/23/2025 10:29

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com for a complete listing of parameters for which EMSL is certified.

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557614

LIMS Reference ID: ED57614

EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: Tackan Elementary School: 99 Midwood Avenue, Nesconset, NY 11767: Smithtown Central School District: Project# 23-54650
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/10/2025 13:53
Reported: 12/23/2025 10:29

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492

FAX: (631) 584-3395

JCB #:

23-54650

Building: Tackan Elementary School

TAC

ED57983

Page 1 of 1

Client:

Smithtown Central School District

Retest/New Install []

Turn Around: Normal 1 wk Rush

48 HR

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
SMTH-0676	KI	NA	KITCHEN	SN	12/31/2025	7:49:00 AM
SMTH-0745	KI	NA	KITCHEN	KC	12/31/2025	7:47:00 AM
SMTH-0746	KI	NA	KITCHEN	KC	12/31/2025	7:47:00 AM

Samples Submitted 3

Pb 200.8 Bldg 112/26

RECEIVED
 EMSL ANALYTICAL, INC.
 Carle Place, NY
 DEC 31 25, AM10:39

Building Address
 99 Midwood Avenue
 Nesconset, NY 11767

Walk In

Analysis Type: ELAP 200.5

Lab Received: DAVID WHITTON 12/31/25
10:39 AM

Signature: David Whitton

Samplers Name: Jacelynn Boniface

Samplers Signature:

JCB Project Manager: Bryan Ecelius

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557983**LIMS Reference ID:** ED57983**EMSL Customer ID:** JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 23-54650 / Smithtown Central School District /
Tackan Elementary School TAC / 99 Midwood
Avenue, Nesconset, NY 11767
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/31/2025 10:39
Reported: 01/02/2026 12:32

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SMTM-0676									
Metals									
Lead	4.0		1	1.0	µg/L	01/02/26 11:26	01/02/26 11:26	BP	EPA 200.8 (DA)/EPA 200.8
Sample: SMTM-0745									
Metals									
Lead	< 1.0		1	1.0	µg/L	01/02/26 11:32	01/02/26 11:32	BP	EPA 200.8 (DA)/EPA 200.8
Sample: SMTM-0746									
Metals									
Lead	< 1.0		1	1.0	µg/L	01/02/26 11:34	01/02/26 11:34	BP	EPA 200.8 (DA)/EPA 200.8



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557983

LIMS Reference ID: ED57983

EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 23-54650 / Smithtown Central School District /
Tackan Elementary School TAC / 99 Midwood
Avenue, Nesconset, NY 11767
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/31/2025 10:39
Reported: 01/02/2026 12:32

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com for a complete listing of parameters for which EMSL is certified.



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557983

LIMS Reference ID: ED57983

EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 23-54650 / Smithtown Central School District /
Tackan Elementary School TAC / 99 Midwood
Avenue, Nesconset, NY 11767
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/31/2025 10:39
Reported: 01/02/2026 12:32

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.


James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 581-5402 FAX: (631) 581-3305

TEL: (631) 584-5492 FAX: (631) 584-3395

JCR #:

23-54650

Building: Smithtown High School East

SME

Client-

Smithtown Central School District

Retest/New Install []

Turn Around: Normal 1 wk Rush

Page

Courier

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
SMTH-0748	KI	1040	Kitchen	KC	12/13/2025	6:15:00 AM
SMTH-0750	KI	1040	Kitchen	KC	12/13/2025	6:16:00 AM
SMTH-0751	KI	1040	Kitchen	KC	12/13/2025	6:16:00 AM
SMTH-0752	KI	1040	Kitchen	KC	12/13/2025	6:23:00 AM
SMTH-0753	OF	1051	Custodial Office	KC	12/13/2025	6:30:00 AM
SMTH-0764	CA	1036	Commons Cafeteria	DW	12/13/2025	6:33:00 AM
SMTH-0767	CS	1042	School Store	KC	12/13/2025	6:36:00 AM
SMTH-0770	HA	1123	Corridor (School Store - Room 105)	DW	12/13/2025	6:39:00 AM
SMTH-0778	HA	1129	Main Office Hallway	WF	12/13/2025	6:42:00 AM
SMTH-0779	HA	1129	Main Office Hallway	WC	12/13/2025	6:42:00 AM
SMTH-0782	OF	1128C	Main Office Kitchen	KC	12/13/2025	7:14:00 AM
SMTH-0785	KI	1124A	Main Cafeteria Dish Room	KC	12/13/2025	6:53:00 AM
SMTH-0786	KI	1124A	Main Cafeteria Dish Room	KC	12/13/2025	6:53:00 AM
SMTH-0790	HA	1112A	Room 184	DW	12/13/2025	6:59:00 AM
SMTH-0811	HA	1134	Library Vestibule	WF	12/13/2025	7:04:00 AM
SMTH-0812	HA	1134	Library Vestibule	WC	12/13/2025	7:04:00 AM
SMTH-0829	NO	1088	NURSES OFFICE	KC	12/13/2025	7:08:00 AM
SMTH-0830	NO	1088	NURSES OFFICE	KC	12/13/2025	7:23:00 AM

Building Address

10 School Street

St. James, NY 11780

Analysis Type: ELAP 200.5

Lab Received: Seen 6/11

Signature: *Mr. Ali*


12/17/25

2:16 PM

Samplers Name: Yuson Zheng

Samplers Signature: Van Z

JCB Project Manager: Bryan Ezeleor



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #:

23-54650

Building: Smithtown High School East

SME

ED57770

Page 2 of 4

Client:

Smithtown Central School District

Retest/New Install

Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time	RECEIVED	QUALITY CHECK	DATE PLACED
SMTH-0845	HA	1145	Girls Locker Room (Hallway)	WF	12/13/2025	8:02:00 AM			
SMTH-0846	HA	1145	Girls Locker Room	WC	12/13/2025	8:02:00 AM			
SMTH-0851	GY	1147	Small Gym	DW	12/13/2025	7:57:00 AM			
SMTH-0852	GY	1147	Small Gym	DW	12/13/2025	7:57:00 AM			
SMTH-0853	ST	1139	Ice Machine Room	IM	12/13/2025	8:14:00 AM			
SMTH-0855	LR	1152	Boys Team Locker Room	DW	12/13/2025	8:11:00 AM			
SMTH-0865	HA	1162	Large Gymnasium (Hallway)	DW	12/13/2025	8:07:00 AM			
SMTH-0900	HA	1074	Hallway Across Room 150	DW	12/13/2025	7:47:00 AM			
SMTH-1040	HA	1000	Room 120 (Hallway)	WF	12/13/2025	8:41:00 AM			
SMTH-1041	HA	1000	Room 120 (Hallway)	DW	12/13/2025	8:41:00 AM			
SMTH-1047	HA	2015	Corridor by Computer Server Room	DW	12/13/2025	9:39:00 AM			
SMTH-1048	KI	2008C	Room 233 Kitchen	KC	12/13/2025	9:40:00 AM			
SMTH-1058	OF	3029	Math Office Kitchenette	KC	12/13/2025	9:47:00 AM			
SMTH-1062	HA	3045	Corridor by Girls' Bathroom	WF	12/13/2025	9:49:00 AM			
SMTH-1063	HA	3045	Corridor by Girls' Bathroom	WC	12/13/2025	9:49:00 AM			
SMTH-1073	OF	3020	Room 330 North Social Studies	KC	12/13/2025	9:54:00 AM			
SMTH-1074	HA	3047	Corridor by Women's Bathroom	DW	12/13/2025	9:51:00 AM			
SMTH-1081	OF	2024C	210 English Dept Break Room	KC	12/13/2025	10:00:00 AM			

Building Address

10 School Street

St. James, NY 11780

Analysis Type: ELAP 200.5

Lab Received: Sean Cull

Signature: Sean Cull

12/17/25


2:10 PM

Samplers Name: Vincent Zhang

Samplers Signature: Vincent Zhang

JCB Project Manager: Bryan Ezelius

DEC 17 25, 2025



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #:

23-54650

Building: Smithtown High School East

SME

EDS7770

Page 3 of 4

Client:

Smithtown Central School District

Retest/New Install

Turn Around: Normal 1 wk Rush _____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
SMTH-2402	KI	1040	Kitchen	KC	12/13/2025	6:20:00 AM
SMTH-2403	OF	1005	Room 123	KC	12/13/2025	9:02:00 AM
SMTH-2408	SC	1010	Science Prep Room 130	IM	12/13/2025	9:09:00 AM
SMTH-2410	SC	1027	Science Prep	IM	12/13/2025	9:16:00 AM
SMTH-2957	KI	1040	Kitchen	KC	12/13/2025	6:19:00 AM
SMTH-3224	HA	2031	Corridor by Women's Faculty Bathroom	WF	12/13/2025	9:58:00 AM
SMTH-3225	HA	2031	Corridor by Women's Faculty Bathroom	WC	12/13/2025	9:58:00 AM
SMTH-3312	KI	1040	Kitchen	SN	12/13/2025	6:26:00 AM
SMTH-3343	ST	1139	Ice Machine Rooms	HB	12/13/2025	8:33:00 AM
SMTH-3350	HE	1083	Room 149	EC	12/13/2025	8:26:00 AM
SMTH-3351	HE	1083	Room 149	EC	12/13/2025	8:27:00 AM
SMTH-3352	HE	1083	Room 149	EC	12/13/2025	8:27:00 AM
SMTH-3353	HE	1083	Room 149	EC	12/13/2025	8:27:00 AM
SMTH-3354	HE	1084	Room 151	EC	12/13/2025	8:23:00 AM
SMTH-3355	HE	1084	Room 151	EC	12/13/2025	8:24:00 AM
SMTH-3356	HE	1084	Room 151	EC	12/13/2025	8:24:00 AM

Carrie Place NY
DEC 17 2025 PM 2:17

Building Address

10 School Street

St. James, NY 11780

Analysis Type: ELAP 200.5

Lab Received: Seen Cell

Signature: Tom Cell


12/17/25

2:17 PM

Samplers Name: Vince Zheng

Samplers Signature: VZ

JCB Project Manager: Bryan Erclus



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-54650

Building: Smithtown High School East

SME

Client:

Smithtown Central School District

Retest/New Install

Turn Around: Normal 1 wk Rush _____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
					Samples Submitted	52

ED57770

Building Address

10 School Street

St. James, NY 11780

Analysis Type: ELAP 200.5

Lab Received:

Signature:

Ben Cull

Ben Cull

12/17/25

2:17 PM

Samplers Name: Vince Zheng

Samplers Signature: Vince Z

JCB Project Manager: Brya Ekelus

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557770**LIMS Reference ID:** ED57770**EMSL Customer ID:** JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 10 School Street St James NY 11780, Smithtown
High School East, JCB#:23-54650, Smithtown
Central School District

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeremy Bish

Received: 12/17/2025 14:16

Reported: 12/23/2025 11:04

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SMTM-0748									
Metals									
Lead	< 1.0		1	1.0	µg/L	12/18/25 17:27	12/18/25 17:27	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: SMTM-0750									
Metals									
Lead	2.9		1	1.0	µg/L	12/18/25 17:31	12/18/25 17:31	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: SMTM-0751									
Metals									
Lead	3.0		1	1.0	µg/L	12/18/25 17:33	12/18/25 17:33	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: SMTM-0752									
Metals									
Lead	209		5	5.0	µg/L	12/18/25 18:04	12/18/25 18:04	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: SMTM-0753									
Metals									
Lead	< 1.0		1	1.0	µg/L	12/18/25 17:38	12/18/25 17:38	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: SMTM-0764									
Metals									
Lead	31.1		1	1.0	µg/L	12/18/25 17:39	12/18/25 17:39	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: SMTM-0767									
Metals									
Lead	8.9		1	1.0	µg/L	12/18/25 17:40	12/18/25 17:40	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: SMTM-0770									
Metals									
Lead	1.5		1	1.0	µg/L	12/18/25 17:42	12/18/25 17:42	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: SMTM-0778									
Metals									

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557770**LIMS Reference ID:** ED57770**EMSL Customer ID:** JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 10 School Street St James NY 11780, Smithtown
High School East, JCB#:23-54650, Smithtown
Central School District

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeremy Bish

Received: 12/17/2025 14:16

Reported: 12/23/2025 11:04

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
---------	--------	---	----	----	-------	--------------------	--------------------	------------------	-------------------------

Sample: SMTM-0778 (Continued) Lims Reference ID: ED57770-09 Matrix: Drinking Water Sampled: 12/13/25 00:00:00

Metals (Continued)

Lead < 1.0 1 1.0 µg/L 12/18/25 17:43 12/18/25 17:43 KT1 EPA 200.8 (DA)/EPA 200.8

Sample: SMTM-0779 Lims Reference ID: ED57770-10 Matrix: Drinking Water Sampled: 12/13/25 00:00:00

Metals

Lead < 1.0 1 1.0 µg/L 12/18/25 17:44 12/18/25 17:44 KT1 EPA 200.8 (DA)/EPA 200.8

Sample: SMTM-0782 Lims Reference ID: ED57770-11 Matrix: Drinking Water Sampled: 12/13/25 00:00:00

Metals

Lead 1.8 1 1.0 µg/L 12/18/25 17:46 12/18/25 17:46 KT1 EPA 200.8 (DA)/EPA 200.8

Sample: SMTM-0785 Lims Reference ID: ED57770-12 Matrix: Drinking Water Sampled: 12/13/25 00:00:00

Metals

Lead 2.5 1 1.0 µg/L 12/18/25 17:50 12/18/25 17:50 KT1 EPA 200.8 (DA)/EPA 200.8

Sample: SMTM-0786 Lims Reference ID: ED57770-13 Matrix: Drinking Water Sampled: 12/13/25 00:00:00

Metals

Lead 12.8 1 1.0 µg/L 12/18/25 17:54 12/18/25 17:54 KT1 EPA 200.8 (DA)/EPA 200.8

Sample: SMTM-0790 Lims Reference ID: ED57770-14 Matrix: Drinking Water Sampled: 12/13/25 00:00:00

Metals

Lead 2.4 1 1.0 µg/L 12/18/25 17:55 12/18/25 17:55 KT1 EPA 200.8 (DA)/EPA 200.8

Sample: SMTM-0811 Lims Reference ID: ED57770-15 Matrix: Drinking Water Sampled: 12/13/25 00:00:00

Metals

Lead < 1.0 1 1.0 µg/L 12/18/25 17:56 12/18/25 17:56 KT1 EPA 200.8 (DA)/EPA 200.8

Sample: SMTM-0812 Lims Reference ID: ED57770-16 Matrix: Drinking Water Sampled: 12/13/25 00:00:00

Metals

Lead < 1.0 1 1.0 µg/L 12/18/25 17:58 12/18/25 17:58 KT1 EPA 200.8 (DA)/EPA 200.8

Sample: SMTM-0829 Lims Reference ID: ED57770-17 Matrix: Drinking Water Sampled: 12/13/25 00:00:00

Metals

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557770**LIMS Reference ID:** ED57770**EMSL Customer ID:** JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 10 School Street St James NY 11780, Smithtown
High School East, JCB#:23-54650, Smithtown
Central School District

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeremy Bish

Received: 12/17/2025 14:16

Reported: 12/23/2025 11:04

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
---------	--------	---	----	----	-------	--------------------	--------------------	------------------	-------------------------

Sample: SMTM-0829 (Continued) Lims Reference ID: ED57770-17 Matrix: Drinking Water Sampled: 12/13/25 00:00:00

Metals (Continued)

Lead < 1.0 1 1.0 µg/L 12/18/25 17:59 12/18/25 17:59 KT1 EPA 200.8 (DA)/EPA 200.8

Sample: SMTM-0830 Lims Reference ID: ED57770-18 Matrix: Drinking Water Sampled: 12/13/25 00:00:00

Metals

Lead 1.2 1 1.0 µg/L 12/18/25 18:00 12/18/25 18:00 KT1 EPA 200.8 (DA)/EPA 200.8

Sample: SMTM-0845 Lims Reference ID: ED57770-19 Matrix: Drinking Water Sampled: 12/13/25 00:00:00

Metals

Lead < 1.0 1 1.0 µg/L 12/18/25 18:01 12/18/25 18:01 KT1 EPA 200.8 (DA)/EPA 200.8

Sample: SMTM-0846 Lims Reference ID: ED57770-20 Matrix: Drinking Water Sampled: 12/13/25 00:00:00

Metals

Lead < 1.0 1 1.0 µg/L 12/18/25 18:03 12/18/25 18:03 KT1 EPA 200.8 (DA)/EPA 200.8

Sample: SMTM-0851 Lims Reference ID: ED57770-21 Matrix: Drinking Water Sampled: 12/13/25 00:00:00

Metals

Lead 8.2 1 1.0 µg/L 12/18/25 18:17 12/18/25 18:17 KT1 EPA 200.8 (DA)/EPA 200.8

Sample: SMTM-0852 Lims Reference ID: ED57770-22 Matrix: Drinking Water Sampled: 12/13/25 00:00:00

Metals

Lead 6.5 1 1.0 µg/L 12/18/25 18:21 12/18/25 18:21 KT1 EPA 200.8 (DA)/EPA 200.8

Sample: SMTM-0853 Lims Reference ID: ED57770-23 Matrix: Drinking Water Sampled: 12/13/25 00:00:00

Metals

Lead < 1.0 1 1.0 µg/L 12/18/25 18:23 12/18/25 18:23 KT1 EPA 200.8 (DA)/EPA 200.8

Sample: SMTM-0855 Lims Reference ID: ED57770-24 Matrix: Drinking Water Sampled: 12/13/25 00:00:00

Metals

Lead 1.9 1 1.0 µg/L 12/18/25 18:24 12/18/25 18:24 KT1 EPA 200.8 (DA)/EPA 200.8

Sample: SMTM-0865 Lims Reference ID: ED57770-25 Matrix: Drinking Water Sampled: 12/13/25 00:00:00

Metals

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
 Telephone: 516.997.7251 Fax: 856-786-5974
 EMSL-CP-06

EMSL Order ID: 062557770**LIMS Reference ID:** ED57770**EMSL Customer ID:** JCBR50

Attention: Bryan Ezelius
 J.C. Broderick & Associates [JCBR50]
 1775 Expressway Drive North, Suite 1
 Hauppauge, NY 11788
 (631) 584-5492
 bezelius@jcbroderick.com

Project Name: 10 School Street St James NY 11780, Smithtown
 High School East, JCB#:23-54650, Smithtown
 Central School District

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeremy Bish

Received: 12/17/2025 14:16

Reported: 12/23/2025 11:04

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SMTM-0865 (Continued)									
Metals (Continued)									
Lead	1.7	1	1.0	µg/L	12/18/25 18:28	12/18/25 18:28	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTM-0900									
Metals									
Lead	5.7	1	1.0	µg/L	12/18/25 18:29	12/18/25 18:29	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTM-1040									
Metals									
Lead	< 1.0	1	1.0	µg/L	12/18/25 18:31	12/18/25 18:31	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTM-1041									
Metals									
Lead	< 1.0	1	1.0	µg/L	12/18/25 18:32	12/18/25 18:32	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTM-1047									
Metals									
Lead	64.0	1	1.0	µg/L	12/18/25 18:33	12/18/25 18:33	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTM-1048									
Metals									
Lead	11.7	1	1.0	µg/L	12/18/25 18:35	12/18/25 18:35	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTM-1058									
Metals									
Lead	3.7	1	1.0	µg/L	12/18/25 18:36	12/18/25 18:36	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTM-1062									
Metals									
Lead	< 1.0	1	1.0	µg/L	12/18/25 18:40	12/18/25 18:40	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTM-1063									
Metals									

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557770**LIMS Reference ID:** ED57770**EMSL Customer ID:** JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 10 School Street St James NY 11780, Smithtown
High School East, JCB#:23-54650, Smithtown
Central School District

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeremy Bish

Received: 12/17/2025 14:16

Reported: 12/23/2025 11:04

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SMTH-1063 (Continued)									Sampled: 12/13/25 00:00:00
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	12/18/25 18:44	12/18/25 18:44	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH-1073									Sampled: 12/13/25 00:00:00
Metals									
Lead	17.2		1	1.0	µg/L	12/18/25 18:45	12/18/25 18:45	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH-1074									Sampled: 12/13/25 00:00:00
Metals									
Lead	9.4		1	1.0	µg/L	12/18/25 18:46	12/18/25 18:46	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH-1081									Sampled: 12/13/25 00:00:00
Metals									
Lead	1.4		1	1.0	µg/L	12/18/25 18:48	12/18/25 18:48	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH-2402									Sampled: 12/13/25 00:00:00
Metals									
Lead	12.6		1	1.0	µg/L	12/18/25 18:49	12/18/25 18:49	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH-2403									Sampled: 12/13/25 00:00:00
Metals									
Lead	< 1.0		1	1.0	µg/L	12/18/25 18:50	12/18/25 18:50	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH-2408									Sampled: 12/13/25 00:00:00
Metals									
Lead	6.4		1	1.0	µg/L	12/18/25 18:52	12/18/25 18:52	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH-2410									Sampled: 12/13/25 00:00:00
Metals									
Lead	1.3		1	1.0	µg/L	12/18/25 18:53	12/18/25 18:53	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH-2957									Sampled: 12/13/25 00:00:00
Metals									

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557770**LIMS Reference ID:** ED57770**EMSL Customer ID:** JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 10 School Street St James NY 11780, Smithtown
High School East, JCB#:23-54650, Smithtown
Central School District

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeremy Bish

Received: 12/17/2025 14:16

Reported: 12/23/2025 11:04

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SMTH-2957 (Continued)									Sampled: 12/13/25 00:00:00
Metals (Continued)									
Lead	< 1.0	1	1.0	µg/L	12/20/25 01:36	12/20/25 01:36	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-3224									Sampled: 12/13/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	12/20/25 01:37	12/20/25 01:37	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-3225									Sampled: 12/13/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	12/20/25 01:39	12/20/25 01:39	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-3312									Sampled: 12/13/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	12/20/25 01:43	12/20/25 01:43	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-3343									Sampled: 12/13/25 00:00:00
Metals									
Lead	< 1.0	1	1.0	µg/L	12/20/25 01:44	12/20/25 01:44	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-3350									Sampled: 12/13/25 00:00:00
Metals									
Lead	18.5	1	1.0	µg/L	12/20/25 11:57	12/20/25 11:57	JH	EPA 200.8 (Dig)/EPA 200.8	
Sample: SMTH-3351									Sampled: 12/13/25 00:00:00
Metals									
Lead	6.6	1	1.0	µg/L	12/20/25 01:45	12/20/25 01:45	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-3352									Sampled: 12/13/25 00:00:00
Metals									
Lead	2.7	1	1.0	µg/L	12/20/25 01:47	12/20/25 01:47	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-3353									Sampled: 12/13/25 00:00:00
Metals									

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557770**LIMS Reference ID:** ED57770**EMSL Customer ID:** JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 10 School Street St James NY 11780, Smithtown
High School East, JCB#:23-54650, Smithtown
Central School District

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeremy Bish

Received: 12/17/2025 14:16

Reported: 12/23/2025 11:04

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SMTH-3353 (Continued)									
Metals (Continued)									
Lead	3.9		1	1.0	µg/L	12/20/25 01:48	12/20/25 01:48	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH-3354									
Metals									
Lead	2.4		1	1.0	µg/L	12/20/25 01:49	12/20/25 01:49	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH-3355									
Metals									
Lead	1.9		1	1.0	µg/L	12/20/25 01:50	12/20/25 01:50	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH-3356									
Metals									
Lead	6.9		1	1.0	µg/L	12/20/25 11:59	12/20/25 11:59	JH	EPA 200.8 (Dig)/EPA 200.8



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557770

LIMS Reference ID: ED57770

EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 10 School Street St James NY 11780, Smithtown High School East, JCB#:23-54650, Smithtown Central School District
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/17/2025 14:16
Reported: 12/23/2025 11:04

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com for a complete listing of parameters for which EMSL is certified.



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557770

LIMS Reference ID: ED57770

EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 10 School Street St James NY 11780, Smithtown
High School East, JCB#:23-54650, Smithtown
Central School District
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/17/2025 14:16
Reported: 12/23/2025 11:04

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-54650
Building: Barton Administration Building
NYA

EDS7049

Page 1 of 1

Client:
Smithtown Central School District

Retest/New Install

Turn Around: Normal 1 wk Rush _____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
SMTH-1235	KI	1025	Room 115 Printing Room	KC	12/11/2025	5:57:00 AM
SMTH-1238	CA	1033	Lunch Room	KC	12/11/2025	5:59:00 AM
SMTH-2377	HA	1023	Corridor (Security Office - Room 134)	WF	12/11/2025	5:59:00 AM
SMTH-2378	HA	1023	Corridor (Security Office - Room 134)	WC	12/11/2025	6:00:00 AM
SMTH-2379	HA	3013	Corridor o/s Accounting Offices	WF	12/11/2025	6:13:00 AM
SMTH-2380	HA	3013	Corridor o/s Accounting Offices	WC	12/11/2025	6:13:00 AM
SMTH-2896	HA	2014	Corridor o/s Special Ed Suite	WF	12/11/2025	6:07:00 AM
SMTH-2897	HA	2014	Corridor o/s Special Ed Suite	WC	12/11/2025	6:07:00 AM

Samples Submitted 8

RECEIVED

EMSL ANALYTICAL, INC.

Carle Place, NY

DEC 11 25, PM01:48

Courier

Pb 260.8
Kostiwicz
12/15/25

12/11/2025

Building Address

26 New York Avenue
Smithtown, NY 11787

Analysis Type: ELAP 200.5

Lab Recieved:

Sample Collected

12/11/25

Samplers Name: Wilson Thurg

Samplers Signature:

Wilson Thurg

1:48 PM

JCB Project Manager: Bryan Ezelur

Page 4 of 4

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557649**LIMS Reference ID:** ED57649**EMSL Customer ID:** JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 26 New York Avenue Smithtown NY 11787, Barton Administration Building, JCB#:23-54650, Smithtown Central School District
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/11/2025 13:48
Reported: 12/23/2025 10:42

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SMTH-1235									
Metals									
Lead	65.8	1	1.0	µg/L	12/15/25 17:39	12/15/25 17:39	KT1	EPA 200.8 (Dig)/EPA 200.8	
Sample: SMTH-1238									
Metals									
Lead	11.8	1	1.0	µg/L	12/15/25 17:40	12/15/25 17:40	KT1	EPA 200.8 (Dig)/EPA 200.8	
Sample: SMTH-2377									
Metals									
Lead	< 1.0	1	1.0	µg/L	12/12/25 18:24	12/12/25 18:24	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-2378									
Metals									
Lead	< 1.0	1	1.0	µg/L	12/12/25 18:26	12/12/25 18:26	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-2379									
Metals									
Lead	< 1.0	1	1.0	µg/L	12/12/25 18:27	12/12/25 18:27	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-2380									
Metals									
Lead	< 1.0	1	1.0	µg/L	12/12/25 18:28	12/12/25 18:28	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-2896									
Metals									
Lead	< 1.0	1	1.0	µg/L	12/12/25 18:29	12/12/25 18:29	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-2897									
Metals									
Lead	< 1.0	1	1.0	µg/L	12/12/25 18:31	12/12/25 18:31	DAZ	EPA 200.8 (DA)/EPA 200.8	



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557649

LIMS Reference ID: ED57649

EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 26 New York Avenue Smithtown NY 11787, Barton Administration Building, JCB#:23-54650, Smithtown Central School District
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/11/2025 13:48
Reported: 12/23/2025 10:42

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com for a complete listing of parameters for which EMSL is certified.



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557649

LIMS Reference ID: ED57649

EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 26 New York Avenue Smithtown NY 11787, Barton Administration Building, JCB#:23-54650, Smithtown Central School District
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/11/2025 13:48
Reported: 12/23/2025 10:42


Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #:

23-54650

Building: Dogwood Elementary School

DOG

Courier

ED57611

Page 1 of 2

Client:

Smithtown Central School District

Retest/New Install

Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	RECEIVED ENGL ANALYTICAL INC Carle Place, NY DEC 10 25, PM 01:48	Outlet Type	Sample Date	Sample Time
SMTH-1280	FL	1025	Faculty Room		KC	12/5/2025	6:02:00 AM
SMTH-1281	HA	1021B	Corridor by Boiler Room		WF	12/5/2025	5:58:00 AM
SMTH-1282	HA	1021B	Corridor by Boiler Room		WC	12/5/2025	5:58:00 AM
SMTH-1284	NO	1028	Health Office		KC	12/5/2025	6:05:00 AM
SMTH-1290	CR	1038	Speech Room (7)		KC	12/5/2025	6:07:00 AM
SMTH-1307	LI	1029A	Library Sink Room		KC	12/5/2025	6:03:00 AM
SMTH-1308	HA	NA	Corridor by Room C		WF	12/5/2025	6:17:00 AM
SMTH-1309	HA	NA	Corridor by Room C		WC	12/5/2025	6:17:00 AM
SMTH-1329	HA	1013	Corridor by Room 31		WF	12/5/2025	5:43:00 AM
SMTH-1330	HA	1013	Corridor by Room 31		WC	12/5/2025	5:43:00 AM
SMTH-1334	KI	NA	Kitchen		KC	12/5/2025	5:37:00 AM
SMTH-1335	KI	NA	Kitchen		KC	12/5/2025	5:37:00 AM
SMTH-1336	KI	NA	Kitchen		SN	12/5/2025	5:38:00 AM
SMTH-1337	KI	NA	Kitchen		KC	12/5/2025	5:38:00 AM
SMTH-1338	KI	NA	Kitchen		KC	12/5/2025	5:38:00 AM
SMTH-1366	CR	NA	Room 43		DW	12/5/2025	5:51:00 AM

Building Address

50 Dogwood Lane
Smithtown, NY 11787

Analysis Type: ELAP 200.5

Lab Received: DAVID WHARTON 12/10/25 1:48 PM

Signature: David Wharton

Samplers Name: Wansen Zheng

Samplers Signature: Wansen Zheng

JCB Project Manager: Bryan Ezelius



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

ED57611

JCB #: 23-54650
Building: Dogwood Elementary School
DOG

Client:

Smithtown Central School District

Retest/New Install

Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
-----------	-----------------------	----------	------------------	-------------	-------------	-------------

Samples Submitted 16

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
DEC 10 25, PM01:48

Building Address

50 Dogwood Lane
Smithtown, NY 11787

Analysis Type: ELAP 200.5

Lab Received: DAVID WHARTON 12/10/25
1:48 PM

Signature: David Wharton

Samplers Name: Vinzen Zheng

Samplers Signature:

JCB Project Manager: Bryan Ezebue

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557611**LIMS Reference ID:** ED57611**EMSL Customer ID:** JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 23-54650 / Smithtown Central School District /
Dogwood Elementary School DOG / 50 Dogwood
Lane, Smithtown, NY 11787
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/10/2025 13:48
Reported: 12/23/2025 10:27

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SMTH-1280									
Metals									
Lead									
	1.9		1	1.0	µg/L	12/11/25 21:07	12/11/25 21:07	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH-1281									
Metals									
Lead									
	< 1.0		1	1.0	µg/L	12/11/25 21:11	12/11/25 21:11	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH-1282									
Metals									
Lead									
	< 1.0		1	1.0	µg/L	12/11/25 21:12	12/11/25 21:12	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH-1284									
Metals									
Lead									
	1.5		1	1.0	µg/L	12/11/25 21:13	12/11/25 21:13	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH-1290									
Metals									
Lead									
	9.4		1	1.0	µg/L	12/12/25 17:55	12/12/25 17:55	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH-1307									
Metals									
Lead									
	12.5		1	1.0	µg/L	12/12/25 17:59	12/12/25 17:59	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH-1308									
Metals									
Lead									
	< 1.0		1	1.0	µg/L	12/12/25 18:00	12/12/25 18:00	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH-1309									
Metals									
Lead									
	< 1.0		1	1.0	µg/L	12/12/25 18:04	12/12/25 18:04	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH-1329									
Metals									
Lead									
	< 1.0		1	1.0	µg/L	12/12/25 18:04	12/12/25 18:04	DAZ	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557611**LIMS Reference ID:** ED57611**EMSL Customer ID:** JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 23-54650 / Smithtown Central School District /
Dogwood Elementary School DOG / 50 Dogwood
Lane, Smithtown, NY 11787
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/10/2025 13:48
Reported: 12/23/2025 10:27

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SMTH-1329 (Continued)									Sampled: 12/05/25 00:00:00
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	12/12/25 18:06	12/12/25 18:06	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH-1330									Sampled: 12/05/25 00:00:00
Metals									
Lead	< 1.0		1	1.0	µg/L	12/12/25 18:07	12/12/25 18:07	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH-1334									Sampled: 12/05/25 00:00:00
Metals									
Lead	22.5		1	1.0	µg/L	12/12/25 18:08	12/12/25 18:08	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH-1335									Sampled: 12/05/25 00:00:00
Metals									
Lead	32.9		1	1.0	µg/L	12/12/25 18:10	12/12/25 18:10	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH-1336									Sampled: 12/05/25 00:00:00
Metals									
Lead	4.0		1	1.0	µg/L	12/12/25 18:11	12/12/25 18:11	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH-1337									Sampled: 12/05/25 00:00:00
Metals									
Lead	1.7		1	1.0	µg/L	12/12/25 18:12	12/12/25 18:12	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH-1338									Sampled: 12/05/25 00:00:00
Metals									
Lead	3.6		1	1.0	µg/L	12/12/25 18:14	12/12/25 18:14	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH-1366									Sampled: 12/05/25 00:00:00
Metals									
Lead	1.7		1	1.0	µg/L	12/12/25 18:20	12/12/25 18:20	DAZ	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557611

LIMS Reference ID: ED57611

EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 23-54650 / Smithtown Central School District /
Dogwood Elementary School DOG / 50 Dogwood
Lane, Smithtown, NY 11787
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/10/2025 13:48
Reported: 12/23/2025 10:27

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com for a complete listing of parameters for which EMSL is certified.

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557611

LIMS Reference ID: ED57611

EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 23-54650 / Smithtown Central School District /
Dogwood Elementary School DOG / 50 Dogwood
Lane, Smithtown, NY 11787
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/10/2025 13:48
Reported: 12/23/2025 10:27


Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 23-54650
Building: Nesaquaque Middle School
NES

ED57809

Walk In

Client:
Smithtown Central School District

Retest/New Install []

Turn Around: Normal 1 w/ Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time	RECEIVED ANALYTICAL INC. Carle Place, NY DE 19 25 2019 03:13
SMTH-1381	HE	5005	Room 503	EC	12/2/2025	5:52:00 AM	
SMTH-1382	HE	5005	Room 503	EC	12/2/2025	5:51:00 AM	
SMTH-1383	HE	5005	Room 503	EC	12/2/2025	5:49:00 AM	
SMTH-1384	HE	5005	Room 503	EC	12/2/2025	5:48:00 AM	
SMTH-1385	HA	5012	Corridor 5012 o/s 5003	DW	12/2/2025	5:53:00 AM	
SMTH-1386	HE	5004	Room 502	EC	12/2/2025	5:55:00 AM	
SMTH-1387	HE	5004	Room 502	EC	12/2/2025	5:56:00 AM	
SMTH-1388	HE	5004	Room 502	EC	12/2/2025	5:56:00 AM	
SMTH-1389	HE	5004	Room 502	EC	12/2/2025	5:57:00 AM	
SMTH-1395	FL	5011H	Faculty Lounge	KC	12/2/2025	6:03:00 AM	
SMTH-1403	HA	3030	Corridor 3030 o/s 3027	WF	12/2/2025	5:45:00 AM	
SMTH-1404	HA	3030	Corridor 3030 o/s 3027	WC	12/2/2025	5:45:00 AM	
SMTH-1408	HA	4001	Corridor 4001 o/s 4003	KC	12/2/2025	6:13:00 AM	
SMTH-1414	HA	3006	Corridor 3006 o/s 3008	WF	12/2/2025	6:20:00 AM	
SMTH-1415	HA	3006	Corridor 3006 o/s 3008	WC	12/2/2025	6:20:00 AM	
SMTH-1497	NO	3014A	Room 317 Attendance Office	KC	12/2/2025	6:23:00 AM	
SMTH-1498	NO	3014A	NURSES OFFICE	NS	12/2/2025	6:25:00 AM	
SMTH-1499	CR	3012	Room 318	KC	12/2/2025	6:28:00 AM	

Building Address

478 Edgewood Avenue Street.
St. James, NY 11780

Pb 200.8
Kathleen Lee 12/22/25

Analysis Type: ELAP 200.5


Lab Received: 12/19/25 15:13

Signature: 

Samplers Name: Vinson Zheng

Samplers Signature: 

JCB Project Manager: Bryan Ezelius



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

ED57809

Page 2 of 2

JCB #: 23-54650
Building: Nesquaque Middle School
NES

Client:
Smithtown Central School District

Retest/ New Install

Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
SMTH-1500	HA	1023	Corridor 1023 o/s 1040	WF	12/2/2025	6:08:00 AM
SMTH-1501	HA	1023	Corridor 1023 o/s 1040	WC	12/2/2025	6:08:00 AM
SMTH-1516	HA	1005	Corridor 1005 o/s 1002D	WF	12/2/2025	6:41:00 AM
SMTH-1517	HA	1005	Corridor 1005 o/s 1002D	WC	12/2/2025	6:41:00 AM
SMTH-1522	KI	1021	KITCHEN	HW	12/2/2025	6:32:00 AM
SMTH-1523	KI	1020	KITCHEN	HW	12/2/2025	6:32:00 AM
SMTH-1524	KI	1020	KITCHEN	KC	12/2/2025	6:33:00 AM
SMTH-1525	KI	1020	KITCHEN	KC	12/2/2025	6:34:00 AM
SMTH-1526	KI	1020	KITCHEN	HW	12/2/2025	6:35:00 AM
SMTH-1527	KI	1020	KITCHEN	KC	12/2/2025	6:35:00 AM
SMTH-1528	KI	1020	KITCHEN	SN	12/2/2025	6:36:00 AM
SMTH-1530	HA	1005	Corridor 1005 o/s Gym	WF	12/2/2025	6:40:00 AM
SMTH-1531	HA	1005	Corridor 1005 o/s Gym	WC	12/2/2025	6:40:00 AM

Samples Submitted 31

RECEIVED
ENSL ANALYTICAL, INC.
Carle Place, NY
DEC 19 25, PM03:14

Pb 200.8
Kathleen
12/22/25

Building Address

478 Edgewood Avenue Street.
St. James, NY 11780

Analysis Type: ELAP 200.5

Lab Received: 12/19/25 16:14

Signature:

Samplers Name: Wilson Zheng

Samplers Signature:

JCB Project Manager: Bryan Ezeleks

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557809**LIMS Reference ID:** ED57809**EMSL Customer ID:** JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: Nesauquake Middle School: 478 Edgewood Avenue Street, St. James, NY 11780: Smithtown Central School District: Project# 23-54650
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/19/2025 15:13
Reported: 12/23/2025 11:07

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SMTH-1381									
Metals									
Lead	< 1.0		1	1.0	µg/L	12/22/25 17:25	12/22/25 17:25	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH-1382									
Metals									
Lead	4.0		1	1.0	µg/L	12/22/25 17:29	12/22/25 17:29	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH-1383									
Metals									
Lead	2.3		1	1.0	µg/L	12/22/25 17:30	12/22/25 17:30	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH-1384									
Metals									
Lead	22.9		1	1.0	µg/L	12/22/25 17:34	12/22/25 17:34	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH-1385									
Metals									
Lead	1.2		1	1.0	µg/L	12/22/25 17:35	12/22/25 17:35	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH-1386									
Metals									
Lead	1.3		1	1.0	µg/L	12/22/25 17:37	12/22/25 17:37	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH-1387									
Metals									
Lead	11.6		1	1.0	µg/L	12/22/25 17:38	12/22/25 17:38	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH-1388									
Metals									
Lead	3.0		1	1.0	µg/L	12/22/25 17:39	12/22/25 17:39	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH-1389									
Metals									

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
 Telephone: 516.997.7251 Fax: 856-786-5974
 EMSL-CP-06

EMSL Order ID: 062557809**LIMS Reference ID:** ED57809**EMSL Customer ID:** JCBR50

Attention: Bryan Ezelius
 J.C. Broderick & Associates [JCBR50]
 1775 Expressway Drive North, Suite 1
 Hauppauge, NY 11788
 (631) 584-5492
 bezelius@jcbroderick.com

Project Name: Nesauquake Middle School: 478 Edgewood Avenue Street, St. James, NY 11780: Smithtown Central School District: Project# 23-54650
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/19/2025 15:13
Reported: 12/23/2025 11:07

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SMTH-1389 (Continued)									
Metals (Continued)									
Lead									
Sample: SMTH-1395	2.3	1	1.0	µg/L	12/22/25 17:41	12/22/25 17:41	KT1	EPA 200.8 (DA)/EPA 200.8	
Metals									
Lead									
Sample: SMTH-1403	1.5	1	1.0	µg/L	12/22/25 17:42	12/22/25 17:42	KT1	EPA 200.8 (DA)/EPA 200.8	
Metals									
Lead									
Sample: SMTH-1404	< 1.0	1	1.0	µg/L	12/22/25 17:43	12/22/25 17:43	KT1	EPA 200.8 (DA)/EPA 200.8	
Metals									
Lead									
Sample: SMTH-1408	< 1.0	1	1.0	µg/L	12/22/25 17:50	12/22/25 17:50	KT1	EPA 200.8 (DA)/EPA 200.8	
Metals									
Lead									
Sample: SMTH-1414	5.8	1	1.0	µg/L	12/22/25 17:51	12/22/25 17:51	KT1	EPA 200.8 (DA)/EPA 200.8	
Metals									
Lead									
Sample: SMTH-1415	< 1.0	1	1.0	µg/L	12/22/25 17:52	12/22/25 17:52	KT1	EPA 200.8 (DA)/EPA 200.8	
Metals									
Lead									
Sample: SMTH-1497	< 1.0	1	1.0	µg/L	12/22/25 17:54	12/22/25 17:54	KT1	EPA 200.8 (DA)/EPA 200.8	
Metals									
Lead									
Sample: SMTH-1498	< 1.0	1	1.0	µg/L	12/22/25 17:55	12/22/25 17:55	KT1	EPA 200.8 (DA)/EPA 200.8	
Metals									
Lead									

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
 Telephone: 516.997.7251 Fax: 856-786-5974
 EMSL-CP-06

EMSL Order ID: 062557809**LIMS Reference ID:** ED57809**EMSL Customer ID:** JCBR50

Attention: Bryan Ezelius
 J.C. Broderick & Associates [JCBR50]
 1775 Expressway Drive North, Suite 1
 Hauppauge, NY 11788
 (631) 584-5492
 bezelius@jcbroderick.com

Project Name: Nesauquake Middle School: 478 Edgewood Avenue Street, St. James, NY 11780: Smithtown Central School District: Project# 23-54650
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/19/2025 15:13
Reported: 12/23/2025 11:07

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method		
Sample: SMTH-1498 (Continued)											
Metals (Continued)											
Lead											
Sample: SMTH-1499	1.8	1	1.0	µg/L	12/22/25 17:56	12/22/25 17:56	KT1	EPA 200.8 (DA)/EPA 200.8			
Metals											
Lead											
Sample: SMTH-1500	< 1.0	1	1.0	µg/L	12/22/25 17:58	12/22/25 17:58	KT1	EPA 200.8 (DA)/EPA 200.8			
Metals											
Lead											
Sample: SMTH-1501	< 1.0	1	1.0	µg/L	12/22/25 17:59	12/22/25 17:59	KT1	EPA 200.8 (DA)/EPA 200.8			
Metals											
Lead											
Sample: SMTH-1516	< 1.0	1	1.0	µg/L	12/22/25 18:00	12/22/25 18:00	KT1	EPA 200.8 (DA)/EPA 200.8			
Metals											
Lead											
Sample: SMTH-1517	< 1.0	1	1.0	µg/L	12/22/25 18:15	12/22/25 18:15	KT1	EPA 200.8 (DA)/EPA 200.8			
Metals											
Lead											
Sample: SMTH-1522	< 1.0	1	1.0	µg/L	12/22/25 18:19	12/22/25 18:19	KT1	EPA 200.8 (DA)/EPA 200.8			
Metals											
Lead											
Sample: SMTH-1523	2.3	1	1.0	µg/L	12/22/25 18:20	12/22/25 18:20	KT1	EPA 200.8 (DA)/EPA 200.8			
Metals											
Lead											
Sample: SMTH-1524	9.0	1	1.0	µg/L	12/22/25 18:22	12/22/25 18:22	KT1	EPA 200.8 (DA)/EPA 200.8			
Metals											
Lead											

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557809**LIMS Reference ID:** ED57809**EMSL Customer ID:** JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: Nesaquake Middle School: 478 Edgewood Avenue Street, St. James, NY 11780: Smithtown Central School District: Project# 23-54650
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/19/2025 15:13
Reported: 12/23/2025 11:07

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SMTH-1524 (Continued)									
Metals (Continued)									
Lead									
Sample: SMTH-1525	13.1		1	1.0	µg/L	12/22/25 18:26	12/22/25 18:26	KT1	EPA 200.8 (DA)/EPA 200.8
Metals									
Lead									
Sample: SMTH-1526	2.9		1	1.0	µg/L	12/22/25 18:27	12/22/25 18:27	KT1	EPA 200.8 (DA)/EPA 200.8
Metals									
Lead									
Sample: SMTH-1527	1.3		1	1.0	µg/L	12/22/25 18:28	12/22/25 18:28	KT1	EPA 200.8 (DA)/EPA 200.8
Metals									
Lead									
Sample: SMTH-1528	6.1		1	1.0	µg/L	12/22/25 18:29	12/22/25 18:29	KT1	EPA 200.8 (DA)/EPA 200.8
Metals									
Lead									
Sample: SMTH-1530	1.6		1	1.0	µg/L	12/22/25 18:31	12/22/25 18:31	KT1	EPA 200.8 (DA)/EPA 200.8
Metals									
Lead									
Sample: SMTH-1531	< 1.0		1	1.0	µg/L	12/22/25 18:32	12/22/25 18:32	KT1	EPA 200.8 (DA)/EPA 200.8
Metals									
Lead									



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557809

LIMS Reference ID: ED57809

EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: Nesaquake Middle School: 478 Edgewood Avenue Street, St. James, NY 11780: Smithtown Central School District: Project# 23-54650
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/19/2025 15:13
Reported: 12/23/2025 11:07

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com for a complete listing of parameters for which EMSL is certified.



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557809

LIMS Reference ID: ED57809

EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: Nesaquake Middle School: 478 Edgewood Avenue
Street, St. James, NY 11780: Smithtown Central
School District: Project# 23-54650

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeremy Bish

Received: 12/19/2025 15:13

Reported: 12/23/2025 11:07


Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

ED57982

JCB #: 23-54650
Building: Nesaquaque Middle School
NES

Client:

Smithtown Central School District

Retest/New Install []

Turn Around: Normal 1 wk Rush 48 HR

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
SMTH-1524	KI	1020	KITCHEN	KC	12/31/2025	8:43:00 AM
SMTH-1527	KI	1020	KITCHEN	KC	12/31/2025	8:45:00 AM
SMTH-1528	KI	1020	KITCHEN	SN	12/31/2025	8:45:00 AM

Samples Submitted 3

PB 2008 Bkng 11/2/26

RECEIVED
 EMSL ANALYTICAL, INC.
 Carle Place, NY
 DEC 31 25, AM10:41

Building Address

478 Edgewood Avenue Street.
 St. James, NY 11780

Walk In

Analysis Type: ELAP 200.5

Lab Received: DAVID WHARTON 12/31/05
 10:41 AM

Signature: David Wharton

Samplers Name: Jacett Bonface

Samplers Signature: J

JCB Project Manager: Bryan Ezel Page 4 of 4

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557982**LIMS Reference ID:** ED57982**EMSL Customer ID:** JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 23-54650 / Smithtown Central School District /
Nesaquaque Middle School NES / 478 Edgewood
Avenue Street, St. James, NY 11780
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/31/2025 10:41
Reported: 01/02/2026 12:30

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SMTH-1524 Lims Reference ID: ED57982-01 Matrix: Drinking Water Sampled: 12/31/25 00:00:00									
Metals									
Lead 1.4 1 1.0 µg/L 01/02/26 11:22 01/02/26 11:22 BP EPA 200.8 (DA)/EPA 200.8									
Sample: SMTH-1527 Lims Reference ID: ED57982-02 Matrix: Drinking Water Sampled: 12/31/25 00:00:00									
Metals									
Lead < 1.0 1 1.0 µg/L 01/02/26 11:23 01/02/26 11:23 BP EPA 200.8 (DA)/EPA 200.8									
Sample: SMTH-1528 Lims Reference ID: ED57982-03 Matrix: Drinking Water Sampled: 12/31/25 00:00:00									
Metals									
Lead < 1.0 1 1.0 µg/L 01/02/26 11:25 01/02/26 11:25 BP EPA 200.8 (DA)/EPA 200.8									



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557982

LIMS Reference ID: ED57982

EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 23-54650 / Smithtown Central School District /
Nesaquaque Middle School NES / 478 Edgewood
Avenue Street, St. James, NY 11780
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/31/2025 10:41
Reported: 01/02/2026 12:30

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com for a complete listing of parameters for which EMSL is certified.



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557982

LIMS Reference ID: ED57982

EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 23-54650 / Smithtown Central School District /
Nesaquaque Middle School NES / 478 Edgewood
Avenue Street, St. James, NY 11780
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/31/2025 10:41
Reported: 01/02/2026 12:30

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #:

23-54650

Building: Branch Brook Elementary School

BRAN

E057455

Page 1 of 1

Client:

Smithtown Central School District

Retest/New Install

Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
SMTH-2026	KI	NA	KITCHEN	KC	11/26/2025	5:55:00 AM
SMTH-2027	KI	NA	KITCHEN	HW	11/26/2025	5:56:00 AM
SMTH-2036	HA	1024	Lobby/Entrance	WF	11/26/2025	6:02:00 AM
SMTH-2037	HA	1024	Lobby/Entrance	WC	11/26/2025	6:02:00 AM
SMTH-2041	OF	1021A	Main Office Mail Room	KC	11/26/2025	6:05:00 AM
SMTH-2050	FL	1006	Faculty Room 7	KC	11/26/2025	6:08:00 AM
SMTH-2056	HA	NA	Corridor by Room 12A	WC	11/26/2025	6:25:00 AM
SMTH-2057	HA	NA	Corridor by Room 12A	WC	11/26/2025	6:25:00 AM

Samples Submitted 8

RECEIVED

EMSL ANALYTICAL, INC.

Carle Place, NY

NOV 28 25, PM03:40



Building Address

15 Redgely Road

Smithtown, NY 11787

Analysis Type: ELAP 200.5

Lab Received:

Sevn CML 11/28/25

Signature:

Boyan Frelih 3:40 PM

Samplers Name: Jarett Boniface

Samplers Signature:

JCB Project Manager:

Boyan Frelih

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557455**LIMS Reference ID:** ED57455**EMSL Customer ID:** JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 15 Redgely Road Smithtown NY 11787, Branch Brook Elementary School, JCB#23-54650, Smithtown central School District
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 11/28/2025 15:40
Reported: 12/23/2025 10:19

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SMTM-2026									
Metals									
Lead	95.3		1	1.0	µg/L	12/10/25 02:12	12/10/25 02:12	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: SMTM-2027									
Metals									
Lead	16.3		1	1.0	µg/L	12/10/25 02:16	12/10/25 02:16	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: SMTM-2036									
Metals									
Lead	< 1.0		1	1.0	µg/L	12/10/25 02:17	12/10/25 02:17	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: SMTM-2037									
Metals									
Lead	< 1.0		1	1.0	µg/L	12/10/25 02:19	12/10/25 02:19	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: SMTM-2041									
Metals									
Lead	46.1		1	1.0	µg/L	12/10/25 02:20	12/10/25 02:20	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: SMTM-2050									
Metals									
Lead	7.6		1	1.0	µg/L	12/10/25 02:21	12/10/25 02:21	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: SMTM-2056									
Metals									
Lead	1.1		1	1.0	µg/L	12/10/25 02:22	12/10/25 02:22	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: SMTM-2057									
Metals									
Lead	< 1.0		1	1.0	µg/L	12/10/25 02:24	12/10/25 02:24	DAZ	EPA 200.8 (DA)/EPA 200.8



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557455

LIMS Reference ID: ED57455

EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 15 Redgely Road Smithtown NY 11787, Branch Brook Elementary School, JCB#23-54650, Smithtown central School District
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 11/28/2025 15:40
Reported: 12/23/2025 10:19

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com for a complete listing of parameters for which EMSL is certified.



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557455

LIMS Reference ID: ED57455

EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 15 Redgely Road Smithtown NY 11787, Branch Brook Elementary School, JCB#23-54650, Smithtown central School District
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 11/28/2025 15:40
Reported: 12/23/2025 10:19


Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #:

23-54650

Building: Nesconset Elementary School

NESC

ED57616

Page 1 of 1

Client:

Smithtown Central School District

Retest/New Install

Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
SMTH-2151	KI	1028	Kitchen	SN	12/5/2025	6:41:00 AM
SMTH-2152	KI	1028	Kitchen	KC	12/5/2025	6:42:00 AM
SMTH-2153	KI	1028	Kitchen	KC	12/5/2025	6:39:00 AM
SMTH-2154	KI	1028	Kitchen	KC	12/5/2025	6:39:00 AM
SMTH-2156	HA	1038	Corridor by Gym	WC	12/5/2025	6:46:00 AM
SMTH-2183	FL	1025	Faculty Room	KC	12/10/2025	6:44:00 AM
SMTH-2203	FL	1019	Room 17	HW	12/5/2025	7:19:00 AM
SMTH-2206	CR	NA	Classroom Adjacent to Room 25	DW	12/5/2025	7:08:00 AM
SMTH-2210	HA	NA	Corridor by New Gym Entrance	DW	12/5/2025	7:45:00 AM
SMTH-2211	HA	NA	Corridor Around Corner from New Gym	WC	12/5/2025	7:45:00 AM
SMTH-2231	CR	NA	CLASSROOM 44	DW	12/5/2025	7:25:00 AM
SMTH-2234	NO	1062	Room 31	KC	12/5/2025	7:23:00 AM
SMTH-2240	CR	1073	Room 37	DW	12/5/2025	7:03:00 AM

Samples Submitted 13

Pb 200.8 Kothiyawala
12/15/25



Pb 200.8
Kothiyawala
12/11/25

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
DEC 10 25, PM01:50

Building Address

29 Gibbs Pond Road
Nesconset, NY 11767

Analysis Type: ELAP 200.5

Lab Received: Sean Bell 12/10/25

Signature: MM Bell

Samplers Name: Uman Zhang

Samplers Signature: Uman Zhang

JCB Project Manager: Bryan Eelus

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
 Telephone: 516.997.7251 Fax: 856-786-5974
 EMSL-CP-06

EMSL Order ID: 062557616**LIMS Reference ID:** ED57616**EMSL Customer ID:** JCBR50

Attention: Bryan Ezelius
 J.C. Broderick & Associates [JCBR50]
 1775 Expressway Drive North, Suite 1
 Hauppauge, NY 11788
 (631) 584-5492
 bezelius@jcbroderick.com

Project Name: 29 Gibbs Pond Road, Nesconset NY 11767,
 Nesconset Elementary School, JCB#:23-54650,
 Smithtown Central School District

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeremy Bish

Received: 12/10/2025 13:50

Reported: 12/23/2025 10:39

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SMTM-2151									
Metals									
Lead	311	5	5.0	µg/L	12/15/25 17:54	12/15/25 17:54	KT1	EPA 200.8 (Dig)/EPA 200.8	
Sample: SMTM-2152									
Metals									
Lead	156	2	2.0	µg/L	12/15/25 17:55	12/15/25 17:55	KT1	EPA 200.8 (Dig)/EPA 200.8	
Sample: SMTM-2153									
Metals									
Lead	116	2	2.0	µg/L	12/11/25 19:44	12/11/25 19:44	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTM-2154									
Metals									
Lead	3.9	1	1.0	µg/L	12/11/25 19:36	12/11/25 19:36	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTM-2156									
Metals									
Lead	74.6	1	1.0	µg/L	12/11/25 19:38	12/11/25 19:38	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTM-2183									
Metals									
Lead	5.1	1	1.0	µg/L	12/11/25 20:03	12/11/25 20:03	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTM-2203									
Metals									
Lead	21.7	1	1.0	µg/L	12/11/25 20:04	12/11/25 20:04	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTM-2206									
Metals									
Lead	8.5	1	1.0	µg/L	12/11/25 20:06	12/11/25 20:06	KT1	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTM-2210									
Metals									

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557616**LIMS Reference ID:** ED57616**EMSL Customer ID:** JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 29 Gibbs Pond Road, Nesconset NY 11767,
Nesconset Elementary School, JCB#:23-54650,
Smithtown Central School District

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeremy Bish

Received: 12/10/2025 13:50

Reported: 12/23/2025 10:39

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SMTH-2210 (Continued)									
Metals (Continued)									
Lead	8.4		1	1.0	µg/L	12/11/25 20:09	12/11/25 20:09	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH-2211									
Metals									
Lead	1.4		1	1.0	µg/L	12/11/25 20:11	12/11/25 20:11	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH-2231									
Metals									
Lead	6.5		1	1.0	µg/L	12/11/25 20:12	12/11/25 20:12	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH-2234									
Metals									
Lead	84.9		1	1.0	µg/L	12/15/25 17:38	12/15/25 17:38	KT1	EPA 200.8 (Dig)/EPA 200.8
Sample: SMTH-2240									
Metals									
Lead	239		5	5.0	µg/L	12/11/25 20:36	12/11/25 20:36	KT1	EPA 200.8 (DA)/EPA 200.8



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557616

LIMS Reference ID: ED57616

EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 29 Gibbs Pond Road, Nesconset NY 11767,
Nesconset Elementary School, JCB#:23-54650,
Smithtown Central School District

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeremy Bish

Received: 12/10/2025 13:50

Reported: 12/23/2025 10:39

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com for a complete listing of parameters for which EMSL is certified.



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557616

LIMS Reference ID: ED57616

EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 29 Gibbs Pond Road, Nesconset NY 11767,
Nesconset Elementary School, JCB#:23-54650,
Smithtown Central School District

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeremy Bish

Received: 12/10/2025 13:50

Reported: 12/23/2025 10:39

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #:

23-54650

Building: Commissary Warehouse

GHW

EDS7447

Client:

Smithtown Central School District

Retest/New Install

Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
SMTH-2244	OF	1002	Main Warehouse Area Locker Room	KC	11/26/2025	8:56:00 AM
SMTH-2247	KI	1012	Kitchen	KC	11/26/2025	8:49:00 AM
SMTH-2248	KI	1012	Kitchen	HW	11/26/2025	8:49:00 AM
SMTH-2249	KI	1012	Kitchen	KC	11/26/2025	8:41:00 AM
SMTH-2250	KI	1012	Kitchen	KC	11/26/2025	8:41:00 AM
SMTH-2252	KI	1012	Kitchen	KC	11/26/2025	8:41:00 AM
SMTH-2253	OF	1013	Kitchen School Lunch Office	KC	11/26/2025	8:39:00 AM
SMTH-2390	KI	1012	Kitchen	KC	11/26/2025	8:40:00 AM
SMTH-2391	KI	1012	Kitchen	PK	11/26/2025	8:44:00 AM
SMTH-2392	KI	1012	Kitchen	PK	11/26/2025	8:44:00 AM
SMTH-2393	KI	1012	Kitchen	PK	11/26/2025	8:45:00 AM
SMTH-3278	HA	1009	Corridor (Warehouse-Kitchen Area)	WF	11/26/2025	8:55:00 AM
SMTH-3279	HA	1009	Corridor (Warehouse-Kitchen Area)	WC	11/26/2025	8:55:00 AM
SMTH-3299	OF	1013	Kitchen School Lunch Office	BW	11/26/2025	8:53:00 AM

RECEIVED
FMS ANALYTICAL, INC.

Samples Submitted Carrie Place, NY

NOV 26 25, PM03:39



Building Address

150 Southern Boulevard
Smithtown, NY 11787

Analysis Type: ELAP 200.5

Lab Received: 11/26/2025

Signature: Carrie

Samplers Name: Vinson Zberg

Samplers Signature: Vin Zberg

JCB Project Manager: Brian Ezelius

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557447**LIMS Reference ID:** ED57447**EMSL Customer ID:** JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: JCB# 23-54650, Commissary Warehouse,
Smithtown Central School District, 150 Southern
Boulevard, Smithtown, NY 11787
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 11/28/2025 15:39
Reported: 12/23/2025 10:12

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SMTH-2244									
Metals									
Lead	2.5	1	1.0	µg/L	12/10/25 02:43	12/10/25 02:43	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-2247									
Metals									
Lead	5.1	1	1.0	µg/L	12/10/25 02:46	12/10/25 02:46	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-2248									
Metals									
Lead	5.0	1	1.0	µg/L	12/10/25 02:48	12/10/25 02:48	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-2249									
Metals									
Lead	9.3	1	1.0	µg/L	12/10/25 02:49	12/10/25 02:49	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-2250									
Metals									
Lead	12.5	1	1.0	µg/L	12/10/25 02:50	12/10/25 02:50	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-2252									
Metals									
Lead	9.4	1	1.0	µg/L	12/10/25 02:54	12/10/25 02:54	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-2253									
Metals									
Lead	6.8	1	1.0	µg/L	12/10/25 02:56	12/10/25 02:56	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-2390									
Metals									
Lead	43.9	1	1.0	µg/L	12/10/25 02:57	12/10/25 02:57	DAZ	EPA 200.8 (DA)/EPA 200.8	
Sample: SMTH-2391									
Metals									

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557447**LIMS Reference ID:** ED57447**EMSL Customer ID:** JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: JCB# 23-54650, Commissary Warehouse,
Smithtown Central School District, 150 Southern
Boulevard, Smithtown, NY 11787
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 11/28/2025 15:39
Reported: 12/23/2025 10:12

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SMTH-2391 (Continued)									
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	12/10/25 02:58	12/10/25 02:58	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH-2392									
Metals									
Lead	3.3		1	1.0	µg/L	12/10/25 03:00	12/10/25 03:00	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH-2393									
Metals									
Lead	2.0		1	1.0	µg/L	12/10/25 03:01	12/10/25 03:01	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH-3278									
Metals									
Lead	< 1.0		1	1.0	µg/L	12/10/25 03:05	12/10/25 03:05	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH-3279									
Metals									
Lead	< 1.0		1	1.0	µg/L	12/10/25 03:06	12/10/25 03:06	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH-3299									
Metals									
Lead	< 1.0		1	1.0	µg/L	12/10/25 03:10	12/10/25 03:10	DAZ	EPA 200.8 (DA)/EPA 200.8



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557447

LIMS Reference ID: ED57447

EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: JCB# 23-54650, Commissary Warehouse,
Smithtown Central School District, 150 Southern
Boulevard, Smithtown, NY 11787
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 11/28/2025 15:39
Reported: 12/23/2025 10:12

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com for a complete listing of parameters for which EMSL is certified.



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557447

LIMS Reference ID: ED57447

EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: JCB# 23-54650, Commissary Warehouse,
Smithtown Central School District, 150 Southern
Boulevard, Smithtown, NY 11787
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 11/28/2025 15:39
Reported: 12/23/2025 10:12

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492

FAX: (631) 584-3395

JCB #:

23-54650

Building: Commissary Warehouse

GHW

ED57979

Page 1 of 1

Client:

Smithtown Central School District

Retest/New Install []

Turn Around: Normal 1 wk Rush

48 HR

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
SMTH-2247	KI	1012	Kitchen	KC	12/31/2025	7:20:00 AM
SMTH-2249	KI	1012	Kitchen	KC	12/31/2025	7:18:00 AM
SMTH-2250	KI	1012	Kitchen	KC	12/31/2025	7:15:00 AM
SMTH-2252	KI	1012	Kitchen	KC	12/31/2025	7:16:00 AM
SMTH-2253	OF	1013	Kitchen School Lunch Office	KC	12/31/2025	7:23:00 AM
SMTH-2390	KI	1012	Kitchen	KC	12/31/2025	7:13:00 AM

Samples Submitted 6

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
DEC 31 25, AM10:42

Pb 200.8 B/long 11/2/26

Pb 200.8
Walk In
11/2/26

EMSL RECEIVED
DEC 31 25, AM10:42

Building Address

150 Southern Boulevard
Smithtown, NY 11787

Walk In

Analysis Type: ELAP 200.5

Lab Received: DAVID MARTIN 12/31/25
10:42 AM

Signature: David white

Samplers Name: Jarett Boniface

Samplers Signature:

JCB Project Manager: Bryan Ezelio

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557979**LIMS Reference ID:** ED57979**EMSL Customer ID:** JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 23-54650 / Smithtown Central School District /
Commissary Warehouse GHW / 150 Southern
Boulevard, Smithtown, NY 11787
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/31/2025 10:42
Reported: 01/03/2026 08:58

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SMTH-2247									
Metals									
Lead	6.0		1	1.0	µg/L	01/02/26 19:32	01/02/26 19:32	KT1	EPA 200.8 (Dig)/EPA 200.8
Sample: SMTH-2249									
Metals									
Lead	2.3		1	1.0	µg/L	01/02/26 10:40	01/02/26 10:40	BP	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH-2250									
Metals									
Lead	1.2		1	1.0	µg/L	01/02/26 10:44	01/02/26 10:44	BP	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH-2252									
Metals									
Lead	< 1.0		1	1.0	µg/L	01/02/26 10:45	01/02/26 10:45	BP	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH-2253									
Metals									
Lead	1.9		1	1.0	µg/L	01/02/26 11:17	01/02/26 11:17	BP	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH-2390									
Metals									
Lead	139		2	2.0	µg/L	01/02/26 19:47	01/02/26 19:47	KT1	EPA 200.8 (Dig)/EPA 200.8

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557979

LIMS Reference ID: ED57979

EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 23-54650 / Smithtown Central School District / Commissary Warehouse GHW / 150 Southern Boulevard, Smithtown, NY 11787
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/31/2025 10:42
Reported: 01/03/2026 08:58

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com for a complete listing of parameters for which EMSL is certified.



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557979

LIMS Reference ID: ED57979

EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 23-54650 / Smithtown Central School District /
Commissary Warehouse GHW / 150 Southern
Boulevard, Smithtown, NY 11787
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/31/2025 10:42
Reported: 01/03/2026 08:58

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.

1775 Expressway North Hauppauge, NY 11788

TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #:

23-54650

Building: Facilities and Transportation

SMFA

Client:


Smithtown Central School District

Retest/New Install

Turn Around: (Normal 1 wk) Rush _____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
SMTH-2269	KI	1003	Kitchen	KC	12/2/2025	7:02:00 AM
SMTH-2271	KI	1009	Kitchenette	KC	12/2/2025	7:05:00 AM
SMTH-2275	HA	B&G1003	Corridor	WF	12/2/2025	7:20:00 AM

Samples Submitted 3



RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
DEC 17 25, PM02:06

Building Address
479 Edgewood Avenue
Smithtown, NY 11787

Analysis Type: ELAP 200.5

Lab Received: S. Chervofsky

Signature: S. Chervofsky

12/17/25 2:06pm

Samplers Name: Vinson Zheng

Samplers Signature: Vin

JCB Project Manager: Bryan Ezelius

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557769**LIMS Reference ID:** ED57769**EMSL Customer ID:** JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: JCB#23-54650, Smithtown Central School District, Facilities and Transportation, 479 Edgewood Avenue, Smithtown, NY 11787
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/17/2025 14:06
Reported: 12/23/2025 10:56

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: SMTH-2269									
Metals									
Lead	1.4		1	1.0	µg/L	12/18/25 13:49	12/18/25 13:49	BP	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH-2271									
Metals									
Lead	3.0		1	1.0	µg/L	12/18/25 13:51	12/18/25 13:51	BP	EPA 200.8 (DA)/EPA 200.8
Sample: SMTH-2275									
Metals									
Lead	11.0		1	1.0	µg/L	12/18/25 13:52	12/18/25 13:52	BP	EPA 200.8 (DA)/EPA 200.8



EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557769

LIMS Reference ID: ED57769

EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: JCB#23-54650, Smithtown Central School District, Facilities and Transportation, 479 Edgewood Avenue, Smithtown, NY 11787
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/17/2025 14:06
Reported: 12/23/2025 10:56

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com for a complete listing of parameters for which EMSL is certified.

**EMSL Analytical, Inc.**

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax: 856-786-5974
EMSL-CP-06

EMSL Order ID: 062557769**LIMS Reference ID:** ED57769**EMSL Customer ID:** JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: JCB#23-54650, Smithtown Central School District, Facilities and Transportation, 479 Edgewood Avenue, Smithtown, NY 11787
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeremy Bish
Received: 12/17/2025 14:06
Reported: 12/23/2025 10:56

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Attachment 4:

Laboratory Certifications



J.C. Broderick & Associates, Inc.

Environmental Consulting & Testing

1775 Expressway Drive North
Hauppauge, New York 11788
631.584.5492 fax 631.584.3395

NEW YORK STATE DEPARTMENT OF HEALTH
WADSWORTH CENTER



Expires 12:01 AM April 01, 2026
Issued April 01, 2025

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE

Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MR. DANIEL CLARKE
EMSL ANALYTICAL, INC.
528 MINEOLA AVE.
CARLE PLACE, NY 11514

NY Lab Id No: 11469

*is hereby APPROVED as an Environmental Laboratory in conformance with the
National Environmental Laboratory Accreditation Conference Standards (2016) for the category
ENVIRONMENTAL ANALYSES POTABLE WATER
All approved analytes are listed below:*

Bacteriology

Coliform, Total / E. coli (Qualitative)	SM 21, 23 9222A,B,C
	SM 20, 21-23 9223B (-04) (Colilert)
E. coli (Enumeration)	SM 21, 23 9222A,B,C
Heterotrophic Plate Count	SM 20, 21-23 9215B (-04)

Metals I

Copper, Total	EPA 200.8 Rev. 5.4
Lead, Total	EPA 200.8 Rev. 5.4
Silver, Total	EPA 200.8 Rev. 5.4

Miscellaneous

Asbestos	EPA 100.2
----------	-----------

Serial No.: 70480

Property of the New York State Department of Health. Certificates are valid only at the address shown and must be conspicuously posted by the laboratory. Continued accreditation depends on the laboratory's successful ongoing participation in the Program. Consumers may verify a laboratory's accreditation status online at <https://apps.health.ny.gov/pubdoh/applinks/wc/elappublicweb/>, by phone (518) 485-5570 or by email to elap@health.ny.gov.

